

**CONTRACT DOCUMENTS  
AND  
SPECIFICATIONS  
FOR  
PROJECT NO. WPC 25-1  
FY'25 WATER POLLUTION CONTROL  
CAPITAL EQUIPMENT REPLACEMENTS**

---

**ATTENDANCE AT PRE-BID CONFERENCE IS MANDATORY**

---

PREPARED BY:  
HOLLOWAY, UPDIKE AND BELLEN, INC.  
2001 N WILLOW AVENUE  
BROKEN ARROW, OK 74012  
918-251-0717 OFFICE  
918-251-0754 FAX



ERIC LEE, DIRECTOR  
WATER AND SEWER DEPARTMENT

---

Account Numbers: 7503362-544003, 7503365-544003,  
2431S00027.SewerTreat.SwrTrt.7523N.75233300-541101

---

Water and Sewer Department  
175 E. 2<sup>nd</sup> Street, Suite 1300  
Tulsa, Oklahoma 74103  
(918) 596-9870

**TECHNICAL SPECIFICATIONS**

**PROJECT SPECIFICATIONS**

**FOR**

**TULSA METROPOLITAN UTILITY AUTHORITY**

**PROJECT NO. WPC 25-1**

**FY'25 WATER POLLUTION CONTROL CAPITAL EQUIPMENT REPLACEMENTS  
TULSA, OKLAHOMA**

**TABLE OF CONTENTS**

<b>SECTION</b>	<b>PAGES</b>
<b>200 INTRODUCTION</b>	<b>1-2</b>
<b>201 QUALIFICATION REQUIREMENTS</b>	<b>2</b>
<b>202 SUMMARY OF BID ITEMS</b>	<b>2-3</b>
<b>203 DESCRIPTION OF BID ITEMS/WORK</b>	
203.100 Magnetic Flow Meters	6
203.400 Southside Main Lift Station Pump	11
203.500 Gravity Thickener Equipment	20
203.620 Diffusers	3
203.640 Blower System	8
203.998 Mobilization	1
203.999 Unforeseen Mechanical, Electrical and Plumbing	1
<b>204 ANCILLARY EQUIPMENT &amp; WORK</b>	
204.0 Ancillary Equipment	7
204.4 General Electrical	8
204.5 Painting	4
204.6 Concrete Coating	4
204.7 Concrete Rehabilitation	6
204.8 Cast-In-Place Concrete	16
204.9 Concrete Reinforcement	5
204.10 Construction Joints, Expansion Joints and Waterstops	6
204.11 Concrete Formwork	4
204.12 Carpentry and Caulking	7
<b>205 SUBMITTALS</b>	<b>1-9</b>
<b>206 MONTHLY PROGRESS REPORTS AND PROGRESS MEETINGS</b>	<b>10</b>
<b>207 SECURITY</b>	<b>10-12</b>
<b>208 SAFETY</b>	<b>12-13</b>
<b>209 PROTECTION OF PROPERTY</b>	<b>13-14</b>
<b>210 PROTECTION OF MATERIALS</b>	<b>14</b>
<b>211 REFERENCES TO OTHER SPECIFICATIONS</b>	<b>14</b>
<b>212 CLEAN-UP</b>	<b>14</b>
<b>213 PLACING WORK IN SERVICE</b>	<b>14-15</b>
<b>214 PAYMENT</b>	<b>15</b>

INTRODUCTION:

200.1 Project work shall include all equipment, labor, materials, hardware, cable, terminations, and incidentals necessary to remove existing equipment that is to be replaced, install the new equipment, and place the new equipment in fully operational, functional, and warrantable service. All equipment to be supplied shall be brand new current year model and not used, remanufactured, or discontinued items.

200.2 The Authority's contact people are:

Water Pollution Control:	Cindy Cantero– Section Manager 175 E. 2 <sup>nd</sup> Street, Suite 1300 Tulsa, OK 74103 918-596-9870 ccantero@cityoftulsa.org
Northside Wastewater Treatment Plant Lower Bird Creek WWTP Port South Lift Station	Colin Wilmering – Northside WWTP and Lower Bird Creek WWTP Superintendent 5628 N 105 <sup>th</sup> East Avenue Tulsa, OK 74117 918-591-4570
Southside Wastewater Treatment Plant Southeast Basin Lift Station	Josh Fisher – Southside WWTP Superintendent 5300 S. Elwood Avenue Tulsa, OK 74107 918-591-4450

201 QUALIFICATION REQUIREMENTS

201.1 Only contractors holding a valid pre-qualification certificate from the Tulsa Metropolitan Utility Authority in Classification A or D, General Utility Constructions, are eligible to bid on this project. No additional qualification information is required to be submitted.

201.2 Only contractors that attend the mandatory pre-bid conference will be allowed to bid on this project.

202 SUMMARY OF BID ITEMS

The Basis of Award shall be determined by the Total Base Bid plus Additive Alternates No. 1-3. Any proposal submitted incomplete shall be considered non-responsive.

<b>BID ITEM</b>	<b>SPEC NO.</b>	<b>DESCRIPTION</b>
1	203.998	Mobilization
2	203.100	All materials, labor, equipment, and supervision required for the Gallery #2 (North) RAS Meter Replacements at the NSWWTP per these specifications.
3	203.300	All materials, labor, equipment, and supervision required for the Sodium Hypochlorite Metering Pump Panel Replacements at the NSWWTP per these specifications.
4	203.400	All materials, labor, equipment, and supervision required for the Main Lift Station Pump #1 Replacement at the SSWWTP per these specifications.
5	203.500	All materials, labor, equipment, and supervision required for the Thickener #1 Replacement at the SSWWTP per these specifications.
6	203.620	All materials, labor, equipment, and supervision required for the Aeration Basin #2 Diffusers and Locking Ring Replacement at the SSWWTP per these specifications.
7	203.640	All materials, labor, equipment, and supervision required for the WAS Blower and Blower Piping Improvements at the SSWWTP per these specifications.
8	203.999	Mechanical, Electrical, Plumbing and Unforeseen Circumstances Allowance for various mechanical, electrical, plumbing, and unforeseen work not shown on the construction drawings or specified in the contract documents.
<b>ADDITIVE ALTERNATE NO. 1</b>		
9	203.200	All materials, labor, equipment, and supervision required for the Digester 1-2 and 3-4 Buildings Hatch Safety and Sample Building Hinge Improvements at the NSWWTP per these specifications.
<b>ADDITIVE ALTERNATE NO. 2</b>		
10	203.320	All materials, labor, equipment, and supervision required for the Sodium Hypochlorite Metering Pump and Back Panel Replacement at the NSWWTP per these specifications.
<b>ADDITIVE ALTERNATE NO. 3</b>		
11	203.700	All materials, labor, equipment, and supervision required for the Lift Station Pipe Repairs at the Southeast Basin Lift Station per these specifications.

END OF SECTION

**TMUA PROJECT NO. WPC 25-1  
FY'25 WATER POLLUTION CONTROL CAPITAL EQUIPMENT REPLACEMENTS  
SPECIFICATION CERTIFICATION SHEET**

- 200 INTRODUCTION**
- 201 QUALIFICATION REQUIREMENTS**
- 202 SUMMARY OF BID ITEMS**
- 203 DESCRIPTION OF BID ITEMS/WORK**
  - 203.100 Magnetic Flow Meters
  - 203.400 Southside Main Lift Station Pump
  - 203.500 Gravity Thickener Equipment
  - 203.620 Diffusers
  - 203.640 Blower System
  - 203.998 Mobilization
  - 203.999 Unforeseen Mechanical, Electrical and Plumbing
- 204 ANCILLARY EQUIPMENT & WORK**
  - 204.4 General Electrical
  - 204.5 Painting
  - 204.6 Concrete Coating
  - 204.7 Concrete Rehabilitation
  - 204.8 Cast In Place Concrete
  - 204.9 Concrete Reinforcement
  - 204.10 Construction Joints, Expansion Joints and Waterstops
  - 204.11 Concrete Formwork
  - 204.12 Carpentry and Caulk
- 205 SUBMITTALS**
- 206 MONTHLY PROGRESS REPORTS & PROGRESS MEETINGS**
- 207 SECURITY**
- 208 SAFETY**
- 209 PROTECTION OF PROPERTY**
- 210 PROTECTION OF MATERIALS**
- 211 REFERENCES TO OTHER SPECIFICATIONS**
- 212 CLEAN-UP**
- 213 PLACING WORK IN SERVICE**
- 214 PAYMENT**
- END OF SPECIFICATIONS**



**Stephen Tolar, P.E., S.E.**  
**OK 20679**  
**Holloway, Updike and Bellen, Inc.**  
**C.A. No. 219**  
**Expires June 30, 2025**

203.100 All materials, labor, equipment, and supervision required for installing new Magnetic Flow Meters for wastewater service per these specifications.

203.100.1 The work consists of demolishing existing meters and installing new magnetic flow meters in accordance with the following schedule:

LOCATION	QUANTITY	SIZE
Northside WWTP WAS system in Gallery 2 (north gallery)	2	16"

203.100.2 The project includes the correct and complete installation of new components specified herein in conformance with the manufacturer's instructions and recommendations for installation, subsequent testing of the new units and ensuring all components are in proper operation.

203.100.3 Contractor shall sequence work so that meters are replaced one at a time while maintaining operation of adjacent units.

203.100.4 Contractor shall be knowledgeable about and shall field verify all elevations and dimensions of existing structures, piping, conduit, valves and equipment that in any way, directly or indirectly, relates to the removal of existing equipment and/or installation of new equipment. Work shall be based on field measurements. The Authority will make information on file that pertains to the existing equipment available for review.

203.100.5 Project work shall include all materials, equipment, labor, and supervision, necessary to complete the project as specified herein including, but not limited to, any and all crane work, rigging, delivery and complete installation of components to fully operational and warrantable condition.

203.100.6 All work requiring flow stoppage or equipment removed from service must be scheduled 48 hours in advance with Plant Superintendent. Contractor shall have valves, temporary pumps and any other necessary materials and equipment at the installation site prior to flow stoppage. It is the contractor's responsibility to prepare the impacted system and any related systems for disassembly. This includes closing of upstream/downstream valves and pumping down any reservoirs as necessary.

203.100.7 Summary: Electromagnetic flow meters shall utilize bipolar pulse DC coil excitation to measure voltage induced by the flow of conductive liquid through a magnetic flux. The voltage shall be linearly proportional to flow velocity from 0.033 to 33 feet per second.

203.100.8 Submittals: Furnish complete Product Data, Shop Drawings, Test Reports, Operating Manuals, Record Drawings, Manufacturer's certifications, Manufacturer's Field Reports.

203.100.9 Delivery, Storage and Handling:

203.100.9.1 Store all instruments in a dedicated structure with space conditioning to meet the recommended storage requirements provided by the manufacturer.

203.100.9.2 Any instruments that are not stored in strict conformance with the manufacturer's recommendation shall be replaced.

203.100.10 Warranty: The meter shall have standard one year warranty from startup date.

203.100.11 Products

203.100.11.1 Manufacturer: Endress+Hauser Promag 400 W Series, or equal.

203.100.11.2 Manufacturer Units

203.100.11.2.1 The flow meter shall be a flanged sensor which complies with AWWA C751 and a remote transmitter with interconnecting cables up to 650 feet in length. Contractor to field confirm actual cable lengths required prior to submittal.

- The flow metering system shall be microprocessor-based and possess a non-volatile memory to store the sensor calibration and transmitter setup information. The electronics shall be interchangeable for meters sizes 1"- 90".
- The sensor shall be the proper size to measure the design flow rate of the piping and measure bi-directional flow as a standard.
- The sensor shall consist of a stainless steel flow tube with AWWA C207 carbon steel flanges. The flanges shall be Class 150 for 24" and smaller, and AWWA Class D for 28" and larger.
  - Sensors from 1"-12" shall have fixed (welded) or rotating lap joint flanges.
  - Sensors from 14"-120" shall have the flanges welded to the sensor body.
- The sensor liner and electrode material shall be chosen to be compatible with the process fluid.
- The sensor tube shall be lined with hard rubber in accordance with NSF-61.
- The sensor shall house two measuring electrodes, a grounding electrode, and one for physical empty pipe detection. The electrodes shall be bullet-nosed shaped and made of 316L SS.
- Meters shall have an unrestricted mounting magnetic flowmeter sensor for applications without the typical inlet/outlet straight pipe run requirements. The full bore magnetic flowmeter in sizes 1"-120" shall maintain zero pressure loss while achieving 0.5% of rate accuracy even when mounted directly before or after a piping elbow, T-fitting or insertion device. This flow tube shall have four measuring electrodes (sizes 1-2.5") and six measuring electrodes (sizes 3"-120") plus a grounding electrode and an empty pipe electrode.

- The external sensor housing shall enclose the coil assemblies and internal wiring. The materials shall be designed and constructed to prevent moisture ingress and promote corrosion resistance.
- The electrode circuit shall have a minimum impedance of  $10^{12}$  ohms to overcome moderate coating buildup.
  - The sensor shall be rated for NEMA 6P/IP68 service and shall allow for permanent immersion in water depths up to 10 feet.
- The transmitter shall be remotely mounted, and custom length cables shall be attached at the factory.
- The flow sensor shall be painted and certified according to ISO-12944 corrosion class. Third party modification or sensor preparations will not be accepted without type test documentation to support the exposure conditions, depth and duration of resistance.

203.100.11.2.2 The transmitter shall be a three-stage microprocessor controller mounted integrally or remotely as specified in the instrument schedule. The transmitter shall incorporate a universal 100-240 VAC/18-30 VDC power supply. The transmitter housing will carry a NEMA 4X rating and shall be constructed to prevent moisture ingress, promote corrosion resistance, and be impervious to saline environments.

- The transmitter shall allow local programming that can be operated through the enclosure window without opening the electrical enclosure.
- The transmitter display shall indicate simultaneous flow rate and total flow with 3 totalizers (forward, reverse, and net total) and user-selectable engineering units, readout of diagnostic error messages, and support 12 standard languages.
- The transmitter shall safeguard against entering of invalid data for the particular meter size and all programming parameters shall be access-code protected with a minimum requirement of dual passwords according to data sensitivity.
- The transmitter output shall be 4-20mA HART®, 0-20mA, pulse/frequency/ switch.
- The transmitter output(s) shall be integral to the magnetic flowmeter transmitter electronics and using an external third-party signal converter is unacceptable.
- There shall be no limitation of transmitter operational capability or diagnostic dependency between integral and compact mounting orientation.
- The transmitter output selected must be supported by add-on instructions (AOI), Level 3 add-on profiles (AOP), device drivers (DD), general station description (GSD) files, instructions and pre-engineered code.
- The transmitter shall support commissioning options via a service interface or device driver less operation via an internal web server accessible through a transmitter accessible RJ-45 Ethernet port or a WLAN (Wireless Local Area Network) connection as specified.
- The transmitter shall retain all setup parameters and accumulated measurements internally in non-volatile memory in the event of power failure. The memory unit shall be transferrable from a damaged unit or used for a duplicate device with no loss of device parameters or data stored.



- The transmitter shall be protected against voltage spikes from the power source with internal transient protection. Power consumption shall be no more than 16 VA, independent of meter size.
- Device failure modes, self-monitoring characteristics and remedy diagnosis shall follow NAMUR standards NE 43 and NE 107.
- The transmitter shall provide access to service and monitoring parameters designed to identify transient or permanent process influences.
- The transmitter and sensor shall include a method to verify flow meter performance to the original manufacturer specifications.
  - The system shall be traceable to factory calibration using a third party, attested onboard system pursuant to ISO standards.
  - The verification technique shall not require external handhelds, interfaces, special tooling or electrical access for a verification to be performed.
  - The transmitter shall store up to eight verifications in the microprocessor.
  - A verification of the system shall be possible at any time, locally or remotely, on demand and under process conditions.
  - The verification report shall be compliant to common quality systems such as ISO 9000 7.6.a to prove reliability of the meter specified accuracy

203.100.12 Accessories

203.100.12.1 Stainless steel tag – labeled to match the contract documents.

203.100.12.2 Provide grounding rings, as per manufacture's recommendations.

203.100.13 Source Quality Control & Calibration

203.100.13.1 Magnetic flow meters shall be factory calibrated on an ISO-17025 accredited test stand per "General Requirements for the Competence of Testing and Calibration Laboratories" with certified accuracy traceable to NIST.

203.100.13.2 Evidence of accreditation shall originate from a national verification agency such as A2LA.

203.100.13.3 Each meter shall ship with a certificate of a 2-point calibration report exceeding stated standard accuracy of 0.5% of rate.

203.100.13.4 A real-time computer-generated printout of the actual calibration data points shall indicate apparent and actual flows. The flow calibration data shall be confirmed by the manufacturer and shipped with the meters to the project site.

203.100.13.5 The manufacturer shall provide complete documentation covering the traceability of all calibration instruments.

203.100.13.6 The manufacturer shall provide ISA data sheet ISA-TR20.00.01 as latest revision of form 20F2321. The manufacturer shall complete the form with all known data and model codes and dash out the inapplicable fields. Incomplete data sheets submitted will result in a

rejected submittal.

203.100.14 Safety

- 203.100.14.1 All electrical equipment shall meet the requirements of ANSI/NFPA 70, National Electric Code latest edition.
- 203.100.14.2 All devices shall be certified for use in hazardous areas: Class 1, Div. 2, Groups B/C; temperature rating T3 (200 deg. C)
- 203.100.14.3 All devices shall be suitable for use as non-incendive devices when used with appropriate non-incendive associated equipment. Devices with intrinsically safe ratings will normally be acceptable with vendor's approval.
- 203.100.14.4 Electrical equipment housing shall conform to NEMA 4X classification.
- 203.100.14.5 Non-intrinsically safe electrical equipment shall be approved by a Nationally Recognized Testing Laboratory (NRTL) such as FM, UL, CSA, etc. for the specified electrical area classification.
- 203.100.14.6 Electrical equipment specified as intrinsically safe shall qualify as "simple apparatus" or NRTL approved intrinsically safe equipment per ANSI/ISA-RP12.6 "Installation of Intrinsically Safe Systems for Hazardous (Classified) Locations," latest edition.
- 203.100.15 TAGGING: New equipment shall be tagged from the manufacturer with a permanent and visible tag showing the new equipment number using the City of Tulsa Equipment ID numbering system. Refer to Specification Section 204.3.6 for requirements.
- 203.100.16 TESTING: All associated new equipment and/or appurtenances shall be installed in strict conformance with the manufacturer's recommendations, which are to be submitted with the shop drawings. After completion of the installation, the equipment shall be tested by the Contractor under actual operating conditions to achieve the flow specified. The test shall be conducted under the supervision of the manufacturer's technical representative and in the presence of the owner's representative. Three (3) copies of test results shall be submitted to the Engineer. The equipment manufacturer shall furnish the services of a factory field representative to inspect the installation, testing and start up the equipment. Refer to Specification Section 205 for additional requirements.
- 203.100.17 OPERATION AND MAINTENANCE: The manufacturer shall provide information to the Owner's representative regarding the operation and maintenance of the equipment.
- 203.100.18 PRODUCT DELIVERY AND STORAGE: All equipment and components shall be delivered in ample time so as not to delay the Work. Store materials to permit easy access for inspection

and identification. Keep steel members off the ground, using pallets, platforms, and other supports. Protect steel members and packaged materials from corrosion and deterioration by keeping in covered storage and off of the ground.

203.100.19 LOCAL MONITORING AND DISPLAY: Unless specifically required otherwise, provide a local display wall mounted near the meter or pedestal mounted. See plan sheets for additional layout information. All Unistrut, bolts, fasteners, anchor bolts and other related components shall be 316 stainless steel. Seal tight flex conduiting shall be limited to 24" unless specifically noted otherwise within the contract documents. Provide layout and location of local display readout in the meter submittal.

END OF SECTION

203.400 All materials, labor, equipment, and supervision required for installing one (1) vertical dry pit pump(s) at the Southside Wastewater Treatment Plant Main Lift Station per these specifications

203.400.1 The work consists of installing vertical dry pit pump(s) and associated piping, fittings, bases/base modifications, frame supports, electrical and control improvements. The project includes the correct and complete installation of new components specified herein in conformance with the manufacturer's instructions and recommendations for installation, subsequent testing of the new units and ensuring all components are in proper operation.

203.400.2 Pump to be replaced is identified as Raw Sewage Pump No. 1 listed on the Table of Contents and the 203.400 Construction Drawings.

203.400.3 Refer to Drawings and Specifications for requirements. Existing disconnects shall be reused. Electrical work shall be in accordance with the General Electrical Section 204.4. See Drawings for additional electrical requirements. Additional wire, conduit and integration services are required for new temperature sensors.

203.400.4 Contractor shall be knowledgeable about and shall field verify all elevations and dimensions of existing piping, conduit, valves and equipment that in any way, directly or indirectly, relates to the removal of existing equipment and/or installation of new equipment. Work shall be based on field measurements. The Authority will make information on file that pertains to the existing equipment available for review.

203.400.5 Project work shall include all materials, equipment, labor, and supervision, necessary to complete the project as specified herein including, but not limited to, all crane work, rigging, delivery and complete installation of components to fully operational and warrantable condition.

All work requiring flow stoppage or equipment removed from service must be scheduled 48 hours in advance with Plant Superintendent. Contractor shall have valves, temporary pumps and any other necessary materials and equipment at the installation site prior to flow stoppage. It is the contractor's responsibility to prepare the impacted system and any related systems for disassembly. This includes closing of upstream/downstream valves and pumping down any reservoirs as necessary.

203.400.6 The Contractor shall furnish and install one vertical dry pit angle flow pumps and associated components as shown on the drawings and as specified herein to provide a complete and operable system.

- 203.400.6.1 Each unit shall be complete and shall include a volute/casing, front head, back head, motor, coupling, coupling guard, motor frame, mounting frame and HDG anchor bolts as required by the Manufacturer's recommendations.
  - 203.400.6.2 Manufacturer shall study the contract documents process and general drawings for locations of pumps with respect to structures and installation detail and location. Manufacturer shall certify with his quote to bidders that Manufacturer has reviewed the contract documents and recommends its pumps for satisfactory long term service for the pumps location and for the material to be pumped.
  - 203.400.6.3 Pumps and components for all pumps shall be of the same manufacturer to obtain standardization of warranty, performance, operation, spare parts, maintenance, and manufacturer's services.
- 203.400.7 The vertical dry pit angle flow pumps furnished under this contract shall be as manufactured by Grundfos-Morris (Basis of Design) or pre-approved equal as specified below.
- 203.400.7.1 Construction drawings have been prepared based on conceptual information provided by the pump manufacturer's representative for the pump model identified as the "Basis of Design". Other pumps listed may have different dimensions and may require additional fittings, supports or other work not shown on the construction drawings in order to provide a complete and functional installation. This work shall be included in the Contract's bid price. Any deviations from the construction drawings shall be submitted for approval with the pump submittal package.
  - 203.400.7.2 Manufacturer's regularly engaged in the manufacture of the type of equipment specified and can demonstrate equipment of their manufacture in actual service for a period of not less than 15 years will be considered as an acceptable manufacturer. Manufacturer's not named in the specifications meeting the minimum experience time requirement must submit to the engineer 10 working days prior to the bid date detailed information describing the equipment proposed to furnish. The detailed information

shall be included but not limited to dimensional data, materials of construction and an installation list with address, telephone number, and an individuals name directly employed by the owner of the equipment. Plan holders will be notified of approved manufacturers by addendum 5 working days prior to bid date.

203.400.7.3 The pump assemblies and motors furnished under this contract shall comply with the applicable provisions of the hydraulic institute, ASTM, ANSI, and NEMA.

203.400.7.4 The tests on pumping equipment shall include an initial and shop non-witnessed performance test in accordance with the Standards of the Hydraulic Institute on each pump and a field running test on each installed unit. Test reports shall follow the format recommended in the Standards of the Hydraulic Institute, and shall include characteristic curves showing capacities, heads, efficiencies, horsepower, and net positive suction head throughout the entire range of the pump. Net positive suction head curve can be from exact same pump type previous tested.

203.400.7.5 Contractor shall fully comply with all applicable requirements of Division 7, City of Tulsa Water and Sewer Department Standards 701, 702 and 730. These Standards include additional requirements for pump, materials, installation, testing and integration.

#### 203.400.8 WARRANTY

203.400.8.1 Pump manufacturer shall furnish to the Owner a warranty written expressly from the manufacturer to the City of Tulsa, covering workmanship, material, and performance deficiency under normal use and service. The full warranty shall cover 100 percent of parts and labor for at least one full year.

203.400.8.2 The warranty period shall commence on the day of start-up acceptance by the City. Warranty shall be in printed form provided for review in the product submittals.

203.400.8.3 Upon request from the Engineer and/or the owner, the manufacturer shall demonstrate proof of financial responsibility with respect to performance and delivery date. In addition, the manufacturer shall provide proof of evidence

of facilities, equipment, and skills required to produce the equipment specified herein and provide technical service and replacement parts.

203.400.8.4 Components failing to perform as specified by the engineer, or as represented by the manufacturer, or proven defective in service during the warranty period, shall be replaced, repaired, or satisfactorily modified by the manufacturer without cost of parts or labor to the owner.

203.400.9 Pumps shall be sized to meet the following design criteria. Operating points shown shall be within the pumps allowable operating range (AOR). Reduced speed curves showing AOR limitations shall be provided in pump submittals:

203.400.9.1 Pump

1. Pump Manufacturer: Grundfos-Morris
2. Pump Model: 24X24-29 4V3
3. Motors shall be TEFC 3-phase, 460 volt, 60 Hz, premium efficiency, inverter duty rated.
4. Motors shall be provided with insulated bearings and a shaft grounding system designed to mitigate bearing failure due to stray shaft voltages or bearing currents when powered by variable frequency drives. refer to electrical drawings and specifications for additional grounding requirements.
5. Pumps shall be supplied with motor and bearing RTDs. Refer to drawings for additional electrical and integration requirements.
6. The fluid pumped will be raw screened sewage.

203.400.9.2 Pump Design

Capacity (gpm)	19,500
Total Discharge Hd. (ft)	40
% Efficiency at Design Point (Minimum Allowed)	85
Maximum Brake Horsepower Allowed at Design Point	250
Maximum Pump Speed (rpm)	600

Minimum Shutoff Head (ft)	68
NPSHR at Design Point (ft)	17.5
Horsepower	250

1. Motors shall be non-overloading for the entire range of operation and shall not exceed 250 hp.
2. Pumps will be operated with an existing VFD.
3. Pumping units shall be furnished with all items to be compatible with the existing system.
4. Primer coats and finish coats shall be applied by the manufacturer while in the shop.

203.400.9.2 Materials of Construction

Volute	Cast Iron ASTM A48 Class 30
Impeller	Cast Iron ASTM A48 Class 30
Shaft	Manganese Steel ASTM A108C1144 or A332C4140
Front Head	Cast Iron ASTM A48-Class 30
Frame	Cast Iron ASTM A48-Class 30
Shaft Sleeve	Stainless Steel (300-350 Brinell) ASTM A743-CA15
Bearing Housing & Cover	Cast Iron ASTM A48-Class 30
Bearings Inner and Outer	Steel
Impeller Key	Steel
Coupling Key	Steel
Base with Coupling Guard	Steel ASTM A283 GR-D and A36 or A7
All Bolts and Nuts	304 Stainless Steel



#### 203.400.10 Pump Components

- 203.400.10.1 Impeller - The impeller shall be three vane, enclosed, single suction, non-clogging type to pass a minimum sphere size of 8.0". Wiper vanes on the impeller back shroud are not allowed. The impeller is dynamically balanced and secured to the shaft by means of a key and impeller bolt and matched to the volute.
- 203.400.10.2 Volute/Casing - Volute is to be one-piece cast with side flanged tangential discharge. Discharge flange shall be 125 lb. ANSI drilling. Volute design to permit front and back impeller removal and be capable of rotation in increments to accommodate piping orientation independent of the base location. Diffusion vanes are not permitted. A contoured volute hand hole for inspection and cleanout at the impeller is required. Casing shall be hydrostatically tested to 1.5 times the design head or 1.25 times the shutoff, whichever is greater. Integral to volute, motor barrel mounting pads are to be provided. Pads shall be designed to accept the combined weight of barrel and motor.
- 203.400.10.3 Front head - The unit shall have an integrally cast base, front head and suction elbow. Suction flange shall be 125 lb. ANSI drilling. Front head shall incorporate a hand hole for inspection and a 24" flanged suction.
- 203.400.10.4 Back head - The back head shall be provided with a mechanical seal with stainless steel sleeve.
- 203.400.10.5 Fits - Volute, suction, back head and frame shall be manufactured with concentric shoulder fits to assure accurate alignment.
- 203.400.10.6 Shaft - The shaft shall be made from high quality steel, of sufficient diameter to carry the maximum load imposed and to prevent vibration and fatigue. Shaft is to be accurately machined along its entire length. A renewable stainless steel shaft sleeve, positive adhesive sealed, shall protect the shaft through the mechanical seal area.
- 203.400.10.7 Wear Rings - Removal stainless steel wearing rings are to be provided on both the impeller and suction head. They shall provide a seal between the impeller and front head for reduction of recirculation. The impeller wear ring shall be

approximately 50 Brinell softer than the front head ring.

- 203.400.10.8 Frame - The bearing frame shall be of rugged, heavy duty construction and line bored for accurate and permanent bearing alignment.
- 203.400.10.9 Bearings - The radial (inboard) bearing shall be grease lubricated deep grooved-ball type. Thrust (outboard) bearing shall be grease lubricated, angular contact, double row, deep groove mounted ball bearing. Bearings to be designed for a minimum of L10 life in accordance with AFBMA.
- 203.400.10.10 Coupling Guard - All pumps shall have a coupling guard that allows visual inspection of the coupling without removal of the guard. Guard is to be retained in place with easily removable fasteners.
- 203.400.10.11 Mechanical Seal - Chesterton 442 split mechanical seal, or approved equal, shall be provided. The manufacturer's rep shall inspect seal water supply piping/valves/fittings before start-up. Seals shall be heavy duty and constructed of tungsten carbide. Contractor shall coordinate mechanical seal with the requirements for the existing seal water system. Contractor shall provide one complete spare seal kit for each pump being installed.
- 203.400.11 Pumping units shall be furnished complete with all accessories and appurtenances specified or otherwise required for proper operation. All parts shall be installed and adjusted by the contractor. The manufacturer shall furnish necessary drawings and detailed installation, operation and maintenance instructions for all components. It shall be the contractor's responsibility to handle, store, and install all parts, including parts and sheaves, as required in accordance with the manufacturer's detailed written recommendations.
- 203.400.12 All pumps, material and equipment to be salvaged shall be removed carefully to prevent damage, and then delivered to an area designated by the Plant Superintendent on site. The contractor shall dispose of all parts of the existing pump deemed unnecessary to the plant. See plan notes for salvage requirements.
- 203.400.13 All piping, pipe supports and hangers, valves and fittings shall be installed to tie into the existing piping system. When attaching piping to pump, special care shall be taken to align pipe so that stresses are not

transmitted to or imposed upon such connections. All pipe supports and attachment hardware, existing or new, shall be 316 SS and shall be secured to surrounding structure by mechanical means. Seal tight flex conduiting shall be limited to 24" unless specifically noted otherwise within the contract documents. Provide both suction and discharge piping liquid filled pressure gauges with threaded stainless steel piping, isolation valve, bend fittings as required for good Plant Operator observation and maintenance access.

203.400.14 PAINTING: All pump suction and discharge piping disturbed shall be painted. Paint process piping standard process colors as required. Refer Section 204.5 for additional requirements.

203.400.15 TAGGING: New equipment shall be tagged from the manufacturer with a permanent and visible tag showing the new equipment number using the City of Tulsa Equipment ID numbering system. Refer to Specification Section 204.3.6 for requirements.

203.400.16 INTEGRATION: Provide controls improvements and software integration services at the Southside Main Lift Station to accomplish the following work:

203.400.16.1 Incorporate the new RTDs into the existing PLC. Provide all new hardware as required.

203.400.16.2 Provide Integration service as required to show temperature information graphically for each RTD on existing HMI screens.

203.400.16.3 Set up user adjustable high temperature alarms.

203.400.16.4 Incorporate new vibration switch into existing PLC. Provide all new hardware as required. Provide Integration services as required to show a high vibration alarm, high vibration setpoint to stop pump graphically on existing HMI screens.

203.400.16.5 Test and confirm all existing PLC and HMI functions work correctly with new pump installation. This includes pump calls, run status, vibration and alarms.

203.400.17 WARRANTY

203.400.17.1 Pump manufacturer shall furnish to the Owner a warranty written expressly from the manufacturer to the City of Tulsa, covering workmanship, material, and performance deficiency under normal use and service. The full warranty shall cover

100 percent of parts and labor for at least one full year.

203.400.17.2 The warranty period shall commence on the day of start-up acceptance by the City. Warranty shall be in printed form provided for review in the product submittals.

203.400.17.3 Upon request from the Engineer and/or the owner, the manufacturer shall demonstrate proof of financial responsibility with respect to performance and delivery date. In addition, the manufacturer shall provide proof of evidence of facilities, equipment, and skills required to produce the equipment specified herein and provide technical service and replacement parts.

203.400.17.4 Components failing to perform as specified by the engineer, or as represented by the manufacturer, or proven defective in service during the warranty period, shall be replaced, repaired, or satisfactorily modified by the manufacturer without cost of parts or labor to the owner.

203.400.18 MANUFACTURERS SERVICES:

203.400.18.1 The Contractor shall require the manufacturer to furnish the services of a qualified field engineer to perform start-up of the pump system and training. Manufacturer's Services to include:

203.400.18.1.1 Check-out of installation, start-up of equipment and initial operator instruction. This service shall take place after all mechanical equipment associated with the control system is installed and mechanically operable.

203.400.18.1.2 After equipment is fully operational, and before Owner will assume responsibility for the operation of the equipment, the equipment manufacturer's operation specialists shall instruct the Owner's operating personnel in the care, maintenance and proper operation of the equipment. Training shall consist of presentation of written materials and demonstration of O&M procedures to the Owner's Staff. Training shall be required for three shifts of Staff and scheduled at least two weeks in advance with the Owner.

203.400.18.2 Field Test

203.400.18.2.1 Prior to plant startup, all equipment described herein shall be inspected for proper alignment, quiet operation, motor rotation, proper connections, and satisfactory performance by means of a functional test.

203.400.18.2.2 The pump and motor assembly shall be field tested to verify vibration is not in excess of the limits stated in the latest revision of Hydraulic Institute and NEMA MG 1.

203.400.18.2.3 The pumps, motors, and controls shall be given an operational test in accordance with the standards of the Hydraulic Institute. Recordings of the test shall substantiate the correct performance of the equipment at the design head, capacity, suction lift, speed and horsepower as herein specified.

203.400.18.2.4 Units apparently failing to meet the specifications to the satisfaction of the Engineer must be more accurately tested in accordance with Hydraulic Institute Standards. If the pump fails the second test, the unit will be rejected, and the Contractor shall furnish a unit that will perform as specified.

203.400.18.3 Instructions for installation of the pumps and related appurtenances shall be written and furnished by the manufacturer.

203.400.18.4 Operation and maintenance materials

203.400.18.4.1 The pump manufacturer shall be responsible for supplying written instruction, which shall be sufficiently comprehensive to enable the operator to operate and maintain the pump and all equipment supplied by the manufacturer. Instructions shall assume that the operator is familiar with pumps, motors, piping, valves, and controls, but that he has not previously operated and/or maintained the exact equipment supplied.

203.400.18.4.2 The instruction shall be prepared as a system manual applicable solely to the pump and equipment supplied by the manufacturer to these specifications, and shall include those devices and equipment supplied by him.

203.400.18.4.3 Operation and maintenance instruction shall be specific to the equipment supplied in accordance with these specifications. Instruction manuals applicable to many different configurations and pump stations, and which require the operator to selectively read portions of the instructions shall not be acceptable.

203.400.18.4.4 All costs for the above manufacturer functions including travel, lodging, meals, and incidental shall be considered to have been included in the Contractor's bid price. The bid should include the number of trips as required for Contractors scope of work and Manufacturers services for proper operations.

203.400.19 PRODUCT DELIVERY AND STORAGE: All equipment and components shall be delivered in ample time so as not to delay the Work. Store materials to permit easy access for inspection and identification. Keep steel members off the ground, using pallets, platforms, and other supports. Protect steel members and packaged materials from corrosion and deterioration by keeping in covered storage and off of the ground.

END OF SECTION

203.500 All materials, labor, equipment and supervision required for removing, installing and testing new Gravity Thickener equipment complete including new sweep arms with squeegees, collectors, drive units, influent baffle, center support and electrical disconnect, electrical control panels for Gravity Thickener No. 1 located at the Southside Wastewater Treatment Plant, per these specifications.

203.500.1 The project located at the Southside Wastewater Treatment Plant, consists of removing and replacing all gravity thickener equipment within thickeners structures for Gravity Thickener No. 1. The existing Gravity Thickener was manufactured by Envirodyne Systems, Inc. The Thickener equipment shall be complete and supplied by a single supplier. The intent of this specification is to completely rehabilitate with all new equipment while utilizing the exiting concrete structures, “wall pipe” connections and center pier floor mounting. The project includes the correct and complete installation of new components specified herein in conformance with the manufacturer’s instructions and recommendations for installation, subsequent testing of the new units and ensuring all components are in proper operation.

The existing thickener has been previously grouted for leveling. Replacement equipment shall be leveled to the existing grout. No new grout shall be installed. The Contractor shall coordinate with the Plant and field verify all necessary conditions and dimensions for the submittal process and the Manufacturer required information.

203.500.2 The thickener and proposed equipment are detailed in the contract drawings.

203.500.3 A new separate electrical disconnect shall be furnished adjacent to the Thickener Control Panels. Refer to the General Electrical specification section 204 for requirements.

203.500.4 Contractor shall completely replace the thickener electrical service, lighting circuit, and control wiring conduits from the outer edge of the thickener structures. New wiring shall be pulled from the existing breaker/termination block to new thickener control panel. Wiring and conduit shall meet the requirements of the General Electrical Section

- 204.4. New work shall include new sealed threaded aluminum conduiting inside the thickener to the thickener building exterior wall.
- 203.500.5 Contractor shall be knowledgeable about and shall field verify all elevations and dimensions of existing structures, equipment, conduit, and other appurtenances that in any way, directly or indirectly, relates to the removal of existing equipment and/or installation of new equipment. Work and construction submittals shall be based on field measurements. The Authority will make information on file that pertains to the existing equipment available for review.
- 203.500.6 Project work shall include all materials, equipment, labor, and supervision, necessary to complete the project as specified herein including, but not limited to, any and all crane work, rigging, delivery, clean-up and complete installation of components to fully operational and warrantable condition.
- 203.500.7 All work requiring flow stoppage or equipment removed from service must be scheduled one week in advance with Plant Superintendent and Plant flow dependent. All thickener outage shall be shown clearly on the Contractors schedule. Contractor shall have valves, temporary pumps and any other necessary materials and equipment at the installation site prior to flow stoppage. It is the contractor's responsibility to prepare the impacted system and any related systems for disassembly. This includes closing of upstream/downstream valves and pumping down any reservoirs necessary.
- 203.500.8 Contractor shall furnish and install equipment for circular scraper shaft drive thickeners. The equipment shall include a center drive unit and torque control, control panel, alarms, reinstallation of existing walkway, stationary influent pipe, center feedwell, rotating drive shaft, rake arms with scraper blades, anchor bolts, scum skimmer beach, scum box effluent weir, piping and all other appurtenances required or indicated on the drawings.
- 203.500.9 Supplier: The thickener equipment specified in this section shall be



designed and supplied as listed in specification section 203.500.14.

203.500.10 Submittals: Submit for review the following:

203.500.10.1 Certified general arrangement drawings showing all important details and materials of construction, dimensions, loads on supporting structures and anchorage location.

203.500.10.2 Descriptive literature, bulletins, and/or catalogs of the equipment.

203.500.10.3 Complete data on motors and speed reducers.

203.500.10.4 Electrical schematics for all control equipment to be furnished.

203.500.10.5 Calculations documenting the AGMA rating of the drive unit and life of the main bearing, prepared and signed by a registered professional engineer.

203.500.10.6 Complete descriptive information and electrical schematic for torque overload device.

203.500.10.7 Complete sludge transport calculations substantiating the rake blade design, rake tip speed, and floor slope.

203.500.10.8 Complete process calculations substantiating the sizing of the feedwell. These calculations shall be based on parameters from the manufacturers operating experience. These parameters shall be verified by data presented from successful operating installations. Side by side comparison testing of feedwell design from existing operating thickeners shall be presented with the calculations.

203.500.10.9 The submittal shall include data from a minimum of five

(5) successfully operating installations that verify the experience of the manufacturer. Data shall include performance verification of influent flow rate (Q), hydraulic loading (OFR), and waste sludge flow rate (WAS).

203.500.11 Design Criteria - Thickener design shall conform to the following: Dimensions shown are approximate based on Record Drawings. Contractor shall physically measure structure and confirm all information to include in submittal information.

- Tank diameter (ft.): 40
- Side water depth (ft.): 10'-2"
- Freeboard (in.): +/-1'-4"
- Bottom slope: 2:12
- Influent pipe diameter (in.): 12"
- Scum box width (in): 36"
- Motor HP: ½ minimum
- Tip Speed (fpm): 8
- Torque (ft.-lbs.)
  - Continuous Rated: 20,000
  - Alarm: 24,000
  - Maximum Rated: 40,000

203.500.12 Quality Assurance - The equipment supplier shall have at least 15 years experience in the design, application, and supply of thickeners in wastewater treatment plants, and shall submit a list of not less than 25 operating installations of thickeners as evidence of meeting the experience requirement. This experience shall be evidenced by process performance data that is submitted showing actual data on a minimum of five existing installations that are operating successfully as required in the submittal section.

203.500.13 Warranty - A written supplier's warranty shall be provided for the equipment specified in this section. The warranty shall be for a minimum period of five (5) years from start-up or 66 months from time of equipment shipment, whichever comes first. Such warranty shall cover all defects or failures of materials or workmanship which occur as the

result of normal operation and service except for normal wear parts (i.e. squeegees, etc.).

203.500.14 Manufacturer – The thickener equipment shall be manufactured by the following:

- Enviro-dyne
- Clear Stream
- WesTech Engineering, Inc.
- Walker
- Pre-approved Equal

203.500.15 General Design - The thickener mechanism shall be of the center drive type, mounted on a walkway, which spans the tank and bears on the wall at one end. Flow shall enter the feedwell through a stationary influent pipe. The thickener shall be designed to remove settled waste sludge from the bottom of the tank.

203.500.15.1 The thickener shall perform the following integrated functions:

- 203.500.15.1.1 Dissipate energy and control localized currents.
- 203.500.15.1.2 Separate solids from the clear liquid.
- 203.500.15.1.3 Evenly withdraw the clear liquid.
- 203.500.15.1.4 Transport and thicken settled sludge.
- 203.500.15.1.5 Prevent sludge dilution at withdrawal point.
- 203.500.15.1.6 Remove scum from the thickener water surface.

203.500.15.2 Materials: All structural steel shall conform to the requirements of ASTM A36. Steel pipe used for structural members shall conform to ASTM A53. Steel members in contact with liquids, either continuously or

intermittently, shall have a minimum thickness of 1/4" unless otherwise noted. All aluminum shall be type 5052, 6061, 6063, or 2014 alloy unless noted.

- 203.500.15.3 Fabrication: Shop fabrication and welding of structural members shall be in accordance with the latest edition of the "Structural Welding Code", AWS D1.1, of the American Welding Society. All welded connections shall develop the full strength of the connected elements and all joined or lapped surfaces shall be completely seal welded with a minimum 3/16" fillet weld. **Intermittent or segment or "stitch" welding shall not be allowed. All welds shall be complete and fully welded at all areas with no pin holes or gaps. All welding and fabrication shall be completed prior to the HDG process.** Provide a G90 (0.9oz/ft<sup>2</sup>) galvanized coating in accordance with ASTM A123 and ASTM A153. Submittal shall confirm requirement.
- 203.500.15.4 Edge Grinding: Sharp projections of cut or sheared edges of ferrous metals shall be ground to a radius by multiple passes of a power grinder. Submittal shall confirm requirement by note.
- 203.500.15.5 Shop Surface Preparation/Coating: All new non-submerged and submerged ferrous components shall be hot dipped galvanized coated (HDG). No field modifications, cutting, welding or damage to the HDG is allowed. All new equipment components shall be design for field installation and adjustments by design such that the HDG will be complete and undamaged. The drive unit shall be coated with the supplier's standard enamel or powder coat paint system. All hot dip galvanized shall meet ASTM A123, ASTM A153 & ASTM A780 with G90 (0.9oz/ft<sup>2</sup>) galvanized coating. Material exceptions for equipment components are limited to stainless or drive

components, unless approved by Engineer by addendum prior to bid.

203.500.15.6 Structural Design: The ratio of un-braced length to least radius of gyration (slenderness ratio) shall not exceed the values listed in the AISC manual. For angles, the radius of gyration shall be taken about the Z-Z axis. In addition, all structural members and connections shall be designed so that the unit stresses will not exceed AISC allowable stresses by more than one-third when subject to loading of the previously listed peak torque. All steel design shall be in accordance with the AISC Manual of Steel Construction, latest edition, and the Uniform Building Code (UBC), latest edition.

203.500.16 Drive Assembly

203.500.16.1 The Drive Mechanism shall consist of an electric drive motor with a torque overload system, primary worm gear reducer, chain & sprockets with a 16 ga. fabricated stainless steel guard, shear pin coupling, intermediate worm gear reducer and pinion gear with enclosed spur gear in a heavy duty ASTM A36 steel weldment housing.

203.500.16.2 Gear Design and Rating Criteria:

203.500.16.2.1 The drive assembly shall be rated to operate at the minimum Continuous Torque of 20,000 ft. lbs. This torque is the maximum torque required for normal operation of the mechanism on a 24 hr./day continuous 20-year service basis with an operating tip speed of 8 fpm.

203.500.16.2.2 The Alarm Torque is the maximum torque that the mechanism can achieve before activating an overload alarm. This torque is set at approx. 100% of the drive Continuous Torque.

- 203.500.16.2.3 The Motor Cut-Out Torque is the maximum running torque for which the machine is designed. Self-correction of a torque overload condition shall be possible until the Motor Cut-Out Torque is reached. The motor HP shall be based on this torque. The Motor Cut-Out Torque is set at approx. 120% of the drive Continuous Torque, a value equivalent to 24,000 ft. lbs.
- 203.500.16.2.4 Maximum Operating Torque is the rating based on the safe dynamic continuous loading of the gear teeth to withstand the repeated impact loads of the specified service. The surface endurance of the gear materials and life of the bearings shall be adequate to withstand short periods of the dynamic load capacity of the gears. Shear pin sizing shall be based on this Maximum Operating Torque and set to 40,000 ft. lbs.
- 203.500.16.2.5 Momentary Peak Torque is the dynamic load capacity of the drive assembly developed momentarily as starting torque or a sudden buildup of torque. This Momentary Peak Torque is set at 40,000 ft. lbs.
- 203.500.16.2.6 All gears shall be designed for surface durability, strength & geometry in accordance with the latest applicable standards of the AGMA, ANSI and British Standard of spur, worm and helical gearing. All bearings shall be selected in accordance with applicable AFBMA-ANSI standards.
- 203.500.16.2.7 All cylindrical worm gearing shall conform to AGMA 6034-B92, Practice for Enclosed Cylindrical Wormgear Speed Reducers and Gearmotors.
- 203.500.16.2.8 All pinions and spur gears shall conform to AGMA 2001-D04, Fundamental Rating Factors and Calculation Methods for Involute Spur and Helical Gear Teeth.
- 203.500.16.2.9 The output torque rating of the drive shall be based on the smaller of the values determined from the above AGMA standards.
- 203.500.16.3 Drive Motor, Primary and Intermediate Wormgear Reducers

- 203.500.16.3.1 The drive motor shall be a constant speed, TEFC, "C" face mount, NEMA Design B "squirrel cage" for 230/460 volt, 3 phase, 60 Hz. current, chemical "dirty duty" service with 1.15 S.F., Class F insulation with a Class B temperature rise. The motor shall be rated for minimum 0.5 HP to match the existing and shall be adequate to start and continuously operate the mechanism at the maximum load encountered under any operating condition without overloading or exceeding the nameplate rating. The drive motor shall be C-face coupled, direct connected to the primary speed reducer. The use of chains, V-belts or exposed shaft couplings between the motor and primary speed reducer will not be accepted.
- 203.500.16.3.2 The primary speed reducer shall be a single or double reduction worm gear unit in an ASTM A48 cast iron housing with oil immersed gearing. It shall be furnished with an adapter and coupling for mounting the motor. The reducer shall be sized for continuous duty.
- 203.500.16.3.3 The primary and intermediate speed reducers shall be connected through an ASA #80 – 1" pitch, self-lubricating steel roller chain and sprockets. A 16 ga. fabricated stainless steel guard shall enclose the chain and sprockets. The mechanism rotational speed shall be easily adjustable by changing the sprocket ratio. Direct coupled speed reducers are not acceptable.
- 203.500.16.3.4 The intermediate speed reducer shall be a single reduction worm gear unit, double enveloping design for greater load carry capacity, in an ASTM A48 cast iron housing with oil immersed gearing. Non-AGMA rated reducers (e.g. cycloidal drives) are not acceptable. The speed reducer is to have anti-friction tapered roller bearings on both sides to prevent tipping of the gear. The housing is to be located via a machined, registered fit (min 3/8" deep) to insure proper alignment is maintained under operating load conditions.

203.500.16.4 Main Gear, Pinion and Housing

203.500.16.4.1 The final gear reduction shall be an oil-bath lubricated solid one-piece external spur gear/anti-friction four-point contact precision design ball bearing assembly mounted in a steel weldment housing. The main gear housing shall be bolted to the top of the stationary center column and shall be capable of transmitting the mechanical design strength.

203.500.16.4.2 The gear housing shall be a heavy duty ASTM A36 steel weldment sealed housing designed to support the torque tube, arms, skimmers and other applied loads. Cast iron housings will not be acceptable due their potential to develop cracks, pinholes and leaks. The housing shall be constructed using proper wall thickness designed to resist deflection at full peak torque. The oil dam in the main gear housing shall be full sidewall construction integral with the turntable base. A condensation collection sump shall be provided below the lower pinion bearing.

203.500.16.4.3 The main spur gear shall be forged of alloy hardened steel and conform to AGMA 6 or better and have a minimum Brinell hardness of 300. The gear shall have a minimum pitch diameter of 28" and shall be supported by and rotated upon the main bearing. The spur gear face surface area shall have a minimum of 251 sq. inches to insure minimal contact stress and mechanical stability and shall match the face and teeth of the pinion gear. The face surface area is defined as the spur gear pitch diameter times the spur gear face width times 3.14.

203.500.16.4.4 The bearing raceway shall be precision ground and deep induction hardened to Rockwell C60 for maximum capacity and to provide true rolling action without the need for strip liners. Drives that require strip liners are not acceptable due to the fact that strip liner wear causes non-uniform rolling action of the balls which could cause the mechanism to "rock" out of plumb. The



balls shall be matched precision chrome-alloy steel with hemispherically faced spacers designed to provide uniform load distribution. The balls and spur gear shall run in an oil bath with minimum 85% gear submergence. The bearing rings shall be minimum 123,000 PSI tensile forged steel with a tooth hardness of minimum RC56. Bearing life shall be a minimum of 100 years per AFBMA L-10.

203.500.16.4.5 The main bearing shall have a minimum ball race diameter of 23" and shall be capable of withstanding an overturning moment without the aid of any underwater guides or bearings to insure correct tooth contact for AGMA rating of the main gear.

203.500.16.4.6 The pinion gear shall be heat treated AISI 4340 alloy steel. The pinion gear shall be keyed to the output shaft of the intermediate speed reducer and supported by bearings on both sides which are fitted into machined pilots.

203.500.16.4.7 The drive base shall be thoroughly inspected for seep holes or inclusions and given a full hydrostatic test to insure of no leaks in the oil containment area. The complete drive shall be assembled in the manufacturer's shop and tested to assure that the drive is running properly and to calibrate the drive control. A complete test report shall be sent to the engineer verifying that the drive meets the quality assurance of the manufacturer and engineer.

203.500.16.5 Torque Control Device

203.500.16.5.1 The drive assembly shall be equipped with an electro mechanical torque control device. The device shall be activated by thrust from the worm shaft. A calibrated spring will react to the worm thrust and allow axial movement of the worm shaft to activate a pointer. The pointer shall be covered by a plexiglass window providing a visual reading of the relative main gear output torque on a 0 to 100 percent graduated scale.

The overload device shall sense two (2) torques – one to energize an alarm when the loading reaches the specified Alarm Torque, the other to actuate the motor cut-off switch when the loading reaches the specified Motor Cut-Out Torque. Exposed linkage bars, rods, revolving secondary reducer housings or motor amperage sensing devices will not be considered equal.

203.500.16.5.2 The overload device, control switches, and electrical terminals shall be mounted in a NEMA 4X rated enclosure that is integral to the worm gear housing. The enclosure shall be sealed to the housing to prevent moisture from entering either the overload device or drive unit.

203.500.16.5.3 Additional overload protection shall be provided by a shear pin device mounted on the driven sprocket.

203.500.17 Walkway: One (1) existing walkway and platform at each thickener with handrails shall be supported by the tank wall at its end and by the center pier shall be removed, sand blasted, repainted and reinstalled. Contractor shall replace all bolts with new 316 stainless steel bolts and fasteners at location where it mounts to the thickener wall and all new thickener equipment connections.

New stainless steel bearing plates, UHMW-PE slide plates, and 316 stainless steel anchor bolts for the wall support shall be provided by the equipment supplier and installed by the contractor. Bearing plate dimensions and anchor bolt diameter, length, quantity, and arrangement shall be per the equipment supplier. The contractor shall block out or otherwise modify the tank or support structure to accommodate walkway and supports, if required.

See painting specification section 204 for additional requirements.

The Center Drive Platform with access doors shall match the existing as part of the new thickener equipment. The center drive platform must be coordinated and connect to the existing cover systems (which will be reused).

See painting specification section 204 for additional requirements.

#### 203.500.18 Influent and Sludge Removal

203.500.18.1 Rotating Center Drive Shaft and Cone Scraper: A rotating steel drive shaft of 1/4" minimum wall thickness shall be provided. The shaft shall be suspended vertically from and receive its rotational power from the center drive unit mounted on the operating platform. The shaft shall extend down to a sludge cone in the center of the tank floor.

The shaft shall have a steel cone scraper attached to its lower end to prevent deposit of solids in the sludge cone.

The shaft shall be provided with connections for the two sludge rake arms and feedwell supports. The shaft shall be bolted to the drive unit, which shall rotate the shaft with the attached arms and feedwell. The shaft and each arm shall be designed to withstand 150 percent of the design running torque of the drive without over stressing the members. Loading to develop the torque shall be considered as uniform loads applied to each arm individually.

203.500.18.2 The rotating shaft shall have adequate structural strength to support the entire rotating mechanism, including rake arms, cone scraper, and feedwell. Design shall accommodate dead load plus live load and torque

with an adequate factor of safety to eliminate deflection or vibration.

- 203.500.18.3 Feedwell: The flocculating feedwell shall diffuse the liquid into the tank without disturbance or formation of velocity currents. Baffled openings shall be provided near the water surface to allow scum to exit the feedwell.

The supports for the feedwell shall be located above the liquid extending from the shaft. The depth of the feedwell shall be such as to provide proper detention time and an exit velocity at maximum flow that will not scour the settled sludge. The diameter, depth, detention time, and exit velocities shall match the process application calculations as evidenced by the required successful operating installations.

The feedwell is shown on the drawings and shall be constructed of 3/16" minimum thick steel plate with necessary stiffening angles.

- 203.500.18.4 Inlet Pipe: An inlet pipe shall be provided for delivering influent into the feedwell. The pipe shall discharge vertically into the feedwell and be supported from the tank wall and connection at the wall.

- 203.500.18.5 Sludge Rake Arms: The mechanism shall include two sludge rake arms of steel construction with steel scraper blades and adjustable stainless steel squeegees. Squeegees shall be fastened to the rake blades with stainless steel fasteners. Rake arms shall be equipped with vertical steel pickets, all adequately supported on the rake arms at 2'-0" centers.

Scraper blades shall be designed for sufficient sludge transport capacity to handle the design solids loading

rate, with the depth of the blade varying from a minimum at the tank periphery to a maximum at the tank center.

Blades shall properly convey settled sludge to the center sludge cone. The arm supports shall be adjustable at the shaft to assure an even grout thickness over the tank bottom.

The rake speed shall be sufficient to transport the necessary volume of sludge to the sludge outlet, but shall not resuspend settled sludge.

#### 203.500.19 Scum Removal

203.500.19.1 General: The manufacturer shall furnish one (1) skimming devices as part of each mechanism (gravity thickener tank). The skimming mechanism shall be arranged to sweep the surface of the sedimentation compartment, once per rotation, automatically removing scum and floating material to a scum box at the periphery of the tank.

203.500.19.2 Skimmer Construction: The rotating scum skimmer shall include a horizontal steel plate skimmer blade supported by vertical steel members extending up from the rake arms. The blade shall extend tangentially from a point away from the influent feedwell to the hinged scum skimmer assembly at the tank periphery.

203.500.19.3 Scum Skimmer Assembly: A hinged scum skimmer assembly shall be mounted on the outer end of the skimmer blade. The hinged scum skimmer assembly shall be designed to form a pocket for trapping the scum. The hinged arrangement shall insure continual contact and proper alignment between wiper blade, scum baffle, and ramp as the blade travels up the scum box ramp.

The wiper blade shall have a wearing strip on its outer end, which contacts the scum baffle and a neoprene strip on its lower and inner edge. The neoprene wipers shall be a minimum 1/4" thickness. The scum is trapped as the wiper blade meets the ramp and is raised up the ramp to be deposited into the scum trough for disposal.

203.500.19.4 Scum Box: The scum box shall be of the size specified, supported from the tank wall and connected to the scum withdrawal piping. It shall be made of 1/4" thick welded steel plate. The box shall have a scum trough, vertical steel sides, and a sloping approach ramp that extends from 1 1/2" above water level to 5 1/2" below and elevations coordinated with the thickener weir elevation. A similar ramp shall be provided at the opposite end to allow the skimmer blade to lower back to the operating position. A flexible connector shall be provided for connection to the contractor supplied scum withdrawal piping in the tank wall.

203.500.19.5 Scum Flushing Valve: A valve shall be attached to the scum box which automatically opens and allows clarified liquid into the scum box to flush out solids. The valve shall actuate at every pass of the scum skimmer over the scum box, allowing sufficient delay after deposit of the solids before flushing begins. Delay and flush duration shall be adjustable. The valve shall be constructed of oil impregnated UHMW-PE disks with stainless steel rods and stainless steel hardware. The opening and closing of the scum flushing valve shall be one smooth continuous movement. The valve shall provide 2 to 5 gallons of flush water per each pass of the skimmer assembly.

203.500.19.6 Scum Baffle: The baffle shall consist of 1/4" thick x 12" deep fiberglass sections. The baffle sections shall be

curved and fastened to the launder wall with adjustable FRP support brackets, stainless steel fasteners, and anchor bolts.

203.500.20 Effluent Removal

203.500.20.1 Launder: The existing concrete thickener launder shall be utilized. The Contractor shall verify any and all field information, including dimensions-elevations and include such information in the equipment submittal for the new equipment. No work is required within the launders.

203.500.20.2 Weir: The existing FRP weir and FRP weir baffle shall be utilized. The Contractor shall verify any and all field information, including dimensions-elevations and include such information in the equipment submittal for the new equipment. No work is required at the FRP weir or RFP weir baffles.

203.500.21 Electrical

203.500.21.1 The equipment supplier shall furnish all electrical items specifically called for in this specification section. The contractor shall supply and install all other electrical items required to place the equipment into service.

203.500.22 Control equipment not required to be on the basin equipment shall be supported on the aluminum mounting plates attached to the support decking adjacent to the drive unit(s). Stainless steel bolts and fasteners shall be used to mount the equipment. The contractor shall supply and install all field wiring required including but not limited to proper size wire, conduit, fittings, and supports.

203.500.23 Anchorage and Fasteners:

203.500.23.1 Anchor Bolts: All anchor bolts shall be a minimum of 1/2" diameter minimum or larger if required by the Manufacturer and made of type 316 stainless steel. The

equipment supplier shall furnish all anchor bolts, nuts, and washers required for the equipment.

- 203.500.23.2 Fasteners: All structural fasteners shall be a minimum of 1/2" diameter minimum or larger if required by the Manufacturer and made of type 316 stainless steel. The equipment supplier shall furnish all fasteners required for the assembly of the equipment.

203.500.24 Site Storage and Handling of Equipment

- 203.500.24.1 The Contractor shall store the supplied equipment in accordance with the manufacturer's recommendations and instructions. Gear reducers and motors shall be stored in buildings or trailers, which have concrete or wooden floor, a roof and fully enclosed walls, and will protect the equipment from dust, dirt, and moisture. Equipment provided with space heaters shall be connected to a temporary power source to provide continuous operation of the heaters until the site is ready for installation. Rotate all shafts with bearings on a monthly basis. The Contractor shall be responsible for work, equipment, and materials until inspected, tested and finally accepted.

203.500.25 Installation

- 203.500.25.1 The equipment shall be installed properly to provide a complete working system. Installation shall follow the supplier's recommendations.
- 203.500.25.2 Manuals: The equipment supplier shall furnish three copies of operation and maintenance manuals, which will be retained at the installation site to assist plant operators. The manual shall include the supplier's erection and assembly recommendations and a complete list of recommended spare parts.



- 203.500.25.3 Shop Assembly and Inspection: The equipment specified herein shall be factory assembled as far as practical to verify that all mating parts can be field assembled. All mating parts shall be trial fit and match-marked. The manufacturer shall submit certification of shop trial assembly and photographs of assembly before shipment. The customer and installing contractor shall be given the opportunity to witness the shop assembly.
- 203.500.25.4 Shop inspection shall be performed by a qualified inspector and certified by the manufacturer. The inspection shall be documented and all deficiencies noted, corrected, re-inspected and final completion formally authorized. Final shipment authorization shall be by the manufacturer to ensure completion of all fabrication, assembly, and inspection requirements. Inspection records and evidence of inspector qualification shall be submitted to the owner upon request.
- 203.500.25.5 Field Service: The equipment supplier shall provide the service of a qualified technical representative for one trip(s) and two full workday(s) for each thickener awarded to inspect the mechanism installation, lubrication, torque test, assist in start-up, and instruct plant personnel in the proper operation and maintenance of the mechanism.
- 203.500.26 Field Testing:
- 203.500.26.1 Torque Tests: The entire sludge collector mechanism shall be statically load tested by individually loading each rake arm with 150 percent of the specified design running torque. The test shall verify the torque overload control device settings for alarm and motor cutout. Each

arm shall be individually anchored and the load measured to demonstrate the rake arms' and drive units' ability to withstand the specified torque. Sketches and calculations shall be submitted illustrating how the torque will be applied prior to the test taking place.

203.500.26.2 Operation Tests: The mechanism shall be operated in a dry tank for a minimum of 4 continuous hours before flow is allowed to enter the system. There shall be no binding, jerky, or unusual motion exhibited during this run in period. Motor amperage shall be checked at least hourly for any unusual or higher than normal figures. After the unit has successfully passed this initial test, flow shall be introduced into the tank and the same 4 hour observation test run. If the unit should fail under any of these conditions, the test shall be halted and the problem corrected. If, after several attempts, the unit does not successfully pass the field test, the faulty portion of the equipment shall be repaired or replaced and the test re-run.

203.500.27 Integration Services:

203.500.27.1 Provide Integration Services as needed to restore, test and demonstrate all existing control functions. Existing equipment controls currently have on/off status and alarms displayed on the HMI.

203.500.27.2 Provide Integration Services to add run time meters for each Thickener Drive to the HMI.

203.500.28 TAGGING: New equipment shall be tagged from the manufacturer with a permanent and visible tag showing the new equipment number using the City of Tulsa equipment numbering system. Refer to Specification Section 204.3.6 for additional requirements. The equipment numbering information is shown on the contract drawings.

END OF SECTION

- 203.620 All materials, labor, equipment, and supervision required for rehabilitation of the Diffused Air System within Aeration Basin 2 at the Southside WWTP per these specifications.
- 203.620.1 Aeration Basin utilizes a diffused air system to distribute and release air into the raw sewage within the basin. The system consists of a network of membrane discs diffusers and associated air piping which are anchored to the basin floor. The purpose of the diffused air system is to provide an aerobic environment for microbial degradation of organic matter.
- 203.620.2 The existing diffused air system was installed in 2012 as part of project ES 2005-05. Most of the membrane discs are original to that project. The membrane discs are at the end of their useful life and are due for replacement.
- 203.620.3 The Plant Staff will take the aeration basin out-of-service and open the appropriate mud valves to drain the basin.
- 203.620.4 The Contractor will Washdown the interior surfaces of the basin including the floors, walls, piping and components, and remove any trash or debris within the basin.
- 203.620.4.1 Coordinate with the Engineer to conduct a pre-work inspection of the diffused air system components within the basin to identify any components that should be repaired or replaced.
- Provide the Engineer with a cost estimate of any potential repairs.
  - The engineer may direct the Contractor to complete the repairs and fund this cost from the General Construction Allowance.
  - Or the Engineer may direct the plant staff to complete some of the minor repairs.
- 203.620.4.2 The Contractor will Replace all of the membrane disc diffusers and retainer rings in accordance with the manufacturer's instructions.
- 203.620.4.2.1 Flush the air piping with water to remove any dirt or debris from the inside of the air piping.
- 203.620.4.3 Coordinate with the Engineer to conduct a post-work inspection of the membrane disc diffusers, retainer rings and other diffused air system components within the basin.
- 203.620.4.4 Provide commissioning and start-up service in accordance with the manufacturer's start-up procedure.
- 203.620.5 Proposed Equipment:

203.620.5.1 Approved equipment and materials are listed below. Contractor will coordinate with the Engineer for approval of other makes, models, or materials.

Equipment	Membrane Disc Diffuser
Make	Aquarius Technologies
Part #	MBD-90001-E
Size	9-inch diameter
Material	EPDM

Equipment	Diffuser Retainer Ring
Make	Aquarius Technologies
Part #	DFR-90000-P
Material	PVC

Equipment	Diffuser Wrench – 9”
Make	Aquarius Technologies
Part #	DIF-RNCH9-S

203.620.5.2 There are nine (9) aeration zones within Aeration Basin. The exact number of diffusers within each zone is not currently known. For estimating purposes, the table below shows the information the City of Tulsa currently has.

Basin Zone	Number of Diffusers and Retainer Rings per Zone as listed in the Aquarius Submittal Drawings
Zone 1	1,254
Zone 2	1,036
Zone 3	800
Zone 4	690
Zone 5	576
Zone 6	352
Zone 7	352
Zone 8	352
Zone 9	352
Misc added at baffle walls & other areas	75
<b>Estimated Total</b>	<b>5,764</b>

**For bidding purposes total diffusers and retainer rings: 5,850 each.**

203.620.6 Drawings:

203.620.6.1 Drawings 203.620 are provided for reference. The Contractor should be aware that these drawings may not fully reflect changes that were made during or after construction.

203.620.7 Documents for Review:

203.620.7.1.1 Material Datasheets with information such as:

- Make and Model
  - Size and Dimensions
  - Materials of Construction
- 203.620.8 Coordination with Plant Operations - Contractor will coordinate with the Engineer regarding the dates when the basin will be out-of-service. The Contractor should provide at least two (2) weeks of advance notice before the basin is to be taken out-of-service.
- 203.620.9 Removal of Existing Equipment - The following items are to be removed and disposed:
- All existing membrane disc diffusers are to be removed and disposed.
  - All existing diffuser retainer rings are to be removed and disposed.
- 203.620.10 Installation of Proposed Equipment - Equipment is to be installed in accordance with the Manufacturer's Installation Instructions.
- 203.620.11 Identification Tags – New equipment shall be tagged from the manufacturer with a permanent and visible tag showing the new equipment number using the City of Tulsa equipment numbering system. Refer to Specification Section 204.3.6 for requirements. A single Tag for all diffusers affixed to the Aeration basin Handrail will be sufficient.
- 203.620.12 Documents for Record – Provide a record count of diffusers confirming installed quantities in each zone and locations of plugged locations within the final O&Ms and Manufacturer's start up report.
- 203.620.13 Manufacturer Services for Equipment Commissioning Service - Provide Technical Manufacturer services for inspections, commissioning, and start-up service in accordance with the manufacturer's start-up procedure. Update final O&Ms with actual diffusers installed, actual lateral layout around columns/walls and note diffuser heads which are plugged.

END OF SECTION

203.640 All materials, labor, equipment, and supervision required for installing three (3) new rotary-lobe, positive displacement blower packages for Unthickened WAS Storage at the Southside WWTP per these specifications.

203.640.1 The work consists of demolishing three (3) existing blower systems and installing three new rotary-lobe positive displacement blower systems and associated piping, fittings, valves, bases, rails, supports, and electrical improvements at the Southside WWTP. The project includes the correct and complete installation of new components specified herein in conformance with the manufacturer's instructions and recommendations for installation, subsequent testing of the new units and ensuring all components are in proper operation.

203.640.2 Contractor shall sequence work so that blower units are replaced one at a time while maintaining aeration to the Unthickened WAS Storage Basins. Coordinate work with blower discharge piping replacement. System outages of up to 12 hours are allowed when coordinated at least 48 hours in advance with WWTP Staff.

203.640.3 Contractor shall provide and install blower systems that match the existing unit configuration to greatest extent possible. New equipment should generally match existing inlet and outlet locations and be sized to maintain existing clearances for operation and maintenance access. Provide dimensional drawings of blower systems by submittal and do not initiate any other related work until submittal is approved.

203.640.4 Blower systems and associated piping improvements are identified as S010-VRS1-BL01-03 on Drawings 203.640.A - J.

203.640.5 Contractor shall be knowledgeable about and shall field verify all elevations and dimensions of existing structures, piping, conduit, valves and equipment that in any way, directly or indirectly, relates to the removal of existing equipment and/or installation of new equipment. Work shall be based on field measurements. The Authority will make information on file that pertains to the existing equipment available for review.

203.640.6 Project work shall include all materials, equipment, labor, and supervision, necessary to complete the project as specified herein including, but not limited to, any and all crane work, rigging, delivery and complete installation of components to fully operational and warrantable condition.

203.640.7 All work requiring flow stoppage or equipment removed from service must be scheduled 48 hours in advance with Plant Superintendent. Contractor shall have valves, temporary pumps and any other necessary materials and equipment at the installation site prior to flow stoppage. It is the contractor's responsibility to prepare the impacted system and any related systems for disassembly. This includes closing of upstream/downstream valves and pumping down any

reservoirs as necessary.

203.640.8 The contractor shall install rotary-lobe positive-displacement blower system(s) built by a qualified manufacturer. All components shall be furnished by a single manufacturer who shall be responsible for the performance and compatibility of the system.

203.640.9 SUBMITTALS

- The submittals shall consist of a bill of material listing all components the blower system manufacturer will deliver; component Manufacturer's catalog cut sheets listing materials of construction, performance curves/charts, standards of design, warranty statement; prime/paint coating system plus the following information:

203.640.10 BLOWER

- BHP at: normal system operating conditions
- Discharge temperature at ambient temperature and normal system operating conditions.
- L10 bearing life calculations for each bearing.

203.640.11 MOTOR

- 1/2, 3/4, full load efficiencies and power factors
- L10 bearing life calculations for each bearing.

203.640.12 SILENCERS

- An attenuation performance curve for each type of silencer.

203.640.13 PRESSURE RELIEF VALVE

203.640.13.1 Set Pressure

- Shop drawings of assembled system stating what items will be shipped to the job site assembled and those shipped loose for field assembly.
- V-belt drive calculations.
- A list of all exceptions and an explanation of each non-compliance with the specifications.

203.640.14 QUALITY ASSURANCE

- The blower system(s) will be built by a blower system supplier who has units at 50 or more wastewater treatment plants, the same size or larger than those specified below, that have been in successful operation for fifteen or more years.
- All components shall be furnished by a single supplier who shall be responsible for the performance and compatibility of the system.

- The blower system manufacturer shall be an authorized warranty service center for the bare blower provided.
- Blowers, motors, and all primary components shall be manufactured in the United States with replacements and parts available from multiple sources within the United States.

203.640.15 STORAGE & HANDLING

- Care must be taken during unloading and handling of equipment to ensure against undue strain to the blower and motor. DO NOT use lifting straps or chains under the blower or motor. Lift from under the main frame, base or use base mounted lifting lugs (if provided).
- In storage blowers must be kept clean, free of moisture and rotated a minimum of 20 revolutions each week to maintain warranty. For storage in excess of four months, or in a damp or corrosive environment see the manufacturer's operation and maintenance manual.

203.640.16 CONDITIONS OF SERVICE

APPLICATION:	Coarse Bubble Aeration
NUMBER OF BLOWERS:	3
SITE ELEVATION, FASL:	629
DESIGN INLET TEMPERATURE, °F:	100
DESIGN RELATIVE HUMIDITY, %:	85
SCFM ± 4 %:	500
ICFM ± 4 %:	583
DIFFERENTIAL PRESSURE, PSIG:	6.55
MAX BHP REQUIRED:	21.8
RPM LIMIT AT ABOVE SCFM:	1835
MOTOR SIZE, HP:	30
SOUND LIMIT REQ. @ 1 METER IN FREE FIELD, dBA:	88

203.640.17 Manufacturer will provide a warranty stating that the blower system is warranted to be in accordance with the product specifications mutually agreed upon and to be free from defects in workmanship and materials. The blower system manufacturer's product warranty will extend to all products supplied by the blower system manufacturer whether or not manufactured by the blower system manufacturer. This warranty shall terminate at twelve (12) months in service with the original user.

203.640.18 PRODUCTS

203.640.18.1 MANUFACTURERS

- The blower system(s) shall be manufactured by Universal Blower Pac, Inc., Noblesville, Indiana, or equal.

203.640.18.2 CONSTRUCTION



203.640.18.3 BLOWER

IMPELLERS:	Involute design; cast or ductile iron; static and dynamically balanced; operate without rubbing, liquid seals or lubrication.
SHAFTS:	One piece steel that pass through the impellers or cast integrally with the impellers.
TIMING GEARS:	Spur or helical tooth; alloy steel; held by taper pins, wedge rings, or bolted to timing hubs spline mounted to the shafts.
LUBRICATION:	Gear end oil splash, other end grease or oil splash. Blower shall be equipped with projecting glass viewports with brass bodies for easy oil level indication from multiple angles.
SEALS:	Labyrinth or lip on each bearing with air vents between seals and impeller chamber.

203.640.18.4 MOTOR

DESIGN:	B, squirrel-cage, induction per NEMA MG1 & IEEE standards
HP:	Nameplate greater than the brake horsepower at 10% above the relief valve set pressure as described in 1.03 D 2.
RPM:	1800
TYPE:	TEFC
POWER:	460 Volt, 3 phase, 60 Hertz
INSULATION:	Class F with class B rise
SERVICE FACTOR:	1.15 at power voltage and site elevation listed above
EFFICIENCY:	"premium efficient" per latest edition of NEMA MG1

203.640.18.5 V-BELT

- High-capacity type, oil and heat resistant, static-dissipating drive belts selected to have a 1.4 or higher service factor above the required blower brake horsepower. Sheaves shall mount to the blower and motor shafts with QD type bushings. A jack-shaft or drive coupling shall be used if recommended by the system manufacturer.

203.640.18.6 DRIVE GUARD

- Top, sides and bottom made of 14 gauge sheet steel with expanded metal front and back. Designed to allow ample ventilation for the drive, have an easy access cover and conform to applicable safety codes.

203.640.18.7 BASE

- A steel angle or channel skeleton-frame base, elevated on legs, with continuous welded joints shall be supplied. Bare base weight shall equal 50% or more of the blower's weight, but not less than 100 pounds. The inlet filter, inlet silencer, blower, motor, drive, drive guard, discharge silencer, valves, interconnecting piping, supports and all other accessories shall be shipped assembled on the base to the extent allowable by trucking.
- 
- Refer to Construction Drawings for existing base configuration and available space. Match existing configuration to extent possible.

203.640.19 ACCESSORIES

203.640.19.1 INLET FILTER

- Each blower shall have a filter with a paper media that removes 99.5% of 2 micron particles. The maximum pressure drop across the clean element and housing shall be less than 2-inches of water column.
- Filter shall be shipped installed on the inlet silencer and positioned for outdoor service. Filter shall be Universal Silencer CCF or equal.

203.640.19.2 SILENCERS

- Silencers 3" and smaller shall be of the premium, straight-through absorptive type. Larger silencers shall be of the multiple-chamber design. Silencers will have acoustically packed nozzle next to blowers operating above transition speed. Silencers with threaded connections shall have ports on each end and those with flanged connections will have ports on the side and end. Multi-chamber silencer attenuation performance shall be at least 18 dB at 63 hertz, 23 dB at 125 hertz, 27 dB at 250 hertz and 31 dB at 500 hertz.
- Each blower shall have an inlet silencer with an air velocity of 4000 to 5700 feet per minute. Silencer shall be Progentex, Inc. series DS, RSI, DRSI, Universal Silencer, Inc. series U5, URB, RIS, Burgess Manning series CA, BMAI, BMSI Stoddard series L/C21, D13/L41, L61/63 or equal. Combination type inlet filter/silencers shall not be permitted.
- Each blower shall have a discharge silencer. Based on inlet CFM air velocity shall be 5500 to 7000 feet per minute. Silencer shall be Progentex, Inc. series DS, RS, DRS, Universal Silencer, Inc. series U5, URB, SD, Burgess Manning series CA, BMA, BMSS, Stoddard series L/C21, D13, D32/33 or equal. Combination type discharge silencer/base frames shall not be permitted.

203.640.19.3 FLEXIBLE JOINT

- Each blower shall have an inlet and discharge flexible joint that matches the blower ports' size and type of connection. The joint's elastomer must be rated higher than the maximum expected service temperature and pressure.
- Each blower shall have an external discharge flexible joint that matches the blower discharge silencer size. The joint's elastomer must be rated higher than the maximum expected service temperature and pressure. The flexible joint shall ship installed on the system.

203.640.20 VALVES

203.640.20.1 PRESSURE RELIEF VALVE

- Each blower shall be protected by a stacked weight type pressure relief valve preset to start opening at half a PSIG above the PSIG listed in the "service" section, be full open at not more than 10% above the set pressure, and rated for the SCFM and PSIG listed in the "service" section.

203.640.20.2 CHECK VALVE

- Each blower shall have a discharge check valve with wafer connection, cast-iron body, cast-iron split discs and seal rated above the maximum anticipated discharge temperature. Valve shall be shipped installed on the system.

203.640.21 INSTRUMENTS

203.640.21.1 FILTER RESTRICTION GAUGE

- Each inlet filter shall have a filter restriction gauge that progressively measures vacuum in the filter element. Provide a visual indicator, with a manual reset and a electronic sensor, conduit and wiring to local control panel.

203.640.21.2 PRESSURE GAUGE

- Each blower shall have a 2 1/2" diameter, stainless steel case, brass bourdon tube, liquid filled, 1/4 NPT connection pressure gauge with a 0-15 PSIG scale on systems operating up to 10 PSIG and 0-30 PSIG for higher pressures. Gauge shall have a 1/4" brass snubber and isolation valve. Gauge shall be Winters 800 or equal.

203.640.21.3 THERMOMETER / TEMPERATURE SWITCH

- Each blower shall have a high discharge air temperature switch and thermometer. The thermometer shall have an easy to read 3-1/4" dual scale dial thermometer and a 3A 250VAC / 2A 250VDC SPDT relay in a 304 stainless steel housing. Color coordinated pointers display the current process temperature and set point. A front adjustment knob controls the set pointer. The internal mechanical switch movement prevents the set point pointer from sticking to the process indicating pointer. Brass wetted internal materials have 3 percent accuracy. The thermometer shall have a 10.5' stainless steel capillary with 1/2" NPT process connection. The electrical connections shall be finger-safe screw terminals. A u-clamp mounting bracket shall be included for mounting to the acoustical enclosure surface.

203.640.21.4 PRESSURE SWITCH

- Each blower shall have a high discharge pressure switch.

#### 203.640.21.5 REPLACEMENT PARTS

- Each blower shall be furnished with the following spare parts:
  - One spare filter element
  - One set of spare V-belts
  - Lubricants for 6 months

#### 203.640.22 COATINGS

- All equipment shall be cleaned to SSPC-SP 3 and receive a 2-3 mil DFT shop coat of phenolic alkyd, zinc-chromate, red iron oxide, rust inhibitive universal primer. The blower systems shall then receive a finish coat of Coronado Alkyd Enamel, 139 series, 50% gloss, high temperature paint. The coat shall be 2-3 mil DFT.

#### 203.640.23 ELECTRICAL

- Install a new wall mounted NEMA 4X 316SS combination starter/disconnect for each blower system. Match existing location and reuse existing conduit and wire to extent possible. Install new conduit and wire as required back to first point of termination.

#### 203.640.24 CONTROLS AND INTEGRATION

- Install one (1) new NEMA 4X 316SS Local Control Panel for the 3 blower system. Match existing features and layout. Match existing location and reuse existing conduit and wire to extent possible. Install new conduit and wire as required back to first point of termination.

Provide the following control features:

- Control Power On
- Blower 1 High Discharge Pressure
- Blower 1 High Discharge Air Temperature
- Blower 1 High Differential Pressure Across Filter
- Blower 2 High Discharge Pressure
- Blower 2 High Discharge Air Temperature
- Blower 2 High Differential Pressure Across Filter
- Blower 3 High Discharge Pressure
- Blower 3 High Discharge Air Temperature
- Blower 3 High Differential Pressure Across Filter
- Alarm Reset

Provide Integration services as required to restore existing SCADA functions on the HMI. Current functions include:

- General Alarm for system
- Run Status for each blower

#### 203.640.25 EXECUTION

203.640.25.1 ERECTION/INSTALLATION APPLICATION

- Blowers are recommended to be installed on a non-moving foundation with the industry standard depth of twice the blower gear diameter or a pad 2 times the total mass of all rotating components, whichever depth is greater.
  - o If these recommendations cannot be accommodated, the following points must be followed to ensure an adequate installation:
    - The blower pad must be located on the equivalent of compacted soil substructure, which will allow the pad to remain flat, rigid, and free of resonant frequencies within the operating range of the equipment.
    - The blower must be anchored using bolts intended specifically for dynamic loading.
    - The area between the base and pad must be filled with 1" minimum non-shrink grout.
    - The unit must be installed and leveled per the manufacturer's instructions supplied in the O&M manual.

203.640.25.2 TAGGING: New equipment shall be tagged from the manufacturer with a permanent and visible tag showing the new equipment number using the City of Tulsa Equipment ID numbering system. Refer to Specification Section 204.3.6 for requirements.

203.640.23.2 TESTING: The blower system and all associated new equipment and/or appurtenances shall be installed in strict conformance with the manufacturer's recommendations, which are to be submitted with the shop drawings. After completion of the installation, the equipment shall be tested by the Contractor under actual operating conditions to achieve the flow specified. The test shall be conducted under the supervision of the manufacturer's technical representative and in the presence of the owner's representative. Three (3) copies of test results shall be submitted to the Engineer. The equipment manufacturer shall furnish the services of a factory field representative to inspect the installation, testing and start up the equipment.

203.640.25.3 OPERATION AND MAINTENANCE: The manufacturer shall provide information to the Owner's representative regarding the operation and maintenance of the equipment.

203.640.25.4 PRODUCT DELIVERY AND STORAGE: All equipment and components shall be delivered in ample time so as not to delay the Work. Store materials to permit easy access for inspection and identification. Keep steel members off the ground, using pallets, platforms, and other supports. Protect steel members and packaged materials from corrosion and deterioration by keeping in covered storage and off of the ground.

END OF SECTION

203.998 Mobilization Bid Item – A mobilization bid item is included to help cover initial costs of bonds, insurance, permits, submittal preparation and other incidental costs.

203.998.1 Payment shall be made for a Mobilization Bid Item which is intended to cover the costs of bonds, insurance, permits, submittal preparation and other incidental costs. Payment of the Mobilization Bid Item may be requested in full on the first payment application. The Mobilization Bid Item shall not exceed five percent (5%) of the **sum of all Base Bid Items excluding the Mobilization Bid Item.** Add Alternate Items are not part of the Base Bid Items.

END OF SECTION

203.999 Mechanical, Electrical, Plumbing, and Unforeseen Circumstances Allowance – The allowance amount is shown on the bid proposal for various mechanical, electrical, plumbing, or unforeseen circumstances work not shown on the Construction Drawings or specified in the Contract Documents.

203.999.1 The allowance shall be used for cost of materials, labor, installation, and overhead and profit for additional MEP/Unforeseen Circumstances work that is not shown on the Construction Drawings or specified in the Contract Documents.

203.999.2 The allowance shall be used only at the discretion of the City of Tulsa. Any allowance balance remaining at the completion of the contract will be credited back to the City of Tulsa on the final Application for Payment submitted by the contractor.

203.999.3 The contractor shall provide to the City of Tulsa representative a written request for the use of any of the allowance with a schedule of values and all associated backup information.

203.999.4 The contractor shall proceed with work included in the allowance only after receiving a written order from the City of Tulsa representative authorizing such work. Proceeding with work expected to be covered in the allowance without a written order from the City of Tulsa representative will be at the contractor's risk. Contractor may not be paid for unapproved work/materials at the discretion of the City of Tulsa representative.

203.999.5 Any additional costs for bonds and insurance shall not be included in any MEP allowance because this cost is already included in the contract.

END OF SECTION

204 ANCILLARY EQUIPMENT & WORK

The cost of items in this Section and other Sections of these specifications shall be equitably included in the appropriate Bid items.

204.1 Prior to disposal of any material or equipment that is City of Tulsa property and removed as part of the contract work, Contractor shall contact the appropriate **WWTP Plant Superintendent** and explicitly offer to the Authority first right to claim and retain such materials or equipment as City of Tulsa property. Contractor shall be responsible for the disposal of all such equipment and materials not claimed by the Authority. Items identified for salvage shall be removed carefully, protected, palletized and delivered to the Northside or Southside Maintenance Department. A copy of the Contractor's transmittal shall be provided to the Engineer after delivery.

204.2 Contractor shall field verify all elevations and dimensions of existing piping, valves, and equipment to be demolished. Contractor work shall be based on field measurements and shall include field adjustments and additions for the proper installation of equipment. The contractor shall take note of all objects in the vicinity of equipment being installed to ensure that there are no issues with interference. It is the responsibility of the contractor to make modifications necessary to adjacent objects such as pipe supports and similar to install the new equipment unless such objects are not reasonably visible during the site visit. It is the responsibility of the contractor to review all field conditions and take necessary field measurements prior to ordering equipment. The City of Tulsa will make available the information it has pertaining to the existing equipment.

204.3 General Equipment Requirements:

204.3.1 Approved Equal Equipment: The manufacturers and models specified in the equipment specifications are considered pre-approved. The winning contractor may, at their discretion, submit for approval equipment that has not been approved prior to the bid opening. When doing this, the contractor should be aware that the submitted equipment must not only meet the performance requirements stated in the equipment specifications, but it also must meet or exceed the manufacturing, material, and quality specifications of the pre-approved equipment even though those specifications are not expressly listed in the section. The Engineer will review any non pre-approved equipment through the submittal process and compare it with the pre-approved equipment to determine that the equipment is or is not equal. Contractor should be



prepared to supply technical data, material information, standards conformance information, and other related information as requested by the Engineer. If the requested information is not supplied, the equipment will be deemed to be not equal. Approval of non pre-approved equipment will be at the sole discretion of the Engineer.

204.3.2 Equipment Demolition: All equipment shall be demolished in accordance with each bid item section. No existing equipment is to be abandoned in place unless specifically noted otherwise. All equipment being removed during demolition shall either be set aside for determination of surplus value or disposed of by the contractor per each bid item specification. If after removing the old equipment and installing the new equipment there are unused items still in place, it shall be the responsibility of the contractor to remove these items in a manner that will not affect adjacent equipment or systems. All removed electrical and fluid components shall be properly capped off at the point of removal. Removal shall be performed in a manner that will allow re-installation/replacement of the removed items at a later date if necessary.

204.3.3 Gauges: Each pump shall be provided with a combination pressure/vacuum gauge in the suction piping and a pressure gauge in the discharge piping. Gauges shall conform to ANSI/ASME B40.1 and shall be indicating dial type, with C-type phosphor bronze Bourdon tube and stainless steel rotary geared movement, or direct drive type with stainless steel helical-wound capillary tube pressure sensing element. The gauge shall have a phenolic open front turret case, and adjustable pointer, a stainless steel or phenolic ring, and an acrylic or shatterproof glass window. The dial shall be 4 ½ inches in diameter, with white background and black markings. Pointer travel shall span not less than 200 degrees or more than 270 degrees. All gauges shall be Accuracy Grade A or better. Pressure gauges shall read in pounds per square inch. Compound gauges shall read in inches of mercury vacuum and pounds per square inch. The range of each gauge shall be per pump manufacturer's recommendation.

All gauges shall be installed with a diaphragm seal, brass flushing port and brass isolation valve of appropriate size.

204.3.4 Mechanical Seals and Seal Water:

- 204.3.4.1 All pumps shall be equipped with cartridge mounted double mechanical seals recommended by the pump manufacturer and compatible with Pump Seal Water Support Systems (PSWSS) installed at each pump. Refer to Construction Drawings and pump specifications for additional requirements.
- 204.3.4.2 The new seal water conditioning station (SWCS) and PSWSS may contain components that were not originally part of an existing seal water system. It is the responsibility of the contractor to supply and install all necessary electrical components including wiring, conduit, connectors, contactors and appurtenances required for the complete installation of the new seal water system. It may also be necessary to integrate the new seal water system components into the existing equipment control system. The contractor shall be responsible for all labor and materials required to integrate new components into the existing control system. All electrical work on the seal water station shall conform to the General Electrical Requirements herein. Contractor shall demolish and remove all existing seal water components not reused in construction.
- 204.3.4.3 Seal water piping and accessories shall not utilize rigid PVC piping. Seal water lines connected directly to the mechanical seals shall be PEX. All other piping in the seal water station shall be of a non-corrosive metal material such as stainless steel, or painted copper. Valves and other components shall be bronze unless otherwise required.
- 204.3.4.4 Some existing pumps do not have mechanical seals. Contractor shall determine from field investigations the location of seal water for those pumps. It is the responsibility of the contractor to supply and install all seal water piping, electrical work and materials, and control work and materials required to add a seal water station where one was not used for existing equipment. Locations are to be approved by the engineer.

204.3.4.5 If a new pump is installed that does not require seal water and there are existing seal water lines at the pump location, it is the responsibility of the contractor to remove existing water lines. Lines shall be removed as far up stream as possible to a point that will not interfere with water supply to other equipment. No existing lines shall be abandoned in place.

204.3.5 Valves:

204.3.5.1 All valve parts and surfaces shall be of corrosion resistant materials or have a factory applied epoxy coating sufficient to prevent corrosion in a wastewater environment. See painting/coating section for coating thickness requirements.

204.3.5.2 Plug Valves and Check Valves: Plug valves and check valves shall be of the same size, style and construction as the units being replaced. It is the responsibility of the contractor to review the existing valves and provide correct similar units. Acceptable manufacturers are Pratt, DeZurik, Clow, Val-Matic, or an approved equal.

204.3.5.3 Butterfly Valves: Butterfly valves shall be of the same size, style, and construction as the units being replaced. It is the responsibility of the contractor to review the existing valves and provide correct similar units. Acceptable manufactures are DeZurik, Clow, Val-Matic, or an approved equal.

204.3.5.4 Gate Valves: Gate valves shall be of the same size, style and construction as the units being replaced. It is the responsibility of the contractor to review the existing valves and provide correct similar units. Acceptable manufacturers are Wey, DeZurik, or approved equal.

204.3.5.5 Plug and butterfly valves supplied with hand wheel operators that are installed more than 6'-0" above floor level shall be supplied with chain wheels and chains to allow for valve operation from the floor.

204.3.5.6 Valves and operators shall be selected by the contractor such that when installed in close proximity to one another

the operators will be a sufficient distance apart to allow for uninhibited use by personnel.

204.3.5.7 All Valve placement and orientation shall be installed per Manufacture's recommendations. Systems operation and valve orientation layout (drawing) shall be included in the submittals for review with valve submittal(s).

204.3.6 Equipment Tagging: New equipment shall be tagged, according to the requirements listed below and City standards, with a permanent and visible tag showing the new equipment number and naming using the City of Tulsa Equipment ID numbering system. All tags should be visible to anyone without the need to remove covers or otherwise "hunt" for the tag. See individual equipment sections for Equipment ID numbers for each item. Tags shall conform to the following specifications.

204.3.6.1 Requirements:

- Any equipment valued over \$1,000
- All Valves greater than 6"
- All valves great than 2" buried. Concrete collar tags for valves require a 316 stainless steel tag at each installed location. See valve box concrete collar detail for additional required details.
- All relief and motorized valves that are smaller than 6"
- Any equipment that requires preventive maintenance
- Any equipment that is critical to the process of the plant
- Any equipment that is considered a Safety item
- Emergency Eyewash/Showers
- All Fire Extinguishers
- All Ladders
- Hoists
- All Detectors
- Overhead Doors
- Fire Alarms/Sprinklers

- Emergency Lights
- All electrically powered devices require three (3ea) tags at minimum - one at unit, one on the disconnect and on panel/switch/MMC bucket.
- All equipment with assigned Equipment number
- All mechanical, heating, ventilation and cooling system equipment. Each unit and item of maintenance location shall be tagged individually, along with each component within the system in other areas of the building/facility. Custom engrave (bi-laminated) plastic sleeved tags with equipment numbers, naming and direction arrows for each piping, refrigerant lines, condensate, drain lines and system lines shall receive a label every 6 LF at min which can be readable from below or system access point.

204.3.6.2 Equipment ID tagging shall meet the following requirements:

### **PRODUCTS**

#### **Equipment ID Number and Name Tagging Plates**

All equipment tagged on the drawings, except for buried submerged equipment shall be provided with an Equipment ID Number Plate bearing the equipment tag number and equipment name. Each equipment ID Plates shall be rectangular 3.5"x .75" and 1/16" thick laminated blue phenolic plastic engraving stock that is U/V stable. Lettering shall be 1 line of text, centered, and white capitalized block letters .25" high and engraved to a depth of 0.08mm.

Equipment ID Number Plates must follow the Equipment ID numbering and naming scheme. Each equipment or systems should also include an additional tag noting the general name of the equipment or system adjacent to the equipment ID numbering tag (i.e., "Final Clarifier #3", VFD for Pump #2, etc.).

Equipment ID Number Plates shall be attached with permanent adhesive or stainless fasteners.

Additional Number Plates shall be provided for ancillary devices associated with each piece of new tagged equipment.

Additional tags shall be provided for all electrical disconnects, variable frequency drives, switching and Motor Control Centers whether new or existing.

**VALVE, BUTTERFLY AND GATE EQUIPMENT ID NUMBER AND  
NAME TAGGING PLATES**

**Equipment ID Number and Name Plates**

Additional details for all valves and gates, except buried or submerged valves, that have been assigned an Equipment ID number on the Drawings or in the valve or gate schedule, shall be provided with a permanent number plate. Equipment ID Number Plates shall be round 1.5" and 1/16" thick laminated blue phenolic plastic engraving stock that is U/V stable. Lettering shall be in 3 sections, centered, and white capitalized block letters 3/16" high and engraved to a depth of 0.08mm.

Example: 1<sup>st</sup> line XXXX-

2<sup>nd</sup> line XXXX-

3<sup>rd</sup> line XXXXX

Equipment ID Number Plates must follow the Equipment ID numbering and naming scheme. Reference the project equipment warranty log for additional information.

Equipment ID Number Plates shall be attached with permanent stainless cable ties or stainless fasteners. Plated or coated fasteners will not be permitted.

See contract drawings for buried valves concrete collar details and special custom stainless steel tagging requirements. All buried valves 2" and greater require an engraved stainless steel tagging with system name and equipment number.

204.3.7 Equipment Coatings: All equipment shall be supplied with a factory applied coating sufficient to withstand a wastewater environment. Factory applied coating shall be in accordance with the painting/coating section.

204.3.8 Equipment Installation: All anchor bolt connections shall include the use of a washer, lock washer, and nut (without nylon or similar insert).

- 204.3.8.1 Installation of all equipment and related items shall be performed as directed in the manufacturer's installation instructions.
- 204.3.8.2 No cutting, drilling or welding of new equipment or part thereof as delivered from the manufacturer for the purpose of adapting or modifying said unit to facilitate its installation will be permitted without written prior approval by the authority.
- 204.3.8.3 The Contractor shall be responsible for any and all concrete modifications that may be required to install the new equipment. This shall include modifications or replacement of equipment pads and supports. All modifications shall be designed and constructed to conform to the recommendations of *ACI 302.1R-04 Guide for Concrete Floor and Slab Construction* and *ACI 301-10 Standard Specifications for Structural Concrete*. All concrete modifications and repairs shall be coated per the painting/coating section herein.

204.3.9 Equipment Start Up and performance:

- 204.3.9.1 All new equipment installed by the contractor must be started up and be in operational service for 48 hours with no performance issues prior to demolishing and installing like, adjacent equipment in the same system. If the new equipment exhibits any performance issues, the contractor shall repair the equipment/installation as required and begin a new 48 hour observation period.

END OF SECTION

#### 204.4 General Electrical Requirements

- 204.4.1 Electric Code Compliance: All electrical work shall be performed in compliance with current electrical code.
- 204.4.2 Electrical Disconnects: All equipment installed or worked on with an electrical portion in the scope of work shall have a new local disconnect switch installed. All local disconnect switches shall be of stainless steel construction meeting NEMA 4X standards. In the event a Class 1, Division 1 rating is required for explosion proof service, the disconnect shall meet all required ratings for Class 1, Division 1 service. Control panels that incorporate an integral disconnect will not be required to have an external disconnect.
- 204.4.3 Electric Motors: All electric motors shall be premium efficiency, suitable for operating the intended equipment per the equipment manufacturer's recommendations.
- 204.4.4 Electrical Wiring & Related Items: Contractor shall use caution to avoid damage to existing power cables. These cables shall be reused in new equipment installation provided their reuse meets current code requirements. Contractor shall be responsible for any damage to existing electrical equipment or power cables. The contractor shall be responsible for removing the existing control system and replacing it with the new control system. No unused remnants of the existing control system shall be abandoned in place.
- 204.4.5 Identification: Conduits in manholes, hand-holes, building entrance pull boxes, junction boxes and equipment shall be provided with identification tags. Identification tags shall be 19 gage stainless steel with ½ inch stamped letters and numbers as indicated on the drawings. Identification tags shall be attached to conduits with nylon tie wraps and shall be positioned to be readily visible.
- 204.4.6 Rigid Steel Conduit shall be heavy wall, plated/hot-dip galvanized, shall conform to ANSI C80.1, and shall be manufactured in accordance with UL 6. Not applicable to this contract unless specifically noted otherwise.
- 204.4.7 Liquid tight Flexible Metal Conduit shall be hot-dip galvanized steel, shall be covered with a moisture proof polyvinyl chloride jacket, and shall be UL labeled. For interior applications only.
- 204.4.8 Rigid Nonmetallic (PVC) Conduit - PVC conduit shall be heavy wall, Schedule 40, UL labeled for aboveground and underground uses, and shall conform to NEMA TC-2 and UL651. Not acceptable and not applicable to this contract.



204.4.9 Aluminum Rigid Conduit system:

204.4.9.1 The conduit shall be rigid aluminum, threaded, T-1 temper as part of electrical of an all-aluminum conduit system with couplings, bends and fittings as required. Any fasteners and other hardware shall be 316 stainless steel as required and applicable. In the event a Class 1, Division 1 rating is required for explosion proof service, the conduit system shall meet all required ratings for Class 1, Division 1 service. Provide in all interior and exterior installation locations.

204.4.9.2 The conduit system shall be UL 6A and ANSI C80 5 rated for application.

204.4.9.3 Provide "seal-off" corrosion protection at all and panels, device outlets and equipment as recommended by conduit Manufacture.

204.4.9.4 Acceptable manufactures are Wheatland Tube, Republic Conduit, and American Conduit by Sapa or equal.

204.4.9.5 Unless a Manufacture requirements, code or other governing requirement specifically require something other than aluminum conduits, all conduits and accessories shall be aluminum

204.4.10 Conductors. All conductors in power, control and instrumentation circuits shall be identified and color coded as described herein.

204.4.10.1 Conductor Identification Number. Except for lighting and receptacle circuits, each individual conductor in power, control and instrumentation circuits shall be provided with wire identification markers at the point of termination.

204.4.10.2 The wire numbers shall be of the heat-shrinkable tube type, with custom typed identification numbers.

204.4.10.3 The wire numbers shall be as indicated on the equipment manufacturer's drawings.

204.4.10.4 The wire markers shall be positioned to be readily visible for inspection.

204.4.11 Conductor Color Coding. Power conductors shall be color coded as indicated below. For conductors 6 AWG and smaller, the color coding shall be insulation finish color. For sizes larger than 6 AWG, the color coding may be by marking

tape. The equipment grounding conductor shall be green or green with one or more yellow stripes if the conductor is insulated.

204.4.11.1 The following color coding system shall be used for Power conductors:

204.4.11.1.1 120/240V, single-phase – black, red and white

204.4.11.1.2 120/208V, three-phase – black, red, blue and white

204.4.11.1.3 120/240V, three-phase – black, orange, blue and white

204.4.11.1.4 277/480V, three-phase – brown, orange, yellow and gray

204.4.11.1.5 Where 120/240 and 120/208 volt system share the same conduit or enclosure, the neutral for either the 120/240 volt system or the 208 volt system shall be white with a permanent identifiable violet stripe.

204.4.11.2 Control and instrumentation circuit conductors shall be color coded as indicated below:

204.4.11.2.1 Multiconductor Control Cable: 600 Volt Multiconductor 14 AWG Control Cable

204.4.11.2.2 REFERENCE: UL 83, UL 1277, ICEA S-73-532, ICEA S-58-679.

204.4.11.2.3 CONDUCTOR: 14 AWG, 7 OR 19 strands, concentric-lay, uncoated copper. Maximum operating temperature 90°C dry, 75°C wet.

204.4.11.2.4 INSULATION: Polyvinyl chloride, not less than 15 mils average thickness; 13 mils minimum thickness, UL 83 Type THHN and THWN.

204.4.11.2.5 SHIELD: None.

204.4.11.2.6 JACKET: Conductor: Nylon, 4 mils minimum thickness, UL 83.

204.4.11.2.7 Cable assembly: Black, flame-retardant polyvinyl, UL 1277, applied over tape-wrapped cable core.

- 204.4.11.2.8 COLOR IDENTIFICATION: ICEA S-58-679, Method1, Table 2 or ICEA S-58-679, Method 3, Table 2. White or green conductors shall not be provided. A durable marking shall be provided on the surface of the cable at intervals not exceeding 24 inches. Marking shall include manufacturer's name, Type THWN or THHN, conductor size, number of conductors, and voltage class.
- 204.4.12 Signal Control Cable:
- 204.4.12.1 REFERENCE: UL 62, UL 1277.
- 204.4.12.2 CONDUCTOR: 16 AWG,7-strand, concentric-lay, uncoated copper. Maximum operating temperature 90°C dry, 75°C wet.
- 204.4.12.3 INSULATION: Polyvinyl Chloride, not less than 15 mils average thickness: 13 mils minimum thickness, UL 62, Type TFN.
- 204.4.12.4 LAY: Twisted pair with 1-1/2 inch to 2-1/2 inch lay.
- 204.4.12.5 SHIELD: Cable assembly, combination aluminum-polyester tape and 7-strand, 20 AWG minimum size, tinned copper drain wire, shield applied to achieve 100 percent cover over insulation conductors.
- 204.4.12.6 JACKET: Conductor. Nylon, 4 mils minimum thickness, UL 62.
- 204.4.12.7 Cable assembly: Black, flame-retardant polyvinyl chloride, UL 1277, applied over tape-wrapped cable core.
- 204.4.12.8 CONDUCTOR IDENTIFICATION: One conductor black, one conductor white.
- 204.4.13 Single Conductors: 600 Volt, Single Conductor Power Cable
- 204.4.13.1 REFERENCE: UL 83, ICEA S-95-658 (NEMA WC 70).
- 204.4.13.2 CONDUCTOR: Stranded, uncoated copper. Maximum operating temperature 90°C dry, 75°C wet.

- 204.4.13.3 INSULATION: Polyvinyl, UL 83, type THHN and THWN, ICEA S-95-658.
- 204.4.13.4 SHIELD: None
- 204.4.13.5 JACKET: Conductor. Nylon, 4 mils minimum thickness, UL 83.
- 204.4.14 Pump Control Panels (Cabinets) – Unless otherwise noted, Contractor shall provide each unit with the following system components to conform to the following specifications:
  - 204.4.14.1 Input Disconnect: Furnish an input circuit breaker with an interrupting rating of 65,000 rms symmetrical amperes.
  - 204.4.14.2 Control Devices: Include door mounted control and monitoring devices for each sump pump as follows:
    - A. “Manual-OFF-Auto” control selection
    - B. Power disconnect
    - C. Elapsed time meter; shall be non-resettable, rollover at 9999 hours showing resolution of 0.1 hours
    - D. Phase loss monitor
    - E. Indicator lamps for Power On, Run, Phase Loss and Overload.
  - 204.4.14.3 NEMA contactors size 1 or larger rated to handle the connected load.
  - 204.4.14.4 Refer to Drawings for control panel schematics for additional requirements.
  - 204.4.14.5 Coil Voltage: 120-volts, 60-hertz.
- 204.4.15 Variable Frequency Drives (VFD):
  - 204.4.15.1 Enclosures: New VFD units shall be supplied with and installed in a new enclosure. All component enclosures shall be NEMA 12 compliant, and shall fit in the location of replaced equipment.

204.4.15.2 System Features: Contractor shall provide each unit with the following system components to conform to the following specifications:

204.4.15.3 Input Disconnect: Furnish an input circuit breaker with an interrupting rating of 65,000 rms symmetrical amperes

204.4.15.4 The VFD units must comply with all requirements of the existing pumps. The new VFD units shall be 18 pulse "clean power", low harmonic in compliance with IEEE 519 guidelines for harmonic mitigation and have a continuous output current of approximately 30% more than the motor full load nameplate current.

204.4.15.5 New VFD units shall be installed with no cutting, drilling or welding of the new equipment or part thereof as delivered from the manufacturer, for the purpose of adapting or modifying said unit to facilitate its installation, will be permitted without written prior approval by the Authority.

204.4.15.6 Control Devices: Include door mounted control and monitoring devices for each drive as follows:

Start push button

Stop push button

"Local-OFF-Remote" control selection

Maintained Emergency shutdown button – Palm press and red in color

Speed selection – Door mounted potentiometer operating single turn 0% - 100%

Frequency meter with hertz and 0-100 scales

Output ammeter

Elapsed time meter shall be non-resettable, rollover at 9999 hours showing resolution of 0.1 hours

Diagnostic package with fault indication and reset push button

Indicator lamps for the ON, OFF, Auto, Vibration and FAULT unit status conditions

Vibration sensors shall be installed and operated such that when a vibration alarm is triggered, the VFD/Pump shuts down automatically

Vibration sensors shall have the operating capacity of sending a 4-20 mA signal to an analog PLC input and a dry set of contacts for the relay logic

204.4.15.7 PLC Control Features: Furnish a control system for each drive to allow the following Auto/PLC functions:

Remote, isolated 4-20 mA speed control input

Isolated 4-20 mA speed output

PLC Remote Run command

Alarm outputs

ON/OFF status output

Additional features and controls specified with the drive equipment

Local/Auto status output

204.4.15.8 New and replacement VFDs shall be installed such that all 4-20mA features are available. If a VFD being replaced is not currently configured to communicate with the SCADA system, the replacement unit shall communicate with the SCADA system in the same manner of a new VFD installation. On new VFD installations, all 4-20mA communication features shall be installed in the VFD for future connection to the SCADA system. All function and options which are included in the

new VFD shall be integrated fully into the City's SCADA system, including SCADA screen(s).

204.4.15.9 General Purpose Contactors: Provide general purpose contactors in accordance with NEMA ICS 2 meeting the following:

Coil Voltage: 120-volts, 60-hertz

Poles: Provide three-pole contactors, unless otherwise indicated.

204.4.15.10 Electrical Wiring: Contractor shall be responsible for verifying or replacing all wiring from existing breakers and/or disconnects to the new equipment including replacing breakers as required. All wiring and electrical construction shall meet current electrical code.

204.4.15.11 Complete O&M Manuals and operating parameters shall be supplied on CD.

204.4.15.12 Electrical Wiring & Related Items:

204.4.15.13 All wire to wire connections shall be made using insulated mechanical connectors. All shielded cable shall use heat shrink to cover cable outer cover and shield for termination. No wire nuts or butt splices are to be used unless previous authorization is given by the engineer. Insulated mechanical connectors shall be manufactured by Penn-Union, Galvan Industries, Polaris Electrical Connectors, or an approved equal manufacturer.

204.4.15.14 Power and control wiring will follow the NFPA 79 Chapter 13 standard.

204.4.15.15 Control wiring labeling shall follow NFPA 79 Chapter 13 standard. Control wiring identification tags shall be a thermal transfer print. A Brady TLS2200 or equivalent.

END OF SECTION

## 204.5 Painting/Coating

- 204.5.1 Surface Preparation and Shop Prime Painting: All equipment and disturbed surfaces shall be cleaned and shop primed per equipment manufacturer's recommendation as part of the work. Equipment nameplates and similar information tags shall be masked off for removal after finish coat applications. All surface preparation for applying a specified coating system shall be done in accordance with the appropriate "Application Bulletin" from the manufacture for the specific product specified. Equipment vendors/manufactures shall be consulted concerning the required final coating system to ensure that it will be compatible with the primer coat applied at the factory, in the event that the shop applied primer coat is not removed prior to the coating installation.

In coordination with the painting system submittals, the Contractor shall coordinate and provide an independent testing service or Manufacture's Representative to conduct an overcoat analysis testing report and topcoat compatibility testing prior to finalizing product selection and submission. The written report shall be included in the submittal process for all unique areas of new work and would include sufficient number of testing locations for inspection certification of all areas of the contract new work.

**Provide minimum SP-10 Near white blasting unless Manufacture requirements are more stringent in all areas submerged or exposed to raw sewage, grit structures, sewage flow structures, classification spaces (as shown on plan sheets) and sewage process equipment (high corrosive areas).**

New and rehabilitation work should include, but not limited to field inspection/investigations/testing, storage, preparations, proper procedures, access coordination, a "complete scope application" and any required details for a finish product.

- 204.5.2 Final Coat: Unless otherwise specified, all new equipment shall be shop or field painted with a final coat, provided all shop painted finish surfaces shall receive matching field touch-up painting as final treatment, all with a finish coat per the equipment manufacturer's recommendation. All disturbed surfaces shall be field painted after equipment installation with a finish coat per the equipment manufacturer's recommendation.



204.5.2.1 Disturbed surfaces will be defined as including piping between suction and discharge valves on pump assembly replacements and pipe to either side of valves on individual valve replacements. All other disturbed surfaces will be defined as existing materials adjacent to new equipment.

### 204.5.3 Coating Systems

204.5.3.1 The Coating System for painting structural steel, piping, valves, etc. not exposed to sunlight shall be Sherwin-Williams Coating System Identification A-1, Alkyd 2-coat system. This system has a primer "KemKromik, Univ. Primer" and a finish coat "Industrial Urethane, Alkyd Enamel" or an approved equal. Contractor shall submit supplier information for approval prior to painting.

204.5.3.2 The Coating System for painting structural steel, piping, valves, etc. non-immersed, mildly corrosive, wet environments and not exposed to sunlight shall be Sherwin-Williams Coating System Identification E-1, Polyamide Epoxy system. This system has a primer "Macropoxy 646" and a finish coat "Macropoxy 646" or an approved equal. Contractor shall submit supplier information for approval prior to painting.

204.5.3.3 The Coating System for painting metal surface for exterior weathering exposure in a corrosive environment shall be Sherwin-Williams Coating System Identification EU-2,Urethane Finish, Corrosive Areas 3-coat system or equal. This system has a primer "CorothaneGalvapac", second coat "Macropoxy 646" and a finish coat "Hi-solids Polyurethane" or an approved equal. Contractor shall submit supplier information for approval prior to painting.

204.5.3.4 Coating System for painting metal surface for full or partial immersion service shall be Sherwin-Williams Coating System Identification E-3, Amine Epoxy Glass Flake Reinforcement or equal. This is a two-coat system using Sher-Glass Epoxy FF. The first coat shall have a red oxide color with a minimum dry film

thickness of 10-15 mils. The second coat shall have a haze gray color. Total dry film thickness shall be a minimum 20-25 mils. Application and total dry film thicknesses shall be installed per Manufacture's recommendations.

204.5.3.5 Paint color code shall adhere strictly to DEQ code requirements. Paint Color Schedule (All colors and codes are Sherwin Williams. A crossover for Tnemec and Carboline is available on request.):

a. Potable	WaterFlyway SW6794
b. Plant Effluent Water (PEW)	Pantone 522, DEQ
c. Chilled Water	French Roast SW6069 w/ Heartthrob SW6866 bands
d. Heating Water Supply	Gray Screen SW7071 w/ White bands
e. Heating Water Return	Gray Screen SW7071 w/ Black bands
f. Compressed Air	Supreme Green W6442
g. Instrument Air	Supreme Green SW6442
h. Blower Air	Supreme Green SW6442
i. Natural Gas	Heartthrob SW6866
j. Sludge Return	Bagel SW6114
k. Sludge Waste	Sensational Sand SW6094
l. Digested Sludge	French Roast SW6069
m. Sludge Sample	Web Gray SW7075 w/ Heartthrob SW6866 bands
n. Drain/Sump	Web Gray SW7075
o. Raw Sewage	Software SW7074

204.5.3.6. If the equipment or piping being painted does not fall under any of these categories, the contractor shall make the best color match to the materials being replaced and adjacent like materials after submittal of color selection for acceptance.

204.5.3.7. PEW System specific requirements: All PEW System piping, valves, supports, operators, couplings and miscellaneous shall be color coded and marked as follows.

- a. Color Coding: Topcoat shall be Purple (Pantone 522) per the Oklahoma Department of Environmental Quality (DEQ) Title 252, Chapter 656, Section 252:656-27-4. In addition, piping shall have orange bands that are six (6) inches wide and spaced along the pipe at five (5) foot intervals.
- b. Lettering: The following language: "CAUTION: RECLAIMED WATER-DO NOT DRINK." shall be provided on the pipe near the equipment served, adjacent to valves, at each branch or tee, and at least every 50 feet in straight runs of pipe and be per Department of Environmental Quality (DEQ) Title 252, Chapter 656, Section 252:656-27-4. Lettering shall be painted or stenciled on piping or shall be applied as snap-on markers. Snap-on markers shall be plastic sleeves, Brady "Bradysnap-On B-915" or Seton "Setmark" Lettering shall be white. Reference Table 1 for lettering size requirements.
- c. Flow Arrows: PEW System piping shall not have flow arrows.

204.5.3.8 After painting, any labeling or tags covered by the paint shall be re-applied, updated or uncovered such that all labels are readable and clearly identifies the system. In the event of new piping or equipment replacing piping or equipment with labeling, the new equipment shall be labeled to match the existing. Marking and signage shall be applied once area painting is complete as part of the schedule of value item.

204.5.3.9 Equipment supplied from the manufacturer with an epoxy coating or manufactured from a corrosion resistant material (stainless steel, etc...) shall not be painted/coated after installation.

204.5.3.10 Factory applied epoxy coating systems shall be in the following thicknesses unless noted otherwise per Manufacturer's recommendations:

- a. Primer Coat \*3.0 to 5.0 mils
- b. Finish Coat \*4.0 to 6.0 mils

\*Note – Per Manufacturers Recommendations.

## 204.6 Concrete Coating

204.6.1 Materials: Concrete coating shall be Sikagard 62, Raven 405, Sauereisen SewerGard No. 210, or an approved equal to protect concrete and concrete repairs from H<sub>2</sub>S and other corrosive elements found in wastewater process facilities. Epoxy coating to be applied according to the manufacturer's installation instructions and shall extend beyond repair areas by a minimum of 6". All concrete coating products shall be handled and stored in the manner set forth in the manufacturer's installation instructions.

**The Contractor shall coordinate and provide an independent testing service or Manufacture's Representative to conduct an overcoat analysis testing report and top coat compatibility testing prior to finalizing product selection and submission. The written report shall be included in the submittal process for areas of new work and would include sufficient number of testing locations for inspection certification of all areas of the contract new work.**

204.6.2 Surface Preparation: Concrete surfaces to receive coating shall be inspected prior to surface preparation to determine the condition of the surfaces specified to receive the coating product(s) and the appropriate method or combination of methods to be used for surface preparation to meet the requirements of the coating system(s) to be applied per manufacturer's instructions. The Contactor shall bid the specified product(s) and, if a compatibility issue is found. The Manufacture will provide additional recommendations for the application and environment during the submittal process. Special attention during the Mandatory prebid meeting shall be taken by the Contractor and their

subcontractors to inspect and observe the existing concrete corrosion resistant coating, if any.

204.6.2.1 Oils, grease, incompatible existing coatings, waxes, form release, curing compounds, efflorescence, sealers, salts, or other contaminants which may affect the performance and adhesion of the coating to the substrate shall be removed per ASTM D-4258.

204.6.2.2 Incidental to this contract, every effort shall be made to minimize voids or holidays, providing a uniform coating thickness and coating thin areas by this contract to comply with Manufacturers recommended requirements. Concrete fins, protrusions, burrs, sharp edges, surface debris, existing coating(s) and concrete spatter shall be corrected by grinding or scraping on both new and existing concrete surfaces. Contract document plan sheets indicate areas of new concrete and existing concrete coating application areas.

204.6.2.3 Unless otherwise submitted and approved by the Engineer, surfaces to receive coating shall be abrasive blasted per ASTM D-4259 to remove laitance and weak concrete to expose subsurface voids, open honeycomb and air pockets. Concrete substrate shall receive a surface profile matching or exceeding the Manufacturer requirements. Prior to blasting, existing concrete as indicated on the contract plans sheets may require physical abrasive tool or bush hammer preparations over the entire surfaces to provide and prove the stable substrate as part of the new work. After blasting, surfaces shall be cleaned of all loose blast grit, dust and other debris by sweeping, vacuuming, air blasting and washing as necessary.

A fully prepared surface meeting the Manufacturers requirements shall be provided, including but not limited to surface preparations, mechanical rubbing/surfacing or grouted surface ("surfacers/primer") to comply with the Manufacturer substrate is incidental to the new coating system scope. A mortar slurry fully rubbed surface or concrete repairs of the wall is not allowed unless specifically recommended by the Manufacturer and approved by the Engineer as part of the new work. Surfacers or grouting for the Manufacturer's

requirements may include bug holes, chipped small voids, light honeycomb, cleaning edges, form "fins" or other small imperfections in concrete surfaces as required for the new coating system installation. Additionally, preparations may also include preparations of the existing coating systems for the new system. For structural concrete repairs, see plan sheet details and applicable bid items.

204.6.2.4 Surface preparation method(s) used shall be performed in a manner that provides a uniform, sound clean neutralized surface suitable for the specified coating product(s).

204.6.2.5 Infiltration shall be stopped by using a material which is compatible with the repair products and is suitable for top coating with the coating product(s). The Contactor shall bid the specified product(s) and, if a compatibility issue is found. The Manufacturer will provide additional recommendations for the application and environment during the submittal process.

204.6.2.6 Where defective concrete is encountered requiring repair at the direction of the Engineer refer to Specification Section 204.7 Concrete Rehabilitation for requirements. Concrete rehabilitation areas are defined by the direction of the Engineer for building back of the concrete to an original finished surface if required, a new finished surface if required or areas defined as concrete rehabilitation as shown on the plan sheets and/or by specific bid item for such concrete or structural repairs. **All other surface preparations required for coatings are incidental to the new coating system.**

204.6.3 Application of coating products: Application procedures shall conform to the recommendations of the coating product(s) manufacturer, including environmental controls, product handling, mixing, application equipment and methods.

204.6.3.1 Prepared surfaces shall be primed by application of the waterborne epoxy primer described herein at an application rate of 200 square feet per gallon (8 mils wet film thickness). The primer shall be allowed to dry to a tack free state. The solvent-free epoxy topcoat

described herein shall then be spray applied to a minimum wet film thickness of 80-100 mils.

204.6.3.2 No more than 12 hours shall be permitted to pass between each application of the waterborne epoxy, the solvent-free epoxy primer and the epoxy topcoat. Subsequent top coating or additional coats of the coating product(s) shall occur within the products recoat window as adjusted for temperature extremes. Additional surface preparation procedures will be required if this recoat window is exceeded.

204.6.3.3 Coating product(s) shall interface with adjoining construction materials throughout the structure to effectively seal and protect concrete substrates from infiltration and attack by corrosive elements. Procedures and materials necessary to affect this interface shall be as recommended by the coating product(s) manufacturer.

204.6.4 Submittals: The Contractor shall submit the following to the Engineer, in accordance with this Specification:

- Product data sheets and installation procedures for proposed concrete repair mortar(s).
- Detailed design notes, calculations and Shop Drawings for any temporary works, including formwork and falsework.
- Draft Daily Coating Report form (or one can be provided by the Owners Representative). Submit the draft Daily Coating Inspection Report "form(s)" with the paint submittal(s) for approval or a form can be provided by the Engineer. Provide a completed copy of a Daily Coating Report documenting the application details, including but not limited to: Manufacture's material product information being applied, project information, application location, date, ambient temperature, surface temperature, humidity, dew point, work hours applied, starting time, ending time and other relevant application information. Submit Daily Coating Inspection Report form signed by the applicator

applying the paint/coating to Owners Representative at the end of each workday's activities. At the end of the project, transmit the completed package of the Daily Coating Inspection Reports as project record documentation to the Owners Representative.

## 204.7 Concrete Rehabilitation

204.7.1 Description: The Work shall consist of:

- Removing the deteriorated concrete as shown and described on the Drawings and in this Specification, including saw cutting the perimeter of the repair area.
- Preparing the surface of the concrete for the repair, including abrasive cleaning, cleaning of existing reinforcement, and applying bonding agent to prepared reinforcement and concrete surface bonding agent as required by Manufacturers systems. Minimum exposed reinforcement rehabilitation would include sand blasted SSPC-SP 5 white metal blast cleaning and coated with (green) epoxy reinforcement repair coating system unless specifically required otherwise.
- Supplying materials and the mixing and placing of concrete repair mortar or concrete as shown and described on the Drawings and in this Specification including vibrating, finishing and curing.
- Supplying, fabricating, constructing, maintaining and removing temporary works, including falsework and formwork.

204.7.2 Submittals: The Contractor shall submit the following to the Engineer, in accordance with this Specification:

- Product data sheets and installation procedures for proposed concrete repair mortar(s).
- Detailed design notes, calculations and Shop Drawings for any temporary works, including formwork and falsework.

204.7.3 Materials: The Contractor shall supply all materials necessary for the repair and restoration of deteriorated concrete areas as follows:



204.7.3.1 Acceptable Manufacturers:

- a. Sika MonoTop 611, as manufactured by Sika Corporation, Lyndhurst, New Jersey, and Quadex QM-1s Restore, as manufactured by Quadex, North Little Rock Arkansas, are considered to conform to the requirements of this specification and has performed satisfactorily for patching or overlaying for a minimum of three years.

Sauereisen and other Manufacturers may require specific sub-straight and patching requirements specific system(s) pending submittal approval process.

- b. Substitutions: The use of other than the specified product will be considered providing the contractor requests its use in writing to the Engineer. This request shall be accompanied by:

- A certificate of compliance from an approved independent testing laboratory that the proposed substitute product meets or exceeds the specified performance criteria, tested in accordance with the specified test standards; and
- Documented proof that the proposed substitute product has a three year proven record of performance of patching or overlaying, confirmed by actual field tests and five successful installations that the Engineer can investigate.

Certification from the manufacturer demonstrating compliance with the ISO 9000 quality standard in the development, manufacture, and sale of the product.

204.7.3.2 Performance Criteria Typical Technical Data

- a. Typical Properties of the mixed polymer-modified portland cement mortar:
  - Working Time: approximately 30 minutes

- Finishing Time: 30-60 minutes
- Color: concrete gray

b. Typical Properties of the cured polymer-modified portland cement mortar:

- Compressive Strength (ASTM C-109)
  - 1 day: 3,000 psi
  - 7 day: 5,500 psi
  - 28 day: 6,500 psi
- Splitting Tensile Strength (ASTM C-496) at 28 days: 500 psi
- Flexural Strength (Modulus of Rupture) (ASTM C-78) at 28 days: 720 psi
- Bond Strength (ASTM C-882 Modified) at 28 days: 2200 psi
- Chloride ion permeability (AASHTO T-277): < 600 coulombs
- The silica fume, polymer-modified portland cement mortar shall not produce a vapor barrier.

204.7.3.3 Materials

a. Silica-fume, Polymer-modified portland cement mortar:

- The mortar shall be a silica fume-enhanced, polymer-modified composition containing a blend of selected cements, plasticizing/water-reducing admixtures and shrinkage compensating agents.
- The material shall be non-combustible, either before or after cure.
- The silica fume, polymer-modified portland cement mortar shall be supplied in a factory proportioned unit.
- The silica fume, polymer-modified portland cement mortar must be placeable from 3 inches in depth and extendable in greater depths.

b. To prepare the silica fume, polymer-modified portland cement concrete (for pumping): the factory proportioned unit maybe extended with 34-36 lbs. of a minus 1/4 in. clean, well-graded,

saturated surface dry aggregate, having low absorption and high density. Aggregate shall conform to ASTM C-33.

- c. Materials for forming, as required for the designated work, shall be approved by the Engineer.

#### 204.7.4 Construction Methods

204.7.4.1 Surface Preparation Prior to any concrete repairs, the Contractor shall remove all dust, dirt, water and debris from the surface of the concrete in a manner that will not result in the material being deposited into the channel or onto the underlying ground surface below. The Contractor shall supply and erect appropriate protection barriers/shrouding or other approved means as required on the bridge deck or piers so as to completely contain all loose or flying debris from the surface removal preparations. The means of containment shall be subject to the approval of the Engineer. No debris shall fall into the channel or onto any underlying roadway or ground surfaces.

204.7.4.2 Concrete Removal All areas of unsound concrete to be repaired will be marked by the Engineer once the Contractor has cleaned the existing surface as per Section 204.6.2 of this Specification. The Contractor shall saw cut the outer perimeter of the repair areas 1" deep or as directed by the Engineer. Feathered edges will not be acceptable. The Contractor shall take care to ensure that the existing reinforcing steel or prestressing strands (if applicable) are not damaged during saw cutting. Any damage caused by the Contractor to any portion of the structure not intended for repair shall be repaired by the Contractor, at the Contractor's expense, to the satisfaction of the Engineer. The Contractor shall remove all areas of unsound concrete by chipping or other approved methods. Only chipping hammers of the 20 lb class or less shall be used, and operated at an angle of 45 degrees or less from the horizontal. The Contractor shall exercise caution and take care not to damage any existing reinforcing steel intended to remain in place.

- 204.7.4.3 Types of Repairs Concrete repairs will be classified as follows:
- a. Type A Partial Depth Concrete Repair – A Type A repair is defined as removal of unsound concrete to a depth not greater than the top of the existing reinforcing steel. The Contractor shall remove all unsound concrete from the areas as determined by the Engineer until a sound concrete substrate is exposed.
  - b. Type B Partial Depth Concrete Repair – A Type B repair shall be defined as removal of unsound concrete to a depth a minimum of 1” beyond the existing outer mat of reinforcing steel. For substructure, girder or mass concrete repairs the maximum depth shall be 2” beyond the existing outer mat of reinforcing steel or as directed by the Engineer. For slab repairs the maximum depth shall be mid depth of the slab.
- 204.7.4.4 The Contractor shall supply and place additional reinforcing steel as directed by the Engineer when the existing reinforcing steel has a section loss of 25% or greater. The reinforcing steel shall be of the same type and size as the existing, and spliced with a minimum lap length of 30 bar diameters. Exposed reinforcing steel shall be sandblasted clean and maintained to a near white condition. The Contractor shall roughen all areas of the existing sound concrete substrate to a ¼” amplitude using methods acceptable to the Engineer. All resulting material and by-products from demolition operations shall be collected, loaded, hauled, and disposed of by the Contractor at an approved waste disposal facility. Costs for reinforcing steel shall be considered incidental and included in other portions of the work.
- 204.7.4.5 Surface Preparation Immediately prior to placing the repair mortar or concrete, the Contractor shall thoroughly clean the existing concrete surfaces and formed repair areas, and apply a low resistivity bonding agent or cement slurry as recommended by the repair mortar manufacturer or as directed by the Engineer.
- 204.7.4.6 Repair Mortar Placement and Finishing The concrete repair mortar shall be handled, stored, mixed and applied in accordance with the

manufacturer's instructions. Immediately prior to placing the repair mortar, the Contractor shall thoroughly clean the existing concrete surfaces and formed repair areas, and apply a low resistivity bonding agent or cement slurry as recommended by the repair mortar manufacturer or as directed by the Engineer. The Contractor shall place the repair mortar such that the existing profile and cross section are restored to their original dimensions. Any deviations of ¼" or greater from the repaired areas to the existing surface shall be repaired by the Contractor at his expense to the satisfaction of the Engineer. If the existing or repair concrete surface is damaged in any way by construction operations, or if the concrete repair shows signs of distress or scaling prior to final acceptance, it shall be repaired or replaced by the Contractor at his own expense. The Contractor shall finish the repair surface in accordance with the concrete coating manufacturer's requirements.

204.7.4.7 Curing shall be in accordance with the manufacturer's instructions or as otherwise directed by the Engineer.

#### 204.7.5 Quality Management

204.7.5.1 General Concrete repair mortar that is not stored, handled, prepared, placed, or cured in accordance with the manufacturer's instructions will be rejected by the Engineer and his/her decision shall be considered final. The Engineer reserves the right to require immediate removal of any concrete from rejected batches that may have already been placed in the structure. Quality assurance testing will be carried out by the Engineer and all associated costs will be paid for by the Owner. There shall be no charge to the Owner for materials taken by the Engineer for testing purposes.

#### 204.7.6 Method of Measurement

204.7.6.1 Concrete Repairs Concrete repairs will be measured on a surface area basis. The area to be paid for will be the total number of square feet of concrete repaired in accordance with this specification as computed from measurements made by the Engineer.

#### 204.7.7 Basis of Payment

2.4.7.7.1 Type A Partial Depth Concrete Repair – Type A Partial depth concrete repairs will be paid for at the Contract Unit Price per square foot for “Type A Partial Depth Concrete Repair”, measured as specified herein, which price will be payment in full for performing all operations herein described and all other items incidental to the Work.

204.7.7.2 Type B Partial Depth Concrete Repair – Type B Partial depth concrete repairs will be paid for at the Contract Unit Price per square foot for “Type B Partial Depth Concrete Repair”, measured as specified herein, which price will be payment in full for performing all operations herein described and all other items incidental to the Work.

END OF SECTION

## PART 1 - GENERAL

### 1.1 STANDARDS

- A. Concrete work shall conform to all requirements of ACI 301-89 "Specifications for Structural Concrete for Buildings", ACI 350 "Code Requirements for Environmental Engineering Concrete Structures", ACI 318-89 "Building Code Requirements for Reinforced Concrete" except as modified herein.
- B. All referenced standards shall be the latest editions.

### 1.2 SCOPE

- A. Work consists of furnishing all plant, labor, materials, equipment and appliances, and performing all operations in connection with installation of the concrete work, complete, in strict accordance with the Specifications and Drawings.

### 1.3 INSPECTION

- A. Embedded items must be inspected and tests for concrete and other materials shall have been completed and approved by the Engineer before concrete is placed.

### 1.4 SLAB ON EARTH

- A. Before proceeding to construct concrete slabs on earth, all pipes under concrete floor on earth shall have received the required tests. All backfill and fill material under slabs on grade shall be compacted in 6" layers to 95% maximum density as measured by AASHTO T99 test method. Unsuitable material encountered in subgrade shall be removed and replaced with material approved by the Engineer. Subgrade shall be brought to true, even plane and compacted to solid bearing. Gravel drainage fill shall be placed and compacted where shown on Drawings.

## PART 2 - MATERIALS

- 2.1 All concrete materials shall conform to the latest revised ASTM Designations listed below and shall be subject to the approval of the Engineer:

- A. Coarse Aggregate shall be crushed stone conforming to ASTM C-33 with a maximum size of 1".
- B. Fine Aggregate shall conform to ASTM C-33 and shall be washed river sand composed of clean, uncoated grains of strong materials.
- C. Cement shall be Portland cement conforming to ASTM Specification C-150, Type V. Only one brand of cement shall be used for exposed concrete.
- D. Water: Clean, fresh and free from oil, acids, alkali, vegetable, sewage, organic or other deleterious matter.
- E. Air-Entraining Admixtures shall conform to ASTM C-260.
- G. Premolded Expansion Joint Filler Strips shall be non-extruding type conforming to the current AASHTO Designation M213.
- H. Non-Shrink Grout shall be Pre-mixed "Embeco" as manufactured by Master Builder's, "Ferrolith G" as manufactured by Sonneborn-Contech, or approved equal. Type as recommended by the manufacturer for the particular applications.
- I. Liquid Curing Compound/Sealer shall be "MC 429" as manufactured by Master Builder's, "Kure-N-Seal" as manufactured by Sonneborn-Contech, "Thompson's Water Seal" as manufactured by E. A. Thompson, Inc. or approved equal.
- J. Granular Drainage Fill: Required under all interior building concrete slabs on grade and where noted on the drawings. It shall be either:
  - 1. Clean, washed gravel with particle sizes grading from maximum of 1" down to not more than 5% passing a No. 4 sieve.
  - 2. Clean, washed coarse sand with particular sizes ranging from pea gravel down to largest grains permitted in concrete sand.
- K. Joint Waterproofing for existing structures or as required on the plans shall be Ironite (Metallic) Waterproofing as manufactured by the Ironite Company of Chicago, Illinois or approved equal.



- L. Vapor Barrier required under all interior concrete slabs on grade and where noted in drawings shall be polyethylene sheet, 6 mil thickness conforming to ASTM E-154.
- M. Liquid Chemical Hardener shall be the magnesium fluosilicate and zinc fluosilicate type "Lapidolith" as manufactured by Sonneborn-Contech, Inc., "Symons Quad Cure" as manufactured by Symons Corp., "Hornolith" as manufactured by W. R. Grace & Co., or approved equal.
- N. Cementitious Waterproofing and Finish Compound shall be "Thorseal Plaster Mix" with "Acryl 60" as manufactured by Standard Dry Wall Products or equal.

## 2.2 QUALITY AND CONTROL

### A. Design

Concrete shall be composed of Portland cement, fine aggregate, coarse aggregate and water. All concrete shall be designed by an independent testing laboratory, approved by the Engineer, in accordance with the A.C.I. Standard "Recommended Practice for Selecting Proportions for Concrete" (ACI 211) to produce the strength for each class of concrete specified, and with slumps and maximum sizes of coarse aggregate in accordance with the requirements outlined below. The concrete shall be so designed that the concrete materials will not segregate and excessive bleeding will not occur. Submit laboratory trial mix designs and test results for each class of concrete to be used to the Engineer for approval before any concrete is placed. Any costs of the testing laboratory for designing concrete mixes shall be borne by the Contractor. Concrete strengths shall be as follows:

Class A Concrete - 4000 psi minimum @ 28 days (Air entrained) - six (6) sacks cement minimum

Class B Concrete - 3000 psi @ 28 days - five (5) sacks cement minimum

Class C Concrete - 2000 psi @ 28 days

Class D Concrete - 3000 psi @ 28 days (3/8" Max. Aggregate Size "Pea Gravel")

MAXIMUM SLUMPS FOR VARIOUS  
 TYPES OF CONSTRUCTION

<u>Types of Construction</u>	Hand Placed <u>Maximum</u>	High Frequency Vibrator <u>Used - Maximum</u>
Reinforced Foundation, Footings and Base Slabs of Tanks	5"	3"
Slabs, Beams and Reinforced Walls	6"	5"
Building Columns	6"	5"
Pavements, curb and sidewalks	3"	3"

The slump shall not exceed the maximum specified above for the type of construction for which it is to be used. The 28 day compressive strength determined in accordance with current ASTM Specifications C-39 and C-31 and with specimens cured in accordance with C-31 shall not be less than that shown above for the specified class of concrete. No water will be added after the amount specified by the mix design.

B. Production of Concrete

All ready-mix concrete shall be batched, mixed and transported in accordance with "Specifications for Ready-Mixed Concrete (ASTM C-94)". Plant equipment and facilities shall conform to the "Check List for Certification of Ready-Mixed Concrete Production Facilities" of the National Ready-Mixed Concrete Association. Site mixed concrete shall conform to the requirements of "Specifications for Structural Concrete" (ACI 301). The Contractor may elect to use either ready-mixed or site mixed concrete for this project provided he informs the Engineer of his choice.

C. Laboratory Testing

The Owner shall engage an independent testing laboratory to conduct concrete tests. Contractor will be responsible for sampling concrete for test cylinders, recording, and delivering them to the laboratory, providing all materials required, and for making all slump tests in the field directed by the Engineer. All costs in connection with work performed by the laboratory will be paid by the Owner. The Contractor shall be responsible for the costs of work performed by the laboratory required for redesign of concrete proportions and additional testing of in place concrete when cylinders indicate

low strength concrete has occurred.

At least one test shall be made on fresh concrete for each one hundred (100) cu. yds. of each class of concrete (or fraction thereof) placed on any one day and in any event, not less than one test for each class of concrete each day it is used. Testing shall be done in accordance with the following ASTM Specifications, latest edition:

C172- Standard Method of Sampling Fresh Concrete

C31 - Standard Method of Making and Curing Concrete Compression and Flexure Test Specimens in the Field

C39 - Standard Method of Test of Compressive Strength of Molded Concrete Cylinders

C143- Standard Method of Slump Test for Consistency of Portland Cement Concrete

Before any concrete is poured, the Contractor shall construct a storage box in accordance with ASTM Specification C31. Each set of tests shall consist of one slump test and four compression test cylinders. All cylinders shall be kept in the storage box for the first 24 hours. The four cylinders shall be laboratory cured and tested for adequacy of the design for strength of the concrete in accordance with ASTM Specification C31. One cylinder shall be tested at 7 days and two at 28 days.

The fourth cylinder will be retained for subsequent testing if required by the Engineer.

- D. Failure of Concrete to Meet Strength Requirements: The concrete shall be considered acceptable if, for any one class of concrete, the average of all tests of any five consecutive sets is equal to or greater than the specified strength, provided that no more than one test in ten falls between 90% and 100% of the specified strength. The only cylinders to be used for determination of concrete acceptability will be those laboratory cured and tested at 28 days. When it appears the tests of laboratory-cured cylinders will fail to meet these requirements, the Engineer may require changes in the proportions of concrete for the remainder of the work in order to meet the strength requirements. In addition, the Engineer may also require additional curing on portions of the concrete already poured.

The Engineer may also require tests in accordance with Methods of Securing, Preparing

and Testing Specimen from Hardened Concrete for Compressive and Flexural Strengths (ASTM Specifications C42) when the concrete cylinder tests fail to meet strength requirements. In the event there still is question as to the quality of the concrete in the structure, the Engineer may require load tests for that portion where the questionable concrete has been placed. Such load tests will be made as outlined in American Concrete Institute Building Code, (ACI 318), and shall be at the expense of the Contractor. In-place testing shall be at the expense of the Contractor.

- E. Removal of Under Strength Concrete: If the above tests indicate that a particular batch of previously placed concrete is under strength, the Engineer may direct that the under strength batch be removed and replaced. The removal of the under strength concrete shall also include the removal of concrete that has obtained the required strength if the Engineer deems this necessary to obtain structural or visible continuity when the concrete is replaced.

The removal, and replacement of any under strength concrete, shall be made at no additional cost to the Owner. This shall include any new formwork required or any reinforcing steel that may be required. The Owner shall not be charged any additional costs for any extra work that is required because of the failure of any concrete to meet the minimum test requirements.

- F. Concrete Strengths: The various strengths of concrete shall be installed as follows:
1. Class A, 4000 psi, Air-Entrained shall be used for all liquid containing and non-liquid containing structures, (footings, driveways, slabs, walls, columns and roofs.)
  2. Class B, 3000 psi shall be used for sidewalks, curbs and thrust blocking.
  3. Class C, 2000 psi shall be used for all non-structural fill concrete, mud slabs, over excavation concrete and other selective backfill conditions as approved by the Engineer.
  4. Class D, 3000 psi pea gravel concrete (maximum aggregate size of 3/8") shall be used for all masonry fill, masonry columns cells, and masonry bond beams.

### 3.1 PREPARATION BEFORE PLACING

- A. Water shall be removed from excavations before concrete is deposited. Hardened concrete, wood chips, shavings, and other debris shall be removed from interior of forms and inner surfaces of mixing and conveying equipment. Wood forms shall be oiled or, except in freezing weather, wetted with water in advance of pouring. Reinforcement shall be secured in position, inspected and approved by the Engineer before starting pouring of concrete.

### 3.2 CONVEYING

- A. Concrete shall be conveyed from mixer to forms as rapidly as practicable and by methods, which will prevent segregation or loss of ingredients. It shall be deposited as nearly as practicable in its final position. Chutes used shall be such that concrete slides in them and does not flow. Chutes, if permitted, shall have a slope of less than 1 on 2. Where a vertical drop greater than five (5) feet is necessary, placement shall be through elephant trunks or similar devices to prevent segregation. Ready-mixed concrete shall be delivered with a load ticket showing mix proportions and the time mixing began for each load. The load ticket shall be furnished to the Engineer.

### 3.3 PLACING

- A. Concrete shall be placed before initial set has occurred and in no event after it has contained its water content for more than 30 minutes for site mixed concrete or 1 hour for ready-mixed concrete. Unless otherwise specified, all concrete shall be placed upon clean, damp surfaces free from running water, or upon properly consolidated fills, but never upon soft mud or dry, porous earth. Deposit concrete continuously or in layers of such thickness that no concrete will be placed on concrete which has hardened sufficiently to cause the formation of seams or planes of weakness within the section.
- B. If a section cannot be placed continuously, provide construction joints as herein specified. The concrete shall be compacted and worked in an approved manner into all corners and angles of the forms and around reinforcement and embedded fixtures as to prevent segregation of the coarse aggregate. Construction of forms for the lifts of vertical walls shall be such as to make all parts of the walls easily accessible for the placement, spading, and consolidation of the concrete as specified herein.

- C. No "finished water" shall be surface applied during finishing efforts.
- D. Curing methods shall be submitted to the Engineer and applied per manufacture's recommendations.

### 3.4 VIBRATION

- A. All concrete shall be placed with the aid of mechanical vibration equipment as approved by the Engineer. Vibration shall be transmitted directly to the concrete; in no case shall it be transmitted through forms. The duration of vibration at any location in the forms shall be held to the minimum necessary to produce thorough compaction. Vibrations shall be supplemented by forking or spading by hand, and adjacent to the forms on exposed faces in order to secure smooth, dense and even surfaces, with particular care being taken to prevent coarse aggregate from becoming set too near any surfaces that are to receive rubbed finish.

### 3.5 CONSTRUCTION JOINTS

- A. Construction joints shall be formed as indicated on the drawings or as approved or directed by the Engineer. Contractor shall submit a joint location plan for each structure to the Engineer for approval 28 days prior to commencing concrete operations on that structure. Where indicated or required, dowel rods shall be used. All concrete at the joints shall have been in place not less than 12 hours, and longer if so directed by the Engineer, before concrete resting thereon is placed. Before placing is resumed, or commenced, excess water and laitance shall be removed, and concrete shall be cut away, where necessary, to insure a strong dense concrete at the joint. In order to secure adequate bond, the surface of concrete already in place shall be cleaned, roughened, and then spread with a one-half ( $\frac{1}{2}$ ) inch layer of mortar of the same cement-sand ratio as is used in the concrete, immediately before the new concrete is deposited. The unit of operation is not to exceed 40 feet in any horizontal direction, unless otherwise required by the Drawings. Construction joints, if required, shall be located near the mid-point spans for slabs, beams or girders. Joints in columns or piers shall be made at the underside of the deepest beam or girder at least five (5) hours before any overhead work is placed thereon. Joints not shown or specified shall be so located as to least impair strength and appearance of work. Vertical joints in wall footings shall be reduced to a minimum. Placement of concrete shall be at such a rate that surfaces of concrete not

carried to joint levels will not have attained initial set before additional concrete is placed thereon.

- B. Girders, beams and slabs shall be placed in one operation. To ensure a level straight joint in exposed vertical surfaces, a strip of dressed lumber may be tacked to the inside of the forms at the construction joint. The concrete shall be poured to a point one (1) inch above the underside of the strip. The strip shall be removed one (1) hour after concrete has been placed and any irregularities in the joint line leveled off with a wood float and all laitance removed. Waterstops shall be installed in all construction joints below grade or in liquid containing structures as noted on the Plans. Install as per SECTION 3.3, CONSTRUCTION JOINTS, EXPANSION JOINTS, & WATERSTOPS.

### 3.6 PATCHING

- A. Any concrete which is not formed as shown on the Plans, or for any reason is out of alignment or level or shows a defective surface shall be considered as not conforming with the intent of these Specifications and shall be removed from job by Contractor at his expense, unless the Engineer grants permission to patch defective area, which shall be done in accordance with the following procedure. Permission to patch any such area shall not be considered a waiver of the Engineer's right to require complete removal of defective work if patching does not, in his opinion, satisfactorily restore quality and appearance of surface. Suitable non-shrink, latex or epoxy mortar shall be used for patching and repairing defective surface if permitted by the Engineer.
- B. After removing forms, all concrete surfaces shall be inspected and any poor joints, voids, stone pockets, all tie holes, or other defective areas shall be patched, if permitted by the Engineer. Where necessary, defective areas shall be chipped away to a depth of not less than one (1) inch with edges perpendicular to the surface. Area to be patched and a space at least six (6) inches wide entirely surrounding it shall be wetted to prevent absorption of water from the patching mortar. A grout of equal parts Portland cement and sand, with sufficient water to produce a brushing consistency, shall then be well brushed into the surface followed immediately by the patching mortar. The patch shall be made of the same material and of approximately the same proportions and shall not be richer than 1 part cement to 3 parts sand. White Portland cement shall be substituted for a part of the gray Portland cement to match color of the surrounding concrete. The proportion of white and gray cements shall be determined by making a trail patch. The amount of mixing water shall be as little as consistent with the requirements of handling and placing.

The mortar shall be retempered without the addition of water by allowing it to stand for a period of one (1) hour during which time it shall be mixed occasionally with a trowel to prevent setting.

- C. The mortar shall be thoroughly compacted into place and screened off so as to leave patch slightly higher than surrounding surface. It shall then be left undisturbed for a period of 1 to 2 hours to permit initial shrinkage before being finally finished. The patch shall be finished in such a manner as to match the adjoining surface. On surfaces where unlined forms have been used, the final finish shall be obtained by striking off the surface with a straightedge spanning the patch and held parallel to the direction of the form marks.
- D. Tie holes left by withdrawal of rods or the holes left by removal of ends of ties shall be filled solid with non-shrink grout after first being thoroughly wetted within 7 days of placement and prior to any area backfill.

### 3.7 SLAB FINISHES

- A. Exterior Concrete Walks:

After thoroughly consolidating the concrete the top surface shall be struck off with a straight edge and tamped or vibrated sufficiently to bring mortar to the surface. Finish with a wood float to a smooth, even surface and lightly broomed to provide "slip resistant" surface. Edges shall be rounded with a 1/4" radius.

- B. Interior slabs to receive grout fill or mortar setting bed shall be finished by tamping concrete with special tools to force coarse aggregate below the surface, and screened with straightedges to bring surface to finish plane with a tolerance not exceeding 1/8" in 2 feet. Surface shall be left roughened sufficiently to produce good bond with topping material. Use stiff brushes, brooms or rakes as necessary to provide 1/8 inch deep grooves at maximum of 1/2 inch on center.
- C. Top and bottom slabs of all structures and water carrying conduits except as noted otherwise on the Plans shall be finished as follows: The top of the slab shall be screened to grade and cross section; lightly tamped as required to bring up a good bed of mortar for finishing and re-screened as necessary. The surface shall then be finished with a wood float and leveling darby. No further finish will be required on top slabs of structures



or conduits, which are to be buried. In the case of all exposed top slabs of structures and conduits, they shall be given a final wood float and a lightly broomed, slip resistant finish to a uniform surface, which conforms with accuracy to required shape, slope and grade. Slabs shall be edged as appropriate. No liquid hardener is to be applied to these surfaces.

- D. Interior floor slabs that are not to receive any finish floor covering shall be "slip resistant finish" as follows: The top surface shall be steel troweled and have a final finish applied by brushing lightly with a soft bristle brush to form a slightly roughened surface.
- E. Liquid Hardener shall be applied to the floors where scheduled to be exposed concrete. Concrete surfaces to be treated must be thoroughly set and dry, clean and free of dust. Three applications of the liquid hardener are required, using one gallon per 100 square feet for the complete treatment. Apply hardener strictly according to the manufacturer's printed instructions. Liquid floor hardener is not required when a minimum of two (2) coats of Thompson's Waterseal or equal has been used as a curing and/or separating compound. Submit material and method to be used for Engineer's approval.

### 3.8 FINISH OTHER THAN SLABS

- A. All top surfaces, other than slabs, not covered by forms, and which are not to be covered by additional concrete or fill shall receive a wood float finish without additional mortar. Care shall be taken that no excess water is present when the finish is made. Other surfaces shall be brought to finished elevations and left true and regular. All exposed top surface interior concrete shall be grouted smooth and given a cement wash of one part light colored Portland cement and two parts fine aggregate mixed with water to consistency of thick paint. Grout shall be cork or wood floated to fill all pits, air bubbles, and surface holes. Excess grout shall be scraped off with a trowel and rubbed with burlap to remove any visible grout film. Surface shall be kept damp during setting period. The finish for any area shall be completed in the same day and the limits of a finished area shall be made at natural breaks in finished surface. Painting of exposed-to-view concrete surfaces is specified under SECTION 9.1 - PAINTING of these Specifications.
- B. Rubbed Finish:

Unless otherwise indicated, all faces (except top surfaces of slabs) exposed to view, such as walls, grade beams, columns, beams, walls of water carrying conduits to a point 1'-0"

below normal water level, canopy soffits and fascias, etc. shall be finished as follows:

Forms shall be removed, as specified in SECTION - CONCRETE FORMWORK, and all fins removed, off-sets leveled, damaged places and depressions resulting from the removal of metal ties or other causes shall be carefully pointed with a mortar of sand and cement in the proportion which has been employed for the particular class of concrete treated. The surface film of all such pointed places shall be carefully removed before setting occurs. After the point has set sufficiently to permit it, all exposed surfaces shall be dampened and rubbed with a No. 16 Carborundum stone, to a smooth even plane. Final rubbing shall be done with a No. 30 Carborundum stone, or an abrasive of equal quality, to obtain an entire surface of a smooth texture and uniformity in color. Mortar or grout worked up during rubbing shall be promptly removed by sacking with burlap or other suitable means so that no visible grout film or paste will remain. A cement wash or plaster coat shall not be used. All surfaces shall be finished uniformly smooth and washed clean. The rubbed finish for any area shall be completed in the same day and the limits of a finished area shall be made at natural breaks in the finished surface. If the Contractor does not provide suitable surface finish using Carborundum stones specified above, the Engineer, without additional cost to the Owner, may require the use of a power operated grinding machine or other methods to produce the desired finish.

C. Cementitious Waterproofing and Finish:

As an option to the rubbed finish, as specified herein, all faces (except top surfaces of slab) exposed to view, such as walls, grade beams, columns, beams, canopy soffits and fascias, etc., shall be finished using "Thorseal" coating or approved equal as described in the following paragraphs.

1. General

Forms shall be removed, as specified in SECTION 3.4 - CONCRETE FORMWORK, and all fins removed, off-sets leveled, damaged places and depressions resulting from the removal of metal ties or other causes shall be carefully pointed with a mortar of sand and cement in proportion which has been employed for the particular class of concrete treated. The surface film of all such pointed places shall be carefully removed before setting occurs. After the point has set sufficiently to permit it, all exposed surfaces shall receive the following treatment.

2. Mixing

Thoroseal plaster mix shall be prepared using a solution composed of not less than one part Acryl 60 (approximately two quarts Acryl 60 per bag) and three parts of clean, potable water (for ceilings, use 1 part Acryl 60 to 2-1/2 parts of the water). This solution shall then be added to the Thoroseal plaster mix slowly in sufficient quantity so that the mixture is the consistency of a heavy batter suitable for application by method specified. Color to be selected by the Owner.

3. Application

At Contractor's option, one of the following methods of application shall be selected:

- a. Sprayed-on finish should be applied with plaster-type spray gun, not high pressure paint type. Spray on evenly distributed coat of Thoroseal plaster mix. To spot-fill deep holes, float or brush first coat before starting second spray application.

Thoroseal plaster mix shall be applied on average surfaces in two coats at the rate of 5 to 6 lbs. per square yard for concrete walls, 6 to 9 lbs. per square yard for masonry walls; but sufficient material shall be applied to fill all holes and voids.

- b. Trowel and float finish - Apply light trowel coat of Thoroseal plaster mix over entire surface to be treated. The workman shall make sure the material is firmly pressed into all voids and leveled. Allow this coat to cure thoroughly before applying the regular trowel application. When surface is set so it will not roll or lift, float uniformly using a sponge float.

Thoroseal plaster mix shall be applied on average surfaces at the rate of 4 to 6 lbs. per square yard for concrete walls, 6 to 9 lbs. for masonry walls. If concrete is rough or untrue, 6 to 9 lbs. per square yard may be required, but sufficient material shall be applied to fill and seal all pores and voids. This application will be approximately 1/8" thick. Leveling uneven surfaces will require more material per square yard.

To prevent shadowing of struck or deep masonry joints, or areas of unequal absorption (like some form marks), after key coat has cured for 5 days, apply a light trowel coat of Thoroseal plaster mix with Acryl 60 in the mixing water over the entire surface to be treated. Allow this coat to set thoroughly before applying the regular trowel application as outlined above.

Do not apply when temperatures are 40°F or due to fall below 40°F within 24 hours or to frozen or frost-filled surfaces.

### 3.9 CURING

- A. General - Immediately following placing, all Class A and Class B concrete shall be protected from premature drying, hot and cold temperatures, rain, flowing water and mechanical injury. Maintain above 50°F and in moist condition for at least seven (7) days after placing for normal concrete and three (3) days for high early strength concrete. Comply with "Recommended Practice for Curing Concrete" ACI 308, unless otherwise indicated. Curing compound of satisfactory composition and characteristics may be used except on surfaces to which new concrete is to be bonded or surfaces scheduled to be painted or to receive other coating and provided such compound does not stain or discolor any surface which will be exposed. Cure formed concrete surfaces, including undersides of beams, supported slabs and other similar surfaces by moist curing with forms in place for full curing period or until forms are removed. If forms are removed, continue curing by methods specified above, as applicable.
  
- B. Cold Weather Procedures - Protect concrete work from physical damage or reduced strength, which could be caused by frost, freezing actions, or low temperatures, in compliance with ACI 306, "Cold Weather Concreting", and as herein specified.
  - 1. When air temperature has fallen to or is expected to fall below 40°F, uniformly heat water and aggregates before mixing as required to obtain a concrete mixture temperature of not less than 55°F, and not more than 80°F at point of placement.

2. Do not use frozen materials or materials containing ice, frost or snow. Do not place concrete on frozen subgrade or on subgrade containing frozen materials.
3. Do not use calcium chloride, salt and other materials containing antifreeze agents or chemical accelerators, unless otherwise accepted in mix designs.
4. Contractor shall obtain and keep on the Project site a copy of the current edition of ACI 306, "Recommended Practice for Cold Weather Concreting", for reference during all concrete operations in cold weather.

C. Hot Weather Procedures:

When hot weather conditions exist that would seriously impair the quality and strength of concrete, place concrete in compliance with ACI 305, "Hot Weather Concreting", and as herein specified.

1. Cool ingredients before mixing to maintain concrete temperature at time of placement below 90°F. Mixing water may be chilled, or chopped ice may be used to control the concrete temperature provided the water equivalent of the ice is calculated to the total amount of mixing.
2. Cover reinforcing steel with water-soaked burlap if it becomes too hot, so that the steel temperature will not exceed the ambient air temperature immediately before embedment in concrete.
3. Wet forms thoroughly before placing concrete.
4. Do not use retarding admixtures unless otherwise accepted in mix designs.
5. Contractor shall obtain and keep on the project site a copy of ACI 305R, "Hot Weather Concreting" for reference during all concreting operations in hot weather.

D. Protection from the Sun:

All concrete shall be adequately protected from injurious action of sun in a manner satisfactory to the Engineer.

E. Temperature Control:

During and at the conclusion of the specified curing period, means shall be provided to ensure that the temperature of the air immediately adjacent to the concrete does not fall more than 3°F in any 1 hour nor more than 30°F in any 24 hours.

3.10 NON-SHRINKING GROUT

- A. Where non-shrinking grout is called for on the Plan, it shall be mixed in strict accordance with the manufacturer's directions. It shall be of a type as recommended by the manufacturer for the particular application.

END OF SECTION

## PART 1 – GENERAL

### 1.1 SCOPE

- A. The extent of concrete reinforcement is shown on the drawings and in schedules.
- B. The work includes fabrication and placement of reinforcement for cast-in-place concrete, including bars, welded wire fabric, ties and supports.

### 1.2 QUALITY ASSURANCE

- A. Codes and Standards:

Comply with requirements of the latest edition of the following codes and standards, except as herein modified:

American Welding Society (AWS), AWS D1.4 "Recommended Practices for Welding Reinforcing Steel, Metal Inserts and Connections in Reinforced Concrete Construction".

Concrete Reinforcing Steel Institute (CRSI), "Manual of Standard Practice". (Current Ed.)

American Concrete Institute (ACI), ACI 318 "Building Code Requirements for Reinforced Concrete".

American Concrete Institute (ACI), ACI 350 "Code Requirements for Environmental Engineering Concrete Structures

- B. Submittals:

Mill Certificates; Concrete Reinforcement: Submit steel producer's certificates of mill analysis, tensile and bend tests for reinforcing steel.

Shop Drawings: Reinforcing number, sizes, spacing dimensions, configurations, locations, mark numbers, lap splice lengths, concrete cover and reinforcing supports. Sufficient reinforcing details to permit installation of reinforcing without reference to contract drawings.

### 1.3 DELIVERY, HANDLING AND STORAGE

- A. Deliver reinforcement to the project site bundled, tagged and marked. Use metal tags indicating bar size, lengths, and other information corresponding to markings shown on placement diagrams.
- B. Store concrete reinforcement materials at the site to prevent damage and accumulation of dirt or excessive rust.

### 1.4 MATERIALS

- A. Steel reinforcement shall conform to the "Specification for Deformed Billet Steel Bars for Concrete Reinforcement," ASTM A615, Grade 60.
- B. Wire fabric reinforcement shall conform to the current "Specifications for Welded Steel Wire Fabric for Concrete Reinforcement," ASTM A-185, or "Specifications for Welded Deformed Steel Wire Fabric for Concrete Reinforcement," ASTM A-497.
- C. Supports for Reinforcement shall be bolsters, chairs, spacers and other devices for spacing, supporting and fastening reinforcement in place. Use only wire bar type supports complying with CRSI recommendations, unless otherwise indicated. Do not use wood, brick, and other unacceptable materials.

### 1.5 SPLICES

- A. No splices of bars, except when shown on the Plans, will be permitted without the approval of the Engineer. Minimum lap splice shall be 48 bar diameters unless specifically detailed or noted otherwise on drawings. Splices in adjacent bars shall be staggered a minimum distance equal to the lap splice length. Bars shall be rigidly clamped or wired at all splices in a manner approved by the Engineer. Welding may not be used except with the specific approval of the Engineer. Welding, when approved, shall conform to the AWS D1.4. Welded wire fabric shall be lap spliced a minimum of 2 inches plus the wire spacing at edge laps and end laps.

### 1.6 DETAILING & FABRICATION



- A. Furnish Shop Detail and Field Placing Drawings for all reinforcing steel for approval of the Engineer. Shop Drawings shall include reinforcing, placing plans and details indicating size, location, arrangement, splice locations, bending diagrams, placing sequence, etc. Placing Drawings shall be in sufficient detail to allow field personnel to accurately place reinforcing. Shop and Placing Drawings shall be prepared in accordance with "Manual of Standard Practice for Detailing Reinforced Concrete Structures" ACI 315, current edition. Photographic copies of engineering drawings shall not be used as placing drawings.
- B. Reinforcement bars shall be bent cold to the shapes indicated on the Plans. Fabrication tolerances, fabrication, and detailing of steel reinforcement shall conform to the "Manual of Standard Practice for Detailing Reinforced Concrete Structures" (ACI-315).
- C. Steel reinforcement shall be of the type and size, cut to lengths and bent to shapes as indicated on the Plans. Unless otherwise indicated, hooks, lap splices, embedment lengths, and other details of reinforcement shall be provided as set forth in the ACI Building Code (ACI 318) to develop the full tensile strength of the bar.

#### 1.7 PLACING REINFORCEMENT

- A. All reinforcement at the time concrete is placed shall be free from mud, oil, paint, excessive rust and excessive mill scale or any other coating that would destroy or reduce its bond with the concrete.
- B. All reinforcement shall be secured in place true to lines and grades indicated by use of metal or concrete supports, spacers, or ties as approved by the Engineer. The bars and mesh shall be tightly secured against displacement by ties of annealed wire, or suitable clips at intersections. Wall reinforcement shall be supported and held securely against displacement in its proper position clear of the forms as indicated on the Plans. Placing tolerance shall conform to ACI 318.
- C. Nails shall not be driven into the wall forms to support reinforcement nor shall any other device used for this purpose come in contact with the form on the liquid side of any liquid containing structure. Metal devices used to provide the required clear distances from reinforcing steel to liquid side of concrete surfaces shall be galvanized, or shall be as approved by the Engineer.

- D. The main reinforcement of slabs in contact with the ground shall be supported in its proper position, as indicated on the Plans, by means of precast cement mortar blocks, of approved dimensions, resting on the slabs' subbase. Such precast blocks shall be made of mortar composed of 1 part cement to 2 parts sand and shall have a loop of No. 16 black annealed wire cast into each block. The length of the wire loop shall be sufficient to allow the block to be tied to the reinforcement. Blocks shall be spaced at the intervals required to maintain the reinforcement in its required position in the slab during the placing of the concrete. The slab reinforcement shall not be used to support planking or runways used in placing concrete.
- E. Bending of bars embedded in hardened concrete will not be permitted except when specifically approved by the Engineer for the field condition encountered. Field cutting of bars will only be permitted when specifically approved by the Engineer.
- F. In the case of exposed finish surfaces of floor slabs, galleries, deck slabs, and beams, metal chairs, spacers and other metal accessories necessary to provide the required clear distances and proper alignment and spacing between bars shall be galvanized or shall have plastic protective covering over portions in contact with forms.

#### 1.8 CONCRETE PROTECTION FOR REINFORCEMENT

- A. Steel reinforcement shall be placed and held in position so that the concrete cover, as measured from the surface of the bar shall be the following, except as otherwise shown, on the drawings:
  - 1. Slabs:
    - 1½ inches, in general, top and bottom.
    - 1½ inches at surfaces troweled as floor finish, walkway, or driveway.
    - 2 inches on bottom for slabs over water and where exposed to the weather.
  - 2. Footings:
    - 2 inches at top of footings.
    - 3 inches at bottom, sides, and end of footings.

3. Walls:

2 inches on surfaces against earth.

1½ inches on interior surfaces.

2 inches on interior surfaces contacting water.

4. Beams and Girders in Contact with Water:

2 inch minimum to stirrup steel.

2½ inch minimum to main longitudinal steel.

5. Columns:

2 inches, in general, to main vertical reinforcement.

2½ inches, to main reinforcement on surfaces in contact with water.

6. Beams and Girders: General:

1½ inch minimum to stirrup steel.

2 inches minimum to longitudinal steel.

END OF SECTION

## PART 1 - GENERAL

### 1.1 SECTION INCLUDES

- A. Construction joints, expansion joints, and the placing of waterstops where such are indicated on the plans.
- B. Construction joints shall be of the type indicated on the drawings and shall be located as shown on the plans unless otherwise approved by the Engineer. Contractor shall submit a joint location plan as specified in 204.8 CAST IN PLACE CONCRETE.

### 1.2 WATERSTOPS

- A. Waterstops shall be installed in construction joints as required by the Plans. All waterstops shall be continuous throughout their length.
- B. The waterstops shall be heavy duty polyvinyl waterstop conforming to Corps of Engineers Specification CRD-C-572, latest edition, as manufactured by Serviced Products Division of W.R. Grace and Company; Vinylstops by Sonneborn- Contech; Sealtight Duo-PVC Waterstops by W. R. Meadows, Inc.; Vinylex Corporation; "labyrinth" waterstop, Type B-2 as manufactured by Water Seals, Inc.; or an approved equal of the same type and material and approximately equal in dimensions and weight but not necessarily of exactly the same shape. Waterstops shall be of the size and type designated on the Plans.
- C. "Rib Type" waterstops shall be of ribbed construction with a center bulb, 5" wide, capable of resisting a maximum pressure load of 65 feet of water.
- D. All waterstops shall be installed so that one-half its width will be embedded on one side of the joint and one-half on the other. The Contractor shall employ a method of holding the waterstop in position for the first pour that is satisfactory to the Engineer. The method selected must ensure that the waterstop will be held securely in true vertical or horizontal position and in straight alignment in the joint.
- E. Care shall be exercised to ensure that the waterstop is completely encompassed in good mortar.

F. Preformed Plastic Waterstops:

Preformed Plastic Waterstop, when approved by the Engineer, shall meet or exceed all requirements of Federal Specifications SS-S-00210, "Sealing Compound, Preformed Plastic for Expansion Joints", Type I or Type II. Such plastic waterstop shall be equal to SYNKO-FLEX as manufactured by Synko-Flex Products Company, Houston, Texas, or "CenSeal GS-231" by Concrete Sealants, Inc., New Carlisle, Ohio and shall meet the following requirements:

The plastic waterstop shall be produced from blends of refined hydrocarbon resins and plasticizing compounds reinforced with inert mineral filler, and shall contain no solvents, irritating fumes or obnoxious odors. The plastic waterstop shall not depend on oxidizing, evaporating or chemical action for its adhesive or cohesive strength. It shall be supplied in extruded form of suitable cross-section and of a size to seal the joint areas of concrete sections. The plastic waterstop shall be protected by a suitable removable two-piece wrapper. The two-piece wrapper shall be so designed that one-half may be removed longitudinally without disturbing the other half, to facilitate application of the sealing compound.

1.3 JOINTS IN WATERSTOPS

- A. All waterstops shall be continuous and so joined at all points of contact in the same plane, or at intersections with waterstops in different planes, as to form a complete barrier to the passage of water through any construction or contraction joint.
- B. Joints in the waterstops, whether made for the purpose of continuity in a straight strip or for the purpose of securing a watertight junction between strips in different planes, shall be made by heat welding as hereinafter specified.
- C. Joints in PVC waterstops shall be made by heating the two surfaces to be jointed until the material has softened to the point where it is just short of being fluid and then bringing the two softened surfaces together with a slight rubbing motion followed by firmly pressing them together so that a solid and tight bond is made.

- D. The joints in strips of waterstop made in the above manner shall be such that the entire cross section of the joint shall be dense, homogeneous and free of all porosity. All finished joints shall have a tensile strength of not less than 75 percent of the material of the strip as extruded.
- E. The heating of the surfaces to be joined shall be done by means of an electric splicing iron designed for the specified purpose and controlled by means of a voltage regulator.
- F. In use, the heat of the hot plate shall be so regulated as to prevent too rapid melting and accompanying charring of the waterstop material.
- G. The use of makeshift hot plates will not be permitted nor will other means of heating the strips to be joined be allowed except in a case of emergency, as determined by the Engineer.
- H. The Contractor shall provide such jigs as will assist in making the joints in a proper and workmanlike manner and in holding the strips so that the alignment of jointed strips is correct and angles are true to those required.
- I. Prior to embedment all joints in the waterstop strips will be inspected by the Engineer and any found defective shall be remedied without delay.

#### 1.4 PROTECTION OF WATERSTOP BETWEEN POURS

- A. The Contractor shall take such steps as are necessary to protect exposed waterstops in the interim period between concrete pours. This would include damage from construction equipment, tools and concrete "slobbers". In the event the waterstop receives small amounts of construction debris and/or concrete "slobbers" while concrete is "green", the Contractor shall fully clean waterstop directly following the stripping of formwork and prior to the placement of future reinforcement.

#### 1.5 EXPANSION JOINTS

- A. Expansion joints of the size and type shown on the plans, or specified herein, shall be placed in concrete pavement or structure as shown on the plans.

1. Materials:

a. Preformed Asphalt Fiber Joint Material

Asphalt fiber sheet filler shall consist of preformed strips of inert material impregnated with asphalt. It shall be of the thickness shown on the Plans or indicated in these Specifications.

The sheet filler shall conform to the requirements of AASHTO Specification M-213 with the following additional provisions.

The sheet filler shall be of such character that it will not be deformed by ordinary handling during hot weather nor become hard and brittle in cold weather. It shall be of a tough, resilient, durable material not affected by weathering.

b. Hot Poured Rubberized Tar Joint Sealer

Hot poured rubberized mastic joint sealer shall consist of a mixture of durable, elastic rubber, coal tar pitch and other materials which will form a resilient and adhesive compound capable of effectively sealing concrete joint surfaces against repeated expansion and contraction. The material shall be installed in accordance with the manufacturer's directions. Hot poured tar sealer shall be used for pavement and sidewalk expansion joints.

B. Joint Surface Preparation:

1. Clean joint surfaces immediately before installation of sealant or caulking compound. Remove dirt, insecure coatings, moisture and other substances which would interfere with bond of sealant or caulking compound.
2. For all sealants, do not proceed with installation of sealant over joint surfaces which have been painted, lacquered, waterproofed or treated with water repellent

or other treatment or coating unless a laboratory test for durability (adhesion), in compliance with Paragraph 4.3.9 of FS TT-S-00227, has successfully demonstrated that sealant bond is not impaired by coating or treatment. If laboratory test has not been performed, or shows bond interference, remove coating or treatment from joint surfaces before installing sealant.

3. Etch concrete and masonry joint surfaces to remove excess alkalinity, unless sealant manufacturer's printed instructions indicate that alkalinity does not interfere with sealant bond and performance. Etch with 5% solution of muriatic acid; neutralize with diluted ammonia solution, rinse thoroughly with water and allow to dry before sealant installation.

C. Installation:

1. Comply with sealant manufacturer's printed instructions except where more stringent requirements are shown or specified and except where manufacturer's technical representative directs otherwise.
2. Prime or seal joint surfaces where shown or recommended by sealant manufacturer. Do not allow primer/sealer to spill or migrate onto adjoining surfaces.
3. Employ only proven installation techniques, which will ensure that sealants will be deposited in uniform, continuous ribbons without gaps or air pockets, with complete "wetting" of joint bond surfaces equally on opposite sides. Except as otherwise indicated, fill sealant rabbet to a slightly concave surface, slightly below adjoining surfaces. Where horizontal joints are between a horizontal surface and a vertical surface, fill joint to form a slight cove, so that joint will not trap moisture and dirt.
4. Install sealants to depths as shown or, if not shown, as recommended by sealant manufacturer but within the following general limitations, measured at center (thin) section of bead.
5. For sidewalks, pavements and similar joints sealed with elastomeric sealants and



subject to traffic and other abrasion and indentation exposures, fill joints to a depth equal to 75% of joint width, and neither more than 5/8" deep nor less than 3/8" deep.

6. For normal moving joints sealed with elastomeric sealants, but not subject to traffic, fill joints to a depth equal to 50% of joint width, but neither more than 1/2" deep nor less than 1/4" deep.
7. Do not allow sealants or compounds to overflow or spill onto adjoining surfaces, or to migrate into voids of adjoining surfaces. Use masking tape or other precautionary devices to prevent staining of adjoining surfaces, by either primer/sealer or the sealant.
8. Remove excess and spillage of compounds promptly as the work progresses. Clean adjoining surfaces by whatever means may be necessary to eliminate evidence of spillage, without damage to adjoining surfaces or finishes.
9. Placement of expansion joint material shall fully cover joint area(s) between concrete placements. No gaps or joint material opens which permit fresh concrete to flow to existing concrete surface will be allowed.

D. Cure and Protection

1. Cure sealants in compliance with manufacturer's instructions and recommendations, to obtain high early bond strength, internal cohesive strength and surface durability. Do not cure in a manner which would significantly alter material's modules of elasticity or other characteristics.
2. Installer shall advise Contractor of procedures required for curing and protection of sealants during construction period, so that they will be without deterioration or damage (other than normal wear and weathering) at time of Owner's acceptance.

END OF SECTION

## PART 1 - GENERAL

### 1.1 SCOPE

- A. Work in this section includes all labor, plant and material necessary to furnish and install all concrete formwork required by the project. Concrete formwork shall conform to all requirements of current editions of ACI 301 "Specifications for Structural Concrete for Buildings" and ACI 318 "Building Code Requirements for Reinforced Concrete" and ACI 347 "Recommended Practice for Concrete Formwork" and ACI 350 "Code Requirements for Environmental Engineering Structures" except as modified herein.

## PART 2 - PRODUCTS

### 2.1 MATERIALS

- A. Forms shall be of wood, metal, highly water resistant plywood, or other material approved by the Engineer. Forms for sections greater than 18" thick shall be of wood. Form surfaces shall be smooth and free from irregularities, dents, sags, or holes when used for permanently exposed surfaces. Bolts and rods used for internal ties shall be so arranged that, when the forms are removed, all metal will not be less than two (2) inches from any concrete surface. Wire ties will not be permitted where concrete surface will be exposed to weathering, and discoloration would be objectionable. Exposed concrete shall have approved form liners of Masonite or plywood, or shall be constructed of smooth surfaced plywood.
- B. Corner forms forming 3/4 inch chamfers or as otherwise specified on plans, shall be used on all outside corners that are to be exposed in the finished structure. Chamfer forms shall be of molded plastic or polyvinyl chloride chamfer strips. Use one style of form throughout the project. The type to be used shall be submitted to the Engineer for approval.
- C. Rustication and Score Line Strips shall be a non-absorbent material such as extruded polyvinyl chloride, plastic, fiberglass or metal or they may be milled from a good quality lumber and well sealed to prevent moisture absorption, wood strips may not have protruding splinters which may become embedded in the concrete. Sealing wood shall be accomplished by emersion or brushing on two coats of form coating.

- D. Form Ties for concrete shall have an approved waterstop barrier to prevent seepage of moisture along the ties. The ends of the metal after breaking off shall be minimum of 2 inches from the finished wall face. Submit samples to the Engineer for review. All temporary tie components of tie system shall be removed from placement once placement is completed and prior to backfilling. Non-shrink grout shall be placed at all voids created by ties.
- E. Form Coatings: Provide commercial formulation form-coating compounds that will not bond with, stain, nor adversely affect concrete surfaces, and will not impair subsequent treatment of concrete surfaces requiring bond or adhesion, nor impede the wetting of surfaces to be cured with water or curing compounds.
- F. Cylindrical Columns and Supports: Form round-section members with paper or fiber tubes, constructed of laminated plies using water-resistant type adhesive with wax-impregnated exterior for weather and moisture protection. Provide units with sufficient wall thickness to resist loads imposed by wet concrete without deformation.
- G. Inserts: Provide metal inserts, anchor bolts and other embedded items for anchorage of materials or equipment to concrete construction, not supplied by other trades and as required for the work.
- H. Provide sheet metal reglets formed of the same type and gauge as the flashing metal to be built into the reglets, unless otherwise indicated. Where resilient or elastomeric sheet flashing or bituminous membranes are terminated in reglets, provide reglets of not less than 26 gauge galvanized sheet steel. Fill reglet or cover face opening to prevent intrusion of concrete or debris.
- I. Side forms of footings may be omitted and concrete placed directly against excavation only when requested by Contractor and accepted by Engineer. When forms are omitted, provide additional concrete required beyond the minimum design profiles and dimensions of the footings as indicated to provide minimum concrete coverage for reinforcement. Contractor shall maintain the earth form to proper alignment with no sloughing of material into the minimum design profile shown on the drawings.
- J. Dovetail Anchor Slots at surfaces to receive masonry veneer to be Heckman #100 or equal.

- K. Formwork used for exposed finished concrete surface placements shall be in like new condition and designed to provide flat and true surfaces.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- A. Design and engineering of formwork, shoring and reshoring as well as its construction is the responsibility of the contractor. Design formwork for loads, lateral pressures and allowable stresses outlined in ACI 347R and for design considerations, wind loads, allowable stresses and other applicable requirements of the controlling local Building Code. Where conflicts occur between these two standards, the more stringent requirements shall govern.
- B. Forms shall be built true to line and grade, and be mortartight and sufficiently rigid to prevent displacement or sagging between supports. All formwork and shoring shall be designed for the construction loads to be placed on them, and the design and construction of said forms shall be in accordance with ACI Standard "Recommended Practice for Concrete Formwork" (ACI 347). The structural adequacy of the formwork shall rest with the Contractor. All forms shall be so constructed that they can be removed without hammering or prying against the concrete.
- C. Before concrete placement check the lines and levels of erected formwork. Make corrections and adjustments to ensure proper size and location of concrete members and stability of forming systems.
- D. During concrete placement check formwork and related supports to ensure that forms are not displaced and that completed work will be within specified tolerances.
- E. Provide temporary openings in wall forms, columns forms and at other locations necessary to permit inspection and clean-out.

#### 3.2 EMBEDDED ITEMS

- A. Before placing concrete, care shall be taken to determine that any embedded metal or wood parts are firmly and securely fastened in their correct location as indicated. Use setting drawings, diagrams, instruction and directions provided by suppliers of items

attached thereto. They shall be thoroughly clean and free from coating, rust, scale, oil, or any foreign matter. Embedding of wood in concrete shall be avoided whenever possible, metal being used instead. If wood is allowed, it shall be thoroughly wetted before concrete is placed.

- B. All aluminum embedded items shall be coated with epoxy paint where in contact with concrete.

### 3.3 FORM REMOVAL

- A. Forms shall not be removed without approval of the Engineer. Forms shall not be removed before the minimum times given below, or longer if job control tests indicate the concrete has not attained strength specified below, except when specifically authorized by the Engineer.

Beams and Slabs	14 days or proof of strength requirements met.
-----------------	--

Walls up to 12" Thick and Vertical Surfaces	1 day if minimum daily temperature is above 50°F, 3 days otherwise
--	---

Columns	5 days or proof of strength requirements met.
---------	---

Walls greater than 12" Thick	3 days if minimum daily temperature is above 50°F with proof of strength requirements met, 7 days otherwise.
------------------------------	--

- B. In general, forms or shores for supported slabs and beams shall not be removed until the concrete, so supported, has acquired 70% of its design strength; except where loads other than the dead weight of the concrete are added, the shores shall not be removed until 24 hours after the concrete has obtained 90% of its design strength. Forms shall be removed immediately after expiration of the lapsed times specified above or sooner, if required by the Engineer, where concrete is to receive a rubbed finish.

END OF SECTION

I. CARPENTRY

A. SUMMARY

This Section includes the following:

Framing with dimension lumber.

Wood grounds, nailers, and blocking.

Wood furring.

Sheathing.

Underlayment.

B. SUBMITTALS

1. General: Submit the following in accordance with Conditions of Contract and Division 1 Specification Sections.

a. Product data for the following products:

Underlayment.

Insulating sheathing.

Air infiltration barrier.

Metal framing anchors

Construction adhesives.

b. Material certificates for dimensional lumber specified to comply with minimum allowable unit stresses. Indicate species and grade selected for each use as well as design values approved by the Board of Review of American Lumber Standards Committee.

c. Wood treatment data as follows including chemical treatment manufacturer's instructions for handling, storing, installation, and finishing of treated material:

For each type of preservative treated wood product include certification by treating plant stating type of preservative solution and pressure process used, net amount of preservative retained, and compliance with applicable standards.

For water-borne treated products include statement that moisture content of treated materials was reduced to levels indicated prior to shipment to product site.

Warranty of chemical treatment manufacturer for each type of treatment.

C. QUALITY ASSURANCE

1. Single-Source Responsibility for Engineered Wood Products: Obtain each type of engineered wood products from one source from a single manufacturer.

D. DELIVERY, STORAGE AND HANDLING

1. Delivery and Storage: Keep materials under cover and dry. Protect against exposure to weather and contact with damp or wet surfaces. Stack lumber as well as plywood and other panels; provide for air circulation within and around stacks and under temporary coverings including polyethylene and similar materials.

For lumber and plywood pressure treated with waterborne chemicals, place spacers between each bundle to provide air circulation.

E. LUMBER, GENERAL

1. Lumber Standards: Furnish lumber manufacture red to comply with PS 20 "American Softwood Lumber Standard" and with applicable grading rules of inspection agencies certified by American Lumber Standards Committee's (ALSC) Board of Review.

Inspection Agencies: Inspection agencies and the abbreviations used to referenced them with lumber grades and species include the following:

SPIB – Southern Pine Inspection Bureau.  
WCLIB – West Coast Lumber Inspection Bureau.  
WWPA – Western Wood Products Association.

Grade Stamps: Provide lumber with each piece factory-marked with grade stamp of inspection agency evidencing compliance with grading rule requirements and identifying grading agency, grade, species, moisture content and at time of surfacing, and mill.

2. Nominal sizes are indicated, except as shown by detail dimensions. Provide actual sizes as required by PS 20, for moisture content specified for each use.

Provide dressed lumber, S4S, unless otherwise indicated.

Provide lumber with 15 percent maximum moisture content at a time of dressing and shipment for sizes 2 inches or less in nominal thickness, unless otherwise indicated.

F. DIMENSION LUMBER

1. For light framing provide "Stud," "No. 2," lumber for stud framing (2 to 4 inches thick, 2 to 4 inches wide, 10 feet and shorter) and "Study" or "No. 2" grade for the light framing (2 to 4 inches thick, 2 to 6 inches wide), any species. Number #3 lumber is not acceptable for use as installed work in this project.

2. For structural framing (2 to 4 inches thick, 5 inches and wider), shall be No. 1 or No. 2 grade Southern Pine graded under SPIB rules. Structural framing shall be used for the bearing walls supporting the roof trusses.

G. MISCELLANEOUS LUMBER

Provide lumber for support or attachment of other construction including rooftop equipment curbs and support bases, cant strips, bucks, nailers, blocking, furring, grounds, stripping, and similar members. Fabricate miscellaneous lumber from dimension lumber of sizes indicated and into shapes shown.

Moisture content to be 19 percent maximum for lumber items not specified to receive wood preservative treatment and grade to be; "Standard" grade light-framing-size lumber of any species or board-size lumber as required. "No. 2 Common" grade boards per WCLIB or WWPA rules or "No. 2 Boards" per SPIB rules.

H. CONSTRUCTION PANELS, GENERAL

Construction Panel Standards: Comply with PS 1 "U.S. Product Standard for Construction and Industrial Plywood" for plywood construction panels and, for products not manufactured under PS 1 provisions, with APA PRP-108. Trademark: Furnish construction panels that are each factory-marked with APA trademark evidencing compliance with grade requirements.

I. CONCEALED PERFORMANCE-RATED CONSTRUCTION PANELS

Where construction panels are indicated for the following concealed types of applications, provide APA Performance-Rated Panels complying with the requirements designated under each application for grade designation, span rating, exposure durability classification, edge detail (where applicable), and thickness.

1. Wall Sheathing: APA RATED SHEATHING, Exterior Grade, thickness noted on drawings.
2. Roof Sheathing: APA RATED SHEATHING, Exterior Grade of thickness shown on drawings.
3. Plywood Backing Panels: For mounting electrical or telephone equipment, provide fire-retardant-treated plywood panels with grade designation, APA C-D PLUGGED EXPOSURE 1, in thickness indicated, or, if not otherwise indicated, not less than 15/32 inch.

J. FASTENERS

General: Provide fasteners of size and type indicated that comply with requirements specified in this article for material and manufacture.

Where rough carpentry is exposed to weather, in ground contact. Or in area of high relative humidity, provide fasteners with a hot-dip zinc coating per ASTM A 153 or of AISI Type 304 stainless steel.

Nails, Wire, Brads, and Staples: FS FF-N-105.

Power Driven Fasteners: National Evaluation Report NER-272.



Wood Screws: ANSI B18.61.

Lag Bolts: ANSI B18.2.1.

Bolts: Steel Bolts complying with ASTM A 307, Grade A; with ASTM A 563 hex nuts and where indicated, flat washers.

K. METAL FRAMING ANCHORS

General: Provide metal framing anchors of type, size, metal, and finish indicated that comply with requirements specified including the following:

Current Evaluation/Research Reports: Provide products for which model code evaluation/research reports exist that are acceptable to authorities having jurisdiction and that evidence compliance of metal framing anchors for application indicated with the building code in effect for this Project.

Allowable Design Loads: Provide products for which manufacturer publishes allowable design loads that are determined from empirical data or by rational engineering analysis and that are demonstrated by comprehensive testing performed by a qualified independent testing laboratory.

Galvanized Steel Sheet: Steel sheet zinc-coated by hot-dip process on continuous lines prior to fabrication to comply with ASTM A 525 for Coating Designation G60 and with ASTM A 446, Grade (structural quality); ASTM A 526 (commercial quality); or ASTM A 527 (lock-forming quality); as standard with manufacturer for type of anchor indicated.

L. PRESERVATIVE WOOD TREATMENT BY PRESSURE PRODUCTS

General: Where lumber or plywood is indicated as preservative-treated wood or is specified herein to be treated, comply with applicable requirements of AWPA Standards C2 (Lumber) and C9 (Plywood). Mark each treated item with the AWPB or SPIB Quality Mark Requirements.

Pressure-treat above-ground items with water-borne preservatives to a minimum retention of 0.25 pcf. For interior uses, after treatment, kiln-dry lumber and plywood to a maximum moisture content, respectively, of 19 percent and 15 percent. Treat indicated items and the following:

Wood cants, nailers, curbs, equipment support bases, blocking, stripping, and similar members in connection with roofing, flashing, vapor barriers, and waterproofing.

Wood sills, sleepers, blocking, furring, stripping, and similar concealed members in contact with masonry or concrete.

Wood framing members less than 18 inches above grade.

Wood floor plates installed over concrete slabs directly in contact with earth.

If cut after treatment, coat cut surfaces to comply with AWPA M4. Inspect each piece of lumber or plywood after drying and discard damaged or defective pieces.

M. INSTALLATION, GENERAL

Discard units of material with defects that impair quality of rough carpentry construction and that are too small to use in fabricating rough carpentry with minimum joints or optimum joint arrangement.

Set rough carpentry to required levels and lines, with members plumb and true to line and cut and fitted.

Fit rough carpentry to other construction; scribe and cope as required for accurate fit. Correlate location of furring, nailers, blocking, grounds, and similar supports to allow attachment of other construction.

Securely attach rough carpentry to substrate by anchoring and fastening as indicated.

Countersink nail heads on exposed carpentry work and fill holes.

Use common wire nails, unless otherwise indicated. Use finishing nails for finish work. Select fasteners of size that will not penetrate member where opposite side will be exposed to view or will receive finish materials. Make tight connections between members. Install fasteners without splitting of wood; predrill as required.

N. WOOD GROUNDS, NAILERS, BLOCKING, AND SLEEPERS

Install wood grounds, nailers, blocking, and sleepers where shown and where required for screeding or attachment of other work. Form to shapes as shown and cut as required for true line and level of work to be attached. Coordinate location with other work involved.

Attach substrates as required to support applied loading. Countersink bolts and nuts flush with surfaces, unless otherwise indicated. Build into masonry during installation of masonry work. Where possible, anchor to formwork before concrete placement.

O. WOOD FRAMING, GENERAL

Framing Standard: Comply with N.F.P.A. "Manual for Wood Frame Construction," unless otherwise indicated.

Install framing members of size and spacing indicated.  
Anchor and nail as shown, and to comply with the following:

National Evaluation Report No. NER-272 for pneumatic or mechanical driven staples, P-Nails, and allied fasteners.

Publish requirements of manufacturer of metal framing anchors.

"Recommended Nailing Schedule" of referenced framing standard and with N.F.P.A. "National Design Specification for Wood Construction."

"Table 2304.9.1 – Fastening Schedule," of the International Building Code.

Do not splice structural members between supports.

Firestop concealed spaces of wood framed walls and partitions at each floor level and at the ceiling line of the top story. Where firestops are not automatically provided by the framing system used, use closely fitted wood blocks of nominal 2-inch-thick lumber of the same width as framing members.

P. TERMITE CONTROL

New construction will require the foundation to be pre-treated for termites. If a soil treatment is used, it must be done after compaction. Disturbed areas must be re-treated. Forms and traps must be plastic or metal. A vapor barrier must be installed. Applications must be made within one foot of the foundation under adjoining slabs.

A licensed pest control contractor will be required to provide preventive treatment for termites. Preventative treatment must be provided by a registered pesticide approved by the local building officials. A certificate of pre-treatment will be presented to the Owner as part of the close-out documentation.

II. CAULKING

A. SCOPE

The work covered by this section includes the furnishing of all labor, materials and equipment for all caulking of doors, and for all joint sealants where required. All materials shall be brought on the job in labeled original containers and shall show quality, kind and manufacturer's name.

B. SUBMITTALS

Within sixty (60) days after award of Contract, and before any material are delivered to the job site, submit to the Engineer a complete list of all materials proposed to be furnished and installed under this portion of the work, making the submittal in accordance with the provisions of the General Conditions of these Specifications.

C. MATERIALS

Caulking Compound shall be an elastic waterproof acrylic latex caulking compound. Caulking compound shall be "Sonolac" as manufactured by Sonneborn Building Products Division, Contech, Inc., Minneapolis, Minnesota; "AC-20 Acrylic Latex" by Pecora Corp., Harleysville, Pennsylvania, or approved equal.

Color shall match adjacent work. Deliver caulking compound in manufacturer's original sealed containers.

Sealant: Polysulfide base sealant based on liquid polysulfide polymer manufactured by Thiokol Chemical Corporation, bearing Thiokol Chemical Corporation's "Tested and Approved Seal". Sealant shall be delivered to the job site in sealed containers, each bearing a "Tested and Approved" seal, manufacturer's name, and product designation. Sealant shall be two (2) part polysulfide base sealant conforming to Thiokol's Building Trade Performance Specification as follows:

- Class A (self-leveling) for joints in horizontal surfaces.
- Class B (non-sag) for joints in vertical surfaces.

Type I (Hardness: 20 35 Shore A) for caulking, glazing and sealing vertical surfaces and non traffic bearing horizontal surfaces.

Type II (Hardness: 35 45 Shore A) for caulking and sealing horizontal surfaces subject to foot and light vehicular traffic, or abrasion.

Thiokol shall be "Synthacaulk GC-5" by Pecora Corp., Harleysville, Pennsylvania; "Sonolastic Two Part" by Sonneborn Building Products Division, Contech, Inc., or approved equal. Color shall match the adjacent materials as closely as possible. Colors shall be selected by the Engineer. Where stock colors are not acceptable, special colors shall be prepared and furnished, as approved by the Engineer. Submit cured samples for Engineer's color selection.

Joint Filler: Back-up material for caulking and sealant shall be compressible in nature and shall have a proven record of compatibility with the sealant used. Glassyad, PVC, Butyl or neoprene rod is acceptable -- expanded polyethylene foam, polyurethane foam, and similar gas-expanded foams are not acceptable.

D. INSTALLATION

Location: Polysulfide sealant shall be used for caulking all exterior joints of any type and elsewhere as indicated. Elastic caulking may be used for interior joints not requiring polysulfied sealant. Set all exterior thresholds in caulking. Caulk all joints in masonry walls; between masonry and concrete intersections; around all windows, door frames, louvers, pipes and other penetrations through walls, floors, and ceilings; joints in metal panels, fascias, etc., and all other joints required for a weathertight and/or neat workmanlike installation.

Application: Thoroughly clean all surfaces to be caulked so they will be clean, free from loose dirt, grease, etc., and dry. Surfaces that are to be caulked with polysulfide sealant must first be cleaned with Methyl-Ethyl- Keytone in strict accordance with manufacturer's directions. Install joint filler back-up material to provide proper caulking depth to width ratio according to sealant manufacturer's recommendations. Apply caulking with a gun with proper size nozzle. Use sufficient pressure to fill all voids and joints solidly. Remove excess caulking and leave surfaces neat, even, smooth, and clean; free of sags, blisters and irregularities. Application shall be according to manufacturer's directions and at least three (3) weeks ahead of painting.

E. CLEAN-UP

Upon completion of the work, all caulking and sealing compounds shall be removed from surrounding areas and all joints checked for watertightness and touched up as required. It shall be the Contractor's responsibility to provide a weathertight building.

END OF SECTION

## 205 SUBMITTALS

All submittals shall be accompanied by a transmittal letter and/or cover letter that includes the project name, bid item information/number and submittal number, the contract specification number under which the equipment is being supplied, the Equipment ID number of the equipment being referenced, and the submittal revision number as appropriate.

- 205.1 Contractor shall submit, for each bid item, the manufacturer's instructions and recommendations for installation, for subsequent testing of the units, and for ensuring they are in proper operation. These instructions shall be part of these specifications and binding on the contractor.
- 205.2 Contractor shall include, for each bid item, a work plan acceptable to the Engineer describing the duration and sequence of work. Plan shall be approved prior to commencement of work. All work requiring flow stoppage or removing equipment from service must be scheduled 48 hours in advance with Plant Superintendent. When flow stoppage is required for equipment installation, contractor shall have all necessary materials at the installation site prior to any flow stoppage, and shall proceed with installation of equipment to minimize downtime.
- 205.3 Contractor shall, within 15 days of issuance of Work Order, submit four (4) copies of the following items for review and approval - one (1) copy to be returned to Contractor following review, two (3) copies to be retained by Authority. At the Authority's sole opinion, electronic submittals may be selected:
  - 205.3.1 Product Data and Information: Submit catalog data including rating and descriptive literature of all components and systems for approval by Authority. This shall include items required by specification section 204 Ancillary Equipment and Work.
  - 205.3.2 Itemized list with manufacturer's part numbers, part descriptions and a schedule of values (unit prices) for the equipment and materials proposed for each location. The SOV shall be approved by the authority and will be used as the basis of periodical pay applications by the Contractor.
  - 205.3.3 Shop Drawings: Submit the following shop drawings for approval by Authority:
    - 205.3.3.1 Bill of materials including manufacturers' name and catalog number

205.3.3.2 Outline drawing showing dimensions, arrangement, and identification of components and nameplate schedule for all units

205.3.3.3 Individual schematic control diagrams for each unit.

205.3.3.4 Submittals should clearly identify items intended to be incorporated into the project. Mark or circle items clearly. Line through items or sizes that do not apply. Clearly identify where and what portion of the project the items are intended for use. Minimize "bundling" and separate important long lead time items out to coordinate and facilitate a review. Electrical and controls shall be submittal separately from related equipment.

205.3.4 Manufacturer's start up, certifications and training requirements:

Manufacturer's certification that the equipment is suitable and will perform within specification and manufacturer's design operating parameters for the locations and conditions herein specified. Manufacturer's services shall also include site visits by the Manufacturer's *Technical Representative's* prior to construction, during installation and for start-up, as necessary for an inspection, detailed start up report and Manufacturer's certification of proper installation. Submit the Manufacturer's start-up report(s) and certification(s) of proper installation when they become available to the Engineer and during the week the equipment being put into service. Included final copies of the Manufacturer's Start-up Certificates in the final O&Ms. Start-up report/Manufacturer's Certification should include pertinent start up details, inspection certifications, equipment description, location, project information, complete initial set points, initial operational readings, equipment numbers and date and other pertinent system information for future operations and maintenance.

Training shall also be provided for the equipment and systems installed. Submit a draft training agenda, draft handouts, power point/video and a Manufacturer's Technical Representative's resume for acceptance prior to scheduling the start-up and training. Provide two separate training days, as coordinated with the Plant to accommodate both day and night shifts. The duration of the training should be a minimum of 4 hours per

training day of classroom and field training or more, if recommended by the Manufacturer. A professional video services shall also be provided to cover both complete classroom and field training sessions. Deliverables are to Include; the full training video on DVD with the final O&Ms to the City. Provide additional standard Manufacturer's videos if available on the same DVD in the final O&M.

- 205.3.5 Safety Plan: This submittal will be checked for general conformance with Section 211 Safety requirements and applicable OSHA and local regulations. Notwithstanding, it is the Contractors responsibility to ensure that the plan is comprehensive and in full conformance with all applicable OSHA, federal, state and local regulations.
- 205.3.6 Work Plan: Submit for approval by Authority, the work plan clearly showing the work task sequencing plan and time requirements, including downtime durations. Draft work plans shall be submitted at least a month before any shut down or equipment being removed from service and provide opportunity for applicable coordination of the work. A time extension for additional contract time will not be granted for work not sufficiently planned and coordinated with the City and facility operations. This shall include items required by specification section 204.
- 205.3.7 Submit for approval by Authority, plans and specifications for any concrete pad, support, piping, or other construction modifications from original installation.
- 205.3.8 Warranty Equipment Log: Submit a preliminary draft within 60 calendar days from the issuing of the Notice to Proceed. The blank template form will be provided by the Owners Representative and is available upon request. A Warranty Equipment Log draft spreadsheet shall be built and completed by the Contractor with project equipment information and equipment numbers for review of the Authority. From that point on, the log will be updated each month by the Contractor and be a handout at the Monthly Meetings. Upon project completion, the Warranty Log spread sheet (in Excel) shall be completed with all required information such as equipment name, equipment tag name, equipment numbers, equipment manufacturer, equipment supplier/rep, start-up dates, training dates, O&M dates and other relevant information, then

transmitted to the Owner for their future use in maintaining the equipment. The warranty log will be used as the tool to establish and agree on the equipment warranty period start date(s).

205.3.9 Schedule of values: Submit for approval by the Authority prior to and for the pay application process a proposal bid item based schedule of values with appropriate breakdowns. Contractor will be required to make appropriate and sufficient breakdown based on bid items, areas of work, scope, Subcontractor efforts and such relevant information that the pay application process can be reviewed more easily, as directed by the Authority.

205.4 Operations and Maintenance Manual Submittals and deliverables:

205.4.1 Contractor shall furnish to the Engineer one soft searchable PDF of a preliminary Operation and Maintenance Manual complete for each piece of equipment, item, system and associated control systems furnished and installed for review, similar to and following 250 Submittals requirements above. Preliminary Operation and Maintenance manual submittals must be a completed draft searchable and tabbed version.

205.4.2 Contractor shall furnish and transmit to the Authority **Two (2) bound hard copies of all final O & M manuals, four (4) USB flash drive/memory cards to the City with the final O&M manuals along with final completed submittals and transmit a final electronically of the final O&Ms by email link to the City/Engineer.** All PDF documents shall be searchable within adobe software. An individual O&M package is required for each equipment at each City facility of the project (even if the same equipment is being installed at different plants or facility's). The USB flash drive/memory card shall be formatted in matching O&Ms; searchable pdf, tabbed sections and shall include matching all printed material included in the hard copies. A separate pdf folder shall be created for each **Equipment** numbered piece of equipment, within which all files pertaining to that piece of equipment shall be located.



205.4.3 The following Contractor's pay application percentages apply to the project, which include completed documentation work and deliverables as applicable to each individual equipment on the Contractor's pay application schedule of value items (bid items) and as approved by the Engineer:

- 1) Any equipment payment item reaching 80% complete shall include: preliminary O&M manual submittal to the Engineer for approval with all the specified materials and contents per section 4.1, including the equipment summary sheet completed to extent possible. Submitted and approved preliminary O&Ms processed.
- 2) Any equipment payment item reaching 90% complete shall include: Equipment or system in functional service and Owner training completed.
- 3) Any equipment payment item reaching 100% complete shall include: Equipment fully in service, substantially completed, work scope completed completely and all SCADA - control functions working correctly and properly for an uninterrupted period of two weeks. Within 30 days after the Engineer's approval and Equipment being put in service, Contractor shall furnish to the Engineer the remaining four (4) hard copies of the final operations and maintenance manual and the three searchable tabbed PDF copies on CD/jump drives. Contractor shall submit any missing material for the manual prior to requesting certification of substantial completion on equipment with and requiring O&Ms, training and start-up. The last 10% of payment shall be for those items completed prior to applying for full payment of that item (100% payment).

205.4.4 Format and Contents: Each O & M manual shall include the following:

205.4.4.1 O&M Cover sheet. A standard Manufactures cover sheet may be used (as PDF), but it will need to be updated to include all of the following detail added to the cover sheet(s). See sample sheet included below.

- a) Project Name
- b) City project number and Contractor's contract number
- c) Bid item number and specification number

- d) Facility location
- e) Equipment name
- f) City's equipment number
- g) Manufacture's name
- h) Date of document (or installation)

**{MANUFACTURER INFORMATION (Logo, etc.)}**

**{Name} OPERATION AND MAINTENANCE MANUAL**

**{Description of what is Included in O&M Manual}**

**To:**

Project Contractor Name  
Address  
City, State Zip  
Phone Number

**Project Name and Location  
PO#: (if applicable)**

**Manufacture Project Number (if applicable)**

**Submittal for fulfillment of specification section:  
{Specification Section and Short Description}**

**Equipment List (if applicable)**

<b>Application</b>	<b>Type</b>	<b>Number</b>	<b>Equipment Tag #</b>

**Represented Locally By:**

Supplier Name  
Address  
City, State Zip  
Phone Number

**Prepared By:**

Manufacturer  
Address  
City, State Zip  
Phone Number

**Date**

205.4.4.2 One copy of a completed **EQUIPMENT NAMEPLATE AND**

**SUMMARY DATA** form as the first page with the O&M. And directly behind that sheet a single sheet with generic site plan showing where the equipment was installed, with call outs to the site name, building/facility name and relative installation location information.

- 205.4.4.3 One copy of the equipment Start-Up report, Inspection form and Manufacture's certification of proper installation as applicable. Report should be and include information from startup and being put into service by the Manufacturer's Technical Representative. Documents should also include all initial set points, settings and data that is adjustable for future reference.
- 205.4.4.4 Index for pages, sections or tags as required.
- 205.4.4.5 One copy of the manufacturer's operating and maintenance instructions. Operating instructions include equipment start-up, normal operation, shutdown, emergency operation and troubleshooting. Maintenance instructions include equipment installation, calibration and adjustment, preventive and repair maintenance, troubleshooting, parts list and recommended spare parts.
- 205.4.4.6 List of electrical relay settings and control and alarm contact settings or any other initial set points or operational levels/elevations. Provide plan sheet(s) as applicable.
- 205.4.4.7 Electrical interconnection wiring diagram for equipment furnished including all control and lighting systems
- 205.4.4.8 Record drawings showing as-built schematic control diagrams for each unit and one-line diagrams.
- 205.4.4.9 Cross-references where required between the appropriate sections of the Contractor's O&M manual and the manufacturers' manuals.
- 205.4.4.10 The Contractor shall provide all required warranty paperwork completed and filled in by the Contractor for the City's use. The completed warranty paperwork shall be specifically transmitted to the Plant Superintendent at time

of start-up equipment being put into service and a separate copy be provided within the Final O&Ms also transmitted to the City. The warranty document shall specifically name the City/Authority.

205.5. Equipment Nameplate Information – Contractor shall, upon startup of each piece of equipment, complete the form, titled **EQUIPMENT NAMEPLATE AND SUMMARY DATA**, found at the end of this section, and shall include the completed form in the front of that equipment's respective O & M manual. The form shall be included with each O & M manual copy submitted. Equipment ID nameplate requirements are found in specification section 204.3.6 of these specifications. Equipment tagging shall be installed prior to start up, training and equipment substantial completion.

205.6 Submittals shall be sent to the following address:

Holloway, Updike and Bellen, Inc.

2001 N Willow Ave.

Broken Arrow, OK 74012

(918) 251-0717



206 MONTHLY PROGRESS REPORTS AND PROGRESS MEETINGS

- 206.1 The Contractor shall submit monthly written project progress reports detailing the project's progress to date, problems encountered or anticipated which impact project schedule, and plans for the next two weeks' work.
- 206.2 Project progress reports shall be due as agreed upon during pre-work meeting.
- 206.3 Monthly progress meetings shall be scheduled on a weekday mutually agreeable to the Authority and the Contractor and shall be specified at the pre-work conference. The Contractor shall run the Monthly Meetings for the duration of the project and provide a meeting agenda including work completed, work planned, project, updated project schedule and other pertinent project status information.
- 206.4 The contractor shall submit a work progress and planned completion schedule for each bid item at the monthly progress meeting. The pre-work conference will constitute the first monthly progress meeting.
- 206.5 The Contractor shall maintain, update and submit an Equipment Log at each monthly meeting that lists each piece of equipment by Equipment ID number and lists Startup Date, Warranty Start Date and O&M Manual Submittal Date, among other project details. The spread sheet document shall be a shared document and submitted to the City at the end of the project for City's future use. A sample Equipment log is available upon request.

207 SECURITY

- 207.1 Each project site where work is to be performed under this Contract is a secured site. The Contractor shall be responsible for security as described in this section.
- 207.2 Site Access: The Contractor shall respect all existing security measures at each project site, and shall implement the following measures to apply to all work performed under this Contract. Coordination for Plant access and City of Tulsa security pass access will be required.
  - 207.2.1 Work at both Northside and Southside shall be restricted to the hours defined by TMUA GC-19 unless otherwise authorized by the Plant Superintendent.
- 207.3 Common Requirements
  - 207.3.1 Identification Badges: An Identification Badge, issued by the City of Tulsa Security Office, is required for the following people:

- The driver of each vehicle that will be entering the facility multiple times or on a regular basis.

- Sub-contractors and foremen that will be supervising other workers.

The Identification Badge also functions as an Access Card to allow access through the front gate of the facility. One year is the maximum time that an Access Card is active.

207.3.2 Contractor will coordinate with the Engineer to request Identification Badges. Application for an Identification Badge will require a background investigation. Each person that is applying for an Identification Badge will need to complete the following two (2) forms:

- City of Tulsa Access Card / Identification Card Request Form
- City of Tulsa Security, Background and Prescreen Investigation Form

A current soft copy of the forms can be obtained from the Engineer.

207.3.3 The Contractor will send the completed forms as required. Approved individuals will coordinate with the City of Tulsa Security Office to complete the process and obtain their Identification Badge.

207.3.4 The Contractor will coordinate with the Engineer to request reactivation of Access Cards. Reactivation may require re-application and additional background investigation.

207.4 Contractor shall maintain a log book listing as a minimum the names of all persons admitted to each secured site by the Contractor, the purpose of the site visit, the dates and times of arrival at the site, entry to the secured site, and departure from the site.

207.5 Contractor and Authority acknowledge that Contractor shall not solely be responsible for all secured access to the site, that City personnel will have access and will be performing their regular duties pertaining to the operation and maintenance of the site facilities, and that security at the site shall require the cooperation of all persons authorized to access the site for the performance of their work. To the extent the Contractor is responsible for and has control of secured access, Contractor shall restrict site access to only persons essential to the performance or inspection of the work being performed under this Contract.



- 207.6 Contractor shall provide Engineer twenty-four (24) hours advance notification of any delivery of equipment or materials to the site, and shall make arrangements with Engineer to provide for inspection of such delivery.
- 207.7 Any observation by the Contractor of activity at or associated with the project site that Contractor observes and considers to be unusual or suspicious in nature, or that Contractor believes poses a threat to the integrity or welfare of the project site or associated facilities, shall be duly noted at the time of the observation in the log book identified in item B above. Any such observation shall be immediately reported to the Engineer.
- 207.8 No statement pertaining to security in these Specifications shall constitute a contract between Contractor and Authority for the performance of security services.

208 SAFETY

- 208.1 Contractor shall be responsible for performing all work under this contract in a safe manner and in compliance with all applicable local, state, and federal safety and health regulations. All of the following requirements shall apply:
- 208.2 Contractor shall submit a site safety plan prior to start of work. Contractor's attention is directed to safety regulations applicable to the work under this contract, which include but are not limited to the following:
  - 208.2.1 OSHA Standards 29CFR1910.147, the control of hazardous energy (Lockout/Tagout)
  - 208.2.2 Fire Prevention and Protection: The Contractor shall take all necessary measures to prevent fire, and shall provide satisfactory firefighting means at the location of work.
  - 208.2.3 Condition of Equipment and Materials: All equipment, tools, and appliances, and materials used in connection with the project shall be handled and operated only when they are in safe operating condition and in accordance with a standard safety procedure.
  - 208.2.4 Confined Space Entry: Contractor shall determine if any work areas in this contract are considered permit spaces for entry, as defined in OSHA regulations, and shall perform all work so determined in accordance with all applicable state and federal labor, safety, and health regulations. The Contractor shall transmit with each pay application all the months copies of the Contractors confined space permits to the City and at the end of

the project with final pay application submittal a complete package of a copy of all the project's Contactor confined space permits.

- 208.2.5 Combustible - Explosive Atmospheres: Contractor shall determine if any work areas in this contract are considered combustible and explosive spaces for entry, as defined in OSHA regulations, and shall perform all work and employ equipment in accordance with all applicable state and federal labor, safety, and health regulations.

209 PROTECTION OF PROPERTY

- 209.1 The protection of City, State and Government equipment, fences, gates, signs, and other City property is of prime importance, and if damaged, destroyed or removed, they shall be repaired, replaced, or paid for by the Contractor. Disturbance to this property must first be approved by the agency which controls it.
- 209.2 No valve or other control on any utility main or building service line shall be operated for any purpose by the Contractor.
- 209.3 At places where the Contractor's operations are adjacent to, or crossing, the plane of railway, telegraph, telephone, electric, and gas lines, or water lines, sanitary sewers, and storm sewers, damage to which might result in expense, loss or inconvenience, work shall not be commenced until all arrangements necessary for the protection thereof have been made. Contractor shall notify the Notification Center of Oklahoma One-Call System, Inc., of any excavation or demolition prior to the commencement of such work. Notification shall be made no sooner than then (10) days nor later than forty-eight (48) hours prior to start of work, excluding Saturdays, Sundays, and legal holidays.
- 209.4 The Authority has attempted to locate all storm sewers, culverts, buried telephone or electrical conduits, sanitary sewers, water mains, and gas mains that might interfere with the construction of this project. The Contractor shall cooperate with the owners of any underground or overhead utility lines in their removal and rearrangement operations in order that these operations may progress in a reasonable manner and duplication or rearrangement work may be reduced to a minimum, and that services rendered by those parties will not be unnecessarily interrupted.
- 209.5 It shall be the responsibility of the contractor to follow all rules and regulations set forth by the Oklahoma Department of Environmental Quality with regards to storm water runoff associated with construction activities involving the disturbance of

land. The contractor shall review the regulations and determine if a DEQ storm water discharge permit is required. If a permit is required, it is the responsibility of the contractor to apply for and obtain the permit prior to disturbance of soil. If a permit is not required, the contractor shall still take all necessary action to comply with DEQ rules.

209.6 In the event the contractor in any way fails to comply with the requirement of protecting, repairing, and restoring of any utility or utility service, the Engineer may, upon forty-eight (48) hours' notice, proceed to protect, repair, rebuild or otherwise restore such utility or utility service as may be deemed necessary, and the cost thereof will be deducted from any money due or which may become due the contractor pursuant to the terms of his contract.

## 210 PROTECTION OF MATERIALS

210.1 All materials and equipment delivered to the work site shall be adequately housed and protected against damage or deterioration as required by the equipment manufacturer. The Contractor shall keep his storage yard(s) in good order, arrange his materials neatly, and protect them from damage.

## 211 REFERENCES TO OTHER SPECIFICATIONS

211.1 Where a referenced American Society for Testing Materials (ASTM), National Electric Code (NEC), National Electrical Manufacturers Association (NEMA), American National Standards Institute (ANSI), Institute of Electrical and Electronics Engineers (IEEE), or other agency designated specification is specified for a material, component, or device, that designated specification shall be the current revision, either tentative or adopted. If a referenced specification is in disagreement with these specifications, the Tulsa Metropolitan Utility Authority specifications shall govern.

## 212 CLEAN-UP

212.1 Immediately upon completion of the work at each site in the contract, the Contractor shall remove all excess materials, equipment, tools, and debris, and restore the site to a condition and in a manner satisfactory to the Engineer.

## 213 PLACING WORK IN SERVICE

213.1 If desired by the Authority, portions of the work may be returned to service when completed, and the Contractor shall give prior access to the work for this purpose, but such use and operation shall not constitute an acceptance of the work. Any

such return to service shall comply with Section GC-38 of the General Conditions of these Contract Documents and Specifications.

213.2 Warranty: All equipment and work shall have a one (1) year factory warranty from date of acceptance, which shall include all materials and labor unless more stringently specifically note elsewhere otherwise.

214 PAYMENT

214.1 Contractor shall submit a schedule of values for all major items of work as a basis for each partial payment. Payments will be made in accordance with section GC-29 of the General Conditions of these Contract Documents and Specifications. Contractor shall submit the SOV in sufficient time prior to the first pay application for the Engineer's review. Contractor should anticipate a typical submittal review durations for the projects SOV review.

214.2 Contractor's attention is directed to the Sales Tax Exemption Document in these Contract Documents and Specifications. Contractor shall have the option of instructing vendors to directly bill the Authority for materials the Contractor purchases while performing work under the terms of this Contract.

END OF SECTION

