

\* The City of Tulsa is required to perform reduced lead and copper monitoring. Fifty lead and copper tap water samples are collected annually between June 1st and September 30th.

\* Regulatory Action Levels (ALs) that require action from the Public Water Supply are based on 90th percentile values. The AL for lead is 15 ug/L and 1.3 mg/L for copper.

\* The 90th percentile concentration for tap water samples collected during the 2024 monitoring period is 1.67 ug/L for lead and 0.312 mg/L for copper.

\* All results indicated by BDL were below the lowest concentration the laboratory can detect.

Rank	Site ID	Address	Sample Date	Lead (µg/L)	
50	LC148	1855 S 138th East Ave	7/24/2024	32.9	
49	LC183	3125 S Columbia Circle	7/18/2024	10.8	
48	LC044	15112 E. 36th St.	7/16/2024	3.30	
47	LC244	6943 S 32nd West Ave	8/6/2024	2.04	
46	LC251	7504 S TRENTON AVE	7/30/2024	1.70	
45	LC129	1404 S 110th East Pl	7/24/2024	1.67	90th Percentile
44	LC114	13020 E 46th ST	7/16/2024	1.60	
43	LC234	6565 S FULTON AVE	8/7/2024	1.59	
42	LC240	6810 S 28th West Ave	7/31/2024	1.020	
41	LC272	8525 E 77th PL	7/31/2024	0.942	
40	LC022	6714 S. 112th E. Ave	7/23/2024	0.932	
39	LC284	9014 S 77th East Pl	7/30/2024	0.926	
38	LC101	12118 E 29th PL	8/1/2024	0.865	
37	LC265	7803 S IRVINGTON AVE	7/30/2024	0.774	
36	LC212	4918 S COLUMBIA PL	7/24/2024	0.682	
35	LC152	2514 W 68th PL	7/23/2024	0.672	
34	LC103	12209 E 30th ST	7/25/2024	0.670	
33	LC241	6824 S 30th West Ave	8/1/2024	0.642	
32	LC165	2806 S 122nd East Ave	7/25/2024	0.637	
31	LC217	5219 E 90th ST	7/16/2024	0.603	
30	LC199	4029 S 118th East Ave	7/24/2024	0.584	
29	LC133	14262 E 37th PL	7/24/2024	0.532	
28	LC231	6322 S 90th East Ave	7/31/2024	0.524	
27	LC255	7704 S 30th West Ave	7/30/2024	0.501	
26	LC113	13003 E 45th St	7/17/2024	BDL(0.500)	
25	LC088	10123 S GRANITE AVE	7/24/2024	BDL(0.500)	
24	LC157	2702 S 137th East Ave	7/18/2024	BDL(0.500)	
23	LC186	3404 E 58th PL	7/17/2024	BDL(0.500)	
22	LC230	6319 S 90th East Ave	8/6/2024	BDL(0.500)	
21	LC115	13104 E 45th ST	7/23/2024	BDL(0.500)	
20	LC293	9342 S GARY AVE	8/7/2024	BDL(0.500)	
19	LC267	7912 E 15th PL	7/18/2024	BDL(0.500)	
18	LC156	2634 W 68th ST	7/24/2024	BDL(0.500)	
17	LC064	7529 S. Trenton	7/25/2024	BDL(0.500)	
16	LC261	7740 E 87th ST	7/31/2024	BDL(0.500)	
15	LC174	2948 S 121st East Ave	7/16/2024	BDL(0.500)	
14	LC037	1928 W. 61st Pl.	7/17/2024	BDL(0.500)	
13	LC295	9838 E 96th PL	7/18/2024	BDL(0.500)	
12	LC028	9725 S. 95th E. Ave.	7/17/2024	BDL(0.500)	
11	LC163	275 S 163rd East Ave	7/25/2024	BDL(0.500)	
10	LC041	8735 S. 79th E. Ave	8/6/2024	BDL(0.500)	
9	LC137	1515 E 19th ST	7/17/2024	BDL(0.500)	
8	LC281	8921 E 86th ST	7/18/2024	BDL(0.500)	
7	LC130	1407 S 111th East Ave	7/23/2024	BDL(0.500)	
6	LC283	8937 S 77th East Ave	7/31/2024	BDL(0.500)	
5	LC282	8929 S 77th East Ave	8/1/2024	BDL(0.500)	
4	LC106	12313 E 27th PL	8/6/2024	BDL(0.500)	
3	LC203	4329 S 28th West Ave	8/8/2024	BDL(0.500)	
2	LC268	7916 E 15th PL	7/17/2024	BDL(0.500)	
1	LC010	1543 S. Gillette	8/6/2024	BDL(0.500)	

\* The City of Tulsa is required to perform reduced lead and copper monitoring. Fifty lead and copper tap water samples are collected annually between June 1st and September 30th.

\* Regulatory Action Levels (ALs) that require action from the Public Water Supply are based on 90th percentile values. The AL for lead is 15 ug/L and 1.3 mg/L for copper.

\* The 90th percentile concentration for tap water samples collected during the 2024 monitoring period is 1.67 ug/L for lead and 0.312 mg/L for copper.

\* All results indicated by BDL were below the lowest concentration the laboratory can detect.

Rank	Site ID	Address	Sample Date	Copper (µg/L)	
50	LC217	5219 E 90th ST	7/16/2024	0.550	
49	LC133	14262 E 37th PL	7/24/2024	0.502	
48	LC044	15112 E. 36th St.	7/16/2024	0.496	
47	LC113	13003 E 45th St	7/17/2024	0.463	
46	LC272	8525 E 77th PL	7/31/2024	0.388	
45	LC088	10123 S GRANITE AVE	7/24/2024	0.312	90th Percentile
44	LC157	2702 S 137th East Ave	7/18/2024	0.301	
43	LC186	3404 E 58th PL	7/17/2024	0.300	
42	LC165	2806 S 122nd East Ave	7/25/2024	0.298	
41	LC101	12118 E 29th PL	8/1/2024	0.291	
40	LC230	6319 S 90th East Ave	8/6/2024	0.276	
39	LC183	3125 S Columbia Circle	7/18/2024	0.271	
38	LC103	12209 E 30th ST	7/25/2024	0.270	
37	LC115	13104 E 45th ST	7/23/2024	0.240	
36	LC293	9342 S GARY AVE	8/7/2024	0.216	
35	LC241	6824 S 30th West Ave	8/1/2024	0.209	
34	LC284	9014 S 77th East Pl	7/30/2024	0.207	
33	LC267	7912 E 15th PL	7/18/2024	0.205	
32	LC114	13020 E 46th ST	7/16/2024	0.204	
31	LC199	4029 S 118th East Ave	7/24/2024	0.199	
30	LC022	6714 S. 112th E. Ave	7/23/2024	0.174	
29	LC265	7803 S IRVINGTON AVE	7/30/2024	0.168	
28	LC244	6943 S 32nd West Ave	8/6/2024	0.164	
27	LC156	2634 W 68th ST	7/24/2024	0.160	
26	LC064	7529 S. Trenton	7/25/2024	0.156	
25	LC129	1404 S 110th East Pl	7/24/2024	0.156	
24	LC234	6565 S FULTON AVE	8/7/2024	0.155	
23	LC231	6322 S 90th East Ave	7/31/2024	0.149	
22	LC261	7740 E 87th ST	7/31/2024	0.144	
21	LC174	2948 S 121st East Ave	7/16/2024	0.143	
20	LC037	1928 W. 61st PL.	7/17/2024	0.129	
19	LC295	9838 E 96th PL	7/18/2024	0.127	
18	LC251	7504 S TRENTON AVE	7/30/2024	0.127	
17	LC028	9725 S. 95th E. Ave.	7/17/2024	0.113	
16	LC148	1855 S 138th East Ave	7/24/2024	0.102	
15	LC163	275 S 163rd East Ave	7/25/2024	0.101	
14	LC240	6810 S 28th West Ave	7/31/2024	0.101	
13	LC212	4918 S COLUMBIA PL	7/24/2024	0.101	
12	LC041	8735 S. 79th E. Ave	8/6/2024	0.0991	
11	LC152	2514 W 68th PL	7/23/2024	0.0991	
10	LC137	1515 E 19th ST	7/17/2024	0.0964	
9	LC281	8921 E 86th ST	7/18/2024	0.0871	
8	LC255	7704 S 30th West Ave	7/30/2024	0.0867	
7	LC130	1407 S 111th East Ave	7/23/2024	0.0724	
6	LC283	8937 S 77th East Ave	7/31/2024	0.0609	
5	LC282	8929 S 77th East Ave	8/1/2024	0.0592	
4	LC106	12313 E 27th PL	8/6/2024	0.0585	
3	LC203	4329 S 28th West Ave	8/8/2024	0.0514	
2	LC268	7916 E 15th PL	7/17/2024	0.0460	
1	LC010	1543 S. Gillette	8/6/2024	0.0174	