



PUBLIC WORKS
Engineering

DATE:
July 7, 2025

**ADDENDUM NO. 3
TO
PROJECT NO. 144017-AA
ARTERIAL STREET REHABILITATION
31st STREET FROM YALE AVE. TO SHERIDAN RD.**

This Addendum No. 3 consisting of two (2) items, submitted by City of Tulsa is hereby made a part of the Contract Documents to the same extent as though it were originally included therein and shall supersede anything contained in the Plans and Specifications with which it might conflict. **All addenda to the contract documents should be denoted on the last page of the Proposal in the space provided.**

This Addendum No. 3 consists of the following:

1. Regarding Item No. 85: Is the contractor responsible for providing & installing new cyberlocks & cyberkeys in the existing traffic signal cabinet?
 - a. If the cabinet does not have a Cyberlock prior to the contractor starting work on the intersection, then the contractor will be required to replace the existing lock with a Cyberlock. If the contractor doesn't already have Cyberkeys, then they will need to acquire them and have them programmed at Traffic Operations so they can open and close the cabinet after the Cyberlock is installed.
2. Pavement Removal and Replacement for Water, Sanitary, and Stormwater Main Installations - This pay item supersedes City of Tulsa Standard Specification section 329.6, with respect to saw cutting and dowels, and includes the following (these items shall not be paid separately):
 - A. Saw cutting
 - B. Dowels
 - C. Disposal of broken pavement
 - D. Temporary surfaces
 - E. Associated excavation
 - F. Preparation of subgrade
 - G. Forms or reinforcing
 - H. Removal or replacement of gravel
 - I. Additional saw cutting or replacement of pavement damaged by the Contractor

PUBLIC WORKS
Engineering

J. Joint sealer, tack coats, or edge sealing


This pay item does not include the following which shall be paid separately in accordance with City Standard Specifications, Details and Drawings:

1. Curb and gutter

All other provisions of the Plans and Specifications shall remain in full force and effect.

CITY OF TULSA

CITY OF TULSA



per Paul D. Zachary, P.E.
Deputy Director

HAS/DH/JR/kt



PUBLIC WORKS
Engineering

DATE:
July 7, 2025

TO:
Plan Holders
Contractors

FROM:
Jenna Richardson
918-596-9637
jennarichardson@cityoftulsa.org

EMAIL TRANSMITTAL

ADDENDUM NO. 3

**PROJECT NO. 144017-AA ARTERIAL STREET REHABILITATION
FOR 31ST STREET YALE AVENUE TO SHERIDAN ROAD**

Number of pages: **3**

All addenda to the contract documents should be denoted on the
last page of the Proposal in the space provided.

Thank you,
Contract Administration