

METER CAN PER
CITY OF TULSA
STANDARD DETAILS
PER 505 A OR 505 B

VIEGA PEX PRESS ADAPTER
ZERO LEAD
MODEL 2893ZL

SINGLE VALVE TYPE METER SETTER
WITH LOCKWINGS AND 18" EXTENSION;
FORD 70 (V OR VB) SERIES,
MUELLER H24104 OR B24104,
McDONALD 60 SERIES. (OPTIONAL)

NOTE:
LEAD SOLDER IS NOT PERMITTED
ON METER SETTER ASSEMBLY.

VIEGA PEX PRESS ADAPTER
ZERO LEAD
MODEL 2892ZL

UNDISTURBED EARTH OR 4" GRAVEL

*VIEGA PEX PRESS ADAPTOR
SMART CONNECT FEATURE
MODEL 2813PZL
OR PRESS COUPLING
MODEL 2815ZL

18 GAUGE INSULATED WIRE
WILL NEED TO BE WRAPPED
AROUND PEX PIPE.

UPONOR AQUA
PEX BLUE
5306 OR VIEGA
PUREFLOW
PEX BLUE 5306

VIEGA PEX PRESS ADAPTER
ZERO LEAD
MODEL 2892ZL

CORPORATION STOP
MUELLER H15000,
FORD F600,
HAYS 5200,
JONES J1500 OR
JONES J3401,
McDONALD 4701.
FLARED ONLY


VIEGA PEX PRESS
ELBOW 90°
ZERO LEAD
MODEL 2816ZL
(OPTIONAL)

VIEGA PEX PRESS ADAPTER
ZERO LEAD
MODEL 2812ZL OR 2811ZL
FOR USE WITH METER SETTER


*FOR CONNECTION TO EXISTING
COPPER CUSTOMER SERVICE.

SERVICE CLAMP

TAP ON D.I.P. - FORD STYLE F202, MUELLER H10500 SERIES
TAP ON P.V.C. - FORD STYLE S90, MUELLER H13400 SERIES, POWERSEAL 3405
TAP ON HDPE - POLY-CAM 415 OR 575



45° TAP



SIDE TAP

NOTE:

1. SERV. CLAMP REQUIRED FOR ALL SIZES
PVC, AND FOR 6" AND SMALLER IRON.
FOR 8" AND LARGER IRON, TAP DIRECTLY.
2. TAP AT ANGLE NECESSARY TO PROVIDE
30° OF COVER OVER THE SERVICE LINE.
3. LOCATE PEX LINE AT LEAST 50 FEET
HORIZONTALLY FROM ANY GASOLINE
STORAGE TANK AND LINES.
4. SHALL BE 1 1/4" MINIMUM.

UPONOR AQUA PEX BLUE 5306 OR
VIEGA PUREFLOW PEX BLUE 5306

STANDARD METER SETTINGS FOR
1" WATER SERVICE

CITY OF TULSA, OKLAHOMA

DRAWN BY: D.J.N.

CHECKED BY:

DATE: AUGUST 2025

APPROVED

T. J. N.

NOT TO SCALE

STANDARD NO. 502A