



PUBLIC WORKS
Engineering

DATE:
January 20, 2026

TO:
Plan Holders
Contractors

FROM:
Jenna Richardson
918-596-9637
jennarichardson@cityoftulsa.org

EMAIL TRANSMITTAL

ADDENDUM NO. 2

**PROJECT NO. 144754, TMUA-W 17-08, & SW 11180
NON-ARTERIAL STREET MAINTENANCE & WATERLINE REPLACEMENT
AT VARIOUS LOCATIONS IN MAINTENANCE ZONE 7054**

Number of pages:

All addenda to the contract documents should be denoted on the
last page of the Proposal in the space provided.

Thank you,
Contract Administration



PUBLIC WORKS
Engineering

DATE:
January 20, 2026

**ADDENDUM NO. 2
TO
PROJECT NO. 144754, TMUA-W 17-08, & SW 11180
NON-ARTERIAL STREET MAINTENANCE & WATERLINE REPLACEMENT
AT VARIOUS LOCATIONS IN MAINTENANCE ZONE 7054**

This Addendum No. 2 consisting of one (1) clarification, submitted by City of Tulsa is hereby made a part of the Contract Documents to the same extent as though it were originally included therein and shall supersede anything contained in the Plans and Specifications with which it might conflict. **All addenda to the contract documents should be denoted on the last page of the Proposal in the space provided.**

This Addendum No. 2 consists of the following:

1. Please clarify how existing waterlines are to be abandoned.
 - a. Spec 333.4 Plug and Abandon Water or Force Mains: Pressurized mains to be abandoned shall have both ends cut and plugged with a minimum length of 2' of lean concrete or nonshrink grout. All water or force mains to be abandoned shall also be filled to 100% of the abandoned pipe volume. Fill material may be either cellular concrete or flowable fill as approved by the Engineer. Standing water, especially in low spots, must be removed prior to using cellular concrete material. Quantity provided was calculated based upon the total length of abandoned line.

All other provisions of the Plans and Specifications shall remain in full force and effect.

CITY OF TULSA

A handwritten signature in blue ink, appearing to read "Paul D. Zachary".

Paul D. Zachary, P.E.
Deputy Director

A handwritten signature in blue ink, appearing to read "HAS/DDH/JR".
HAS/DDH/JR