

* The City of Tulsa is required to perform reduced lead and copper monitoring. Fifty lead and copper tap water samples are collected annually between June 1st and September 30th.

* Regulatory Action Levels (ALs) that require action from the Public Water Supply are based on 90th percentile values. The AL for lead is 15 ug/L and 1.3 mg/L for copper.

* The 90th percentile concentration for tap water samples collected during the 2026 monitoring period is 1.33 ug/L for lead and 0.259 mg/L for copper.

* All results indicated BDL were below the lowest concentration the laboratory can detect.

Rank	LC-CODE	ADDRESS	Sample Date	Lead (µg/L)	
1	LC041	8735 S. 79th E. Ave	7/7/2026	BDL (0.500)	
2	LC028	9725 S. 95th E. Ave	7/8/2026	BDL (0.500)	
3	LC130	1407 S 111th East Ave	7/8/2026	BDL (0.500)	
4	LC064	7529 S. Trenton	7/9/2026	BDL (0.500)	
5	LC088	10123 S GRANITE AVE	7/9/2026	BDL (0.500)	
6	LC166	2806 W 62nd ST	7/9/2026	BDL (0.500)	
7	LC180	3068 W 77th ST	7/9/2026	BDL (0.500)	
8	LC037	1928 W. 61st Pl.	7/14/2026	BDL (0.500)	
9	LC084	8634 S. 86th E. Ave	7/14/2026	BDL (0.500)	
10	LC164	2803 W 64th ST	7/15/2026	BDL (0.500)	
11	LC091	10603 E 100th ST	7/16/2026	BDL (0.500)	
12	LC109	1243 E 24th ST	7/16/2026	BDL (0.500)	
13	LC236	6710 S 29th West Ave	7/21/2026	BDL (0.500)	
14	LC285	9047 E 95th ST	7/21/2026	BDL (0.500)	
15	LC287	9125 S FLORENCE PL	7/21/2026	BDL (0.500)	
16	LC262	7742 S ERIE AVE	7/22/2026	BDL (0.500)	
17	LC195	3850 S 117th East Ave	7/23/2026	BDL (0.500)	
18	LC216	516 E LATIMER CT	7/23/2026	BDL (0.500)	
19	LC233	6406 E 75th ST	7/23/2026	BDL (0.500)	
20	LC279	8828 S ERIE AVE	7/23/2026	BDL (0.500)	
21	LC248	7325 S ELWOOD AVE	7/24/2026	BDL (0.500)	
22	LC077	9133 S. Darlington	7/27/2026	BDL (0.500)	
23	LC282	8929 S 77th East Ave	7/28/2026	BDL (0.500)	
24	LC270	7947 S LAKEWOOD AVE	7/29/2026	BDL (0.500)	
25	LC115	13104 E 45th ST	7/8/2026	0.519	
26	LC138	1521 S 139th East Ave	7/14/2026	0.543	
27	LC241	6824 S 30th West Ave	7/28/2026	0.587	
28	LC094	10702 S TOLEDO AVE	7/8/2026	0.588	
29	LC255	7704 S 30th West Ave	7/21/2026	0.603	
30	LC099	11115 E 17th PL	7/15/2026	0.630	
31	LC039	6230 E. 49th St.	7/15/2026	0.640	
32	LC199	4029 S 118th East Ave	7/21/2026	0.651	
33	LC170	2904 S 123rd East Ave	7/7/2026	0.656	
34	LC092	10624 E 99th ST	7/9/2026	0.669	
35	LC103	12209 E 30th ST	7/14/2026	0.674	
36	LC201	4134 S NORFOLK AVE	7/21/2026	0.681	
37	LC101	12118 E 29th PL	7/9/2026	0.728	
38	LC036	3704 E. 97th St	8/10/2026	0.762	
39	LC286	9119 S 89th East Ave	7/21/2026	0.784	
40	LC265	7803 S IRVINGTON AVE	7/21/2026	0.809	
41	LC212	4918 S COLUMBIA PL	7/21/2026	0.816	
42	LC113	13003 E 45th ST	7/9/2026	0.910	
43	LC268	7916 E 15th PL	7/21/2026	1.20	
44	LC158	2716 W 67th ST	7/14/2026	1.32	
45	LC206	4501 E 107th ST	7/16/2026	1.33	90th Percentile
46	LC137	1515 E 19th ST	7/15/2026	1.84	
47	LC038	5510 E. 75th St.	7/7/2026	2.01	
48	LC090	1034 E 32nd PL	7/21/2026	2.54	
49	LC129	1404 S 110th East Pl	7/7/2026	3.17	
50	LC183	3125 S COLUMBIA CIR	7/7/2026	5.24	

- * The City of Tulsa is required to perform reduced lead and copper monitoring. Fifty lead and copper tap water samples are collected annually between June 1st and September 30th.
- * Regulatory Action Levels (ALs) that require action from the Public Water Supply are based on 90th percentile values. The AL for lead is 15 ug/L and 1.3 mg/L for copper.
- * The 90th percentile concentration for tap water samples collected during the 2026 monitoring period is 1.33 ug/L for lead and 0.259 mg/L for copper.
- * All results indicated BDL were below the lowest concentration the laboratory can detect.

Rank	LC-CODE	ADDRESS	Sample Date	Copper (mg/L)	
1	LC164	2803 W 64th ST	7/15/2026	0.0233	
2	LC130	1407 S 111th East Ave	7/8/2026	0.0284	
3	LC285	9047 E 95th ST	7/21/2026	0.0365	
4	LC287	9125 S FLORENCE PL	7/21/2026	0.0378	
5	LC084	8634 S. 86th E. Ave	7/14/2026	0.0423	
6	LC286	9119 S 89th East Ave	7/21/2026	0.0531	
7	LC248	7325 S ELWOOD AVE	7/24/2026	0.0689	
8	LC268	7916 E 15th PL	7/21/2026	0.0701	
9	LC195	3850 S 117th East Ave	7/23/2026	0.0727	
10	LC099	11115 E 17th PL	7/15/2026	0.0830	
11	LC158	2716 W 67th ST	7/14/2026	0.0902	
12	LC028	9725 S. 95th E. Ave	7/8/2026	0.0927	
13	LC041	8735 S. 79th E. Ave	7/7/2026	0.0983	
14	LC090	1034 E 32nd PL	7/21/2026	0.0984	
15	LC255	7704 S 30th West Ave	7/21/2026	0.100	
16	LC241	6824 S 30th West Ave	7/28/2026	0.101	
17	LC077	9133 S. Darlington	7/27/2026	0.103	
18	LC236	6710 S 29th West Ave	7/21/2026	0.106	
19	LC109	1243 E 24th ST	7/16/2026	0.107	
20	LC180	3068 W 77th ST	7/9/2026	0.109	
21	LC115	13104 E 45th ST	7/8/2026	0.112	
22	LC036	3704 E. 97th St	8/10/2026	0.118	
23	LC138	1521 S 139th East Ave	7/14/2026	0.121	
24	LC265	7803 S IRVINGTON AVE	7/21/2026	0.123	
25	LC216	516 E LATIMER CT	7/23/2026	0.123	
26	LC206	4501 E 107th ST	7/16/2026	0.127	
27	LC270	7947 S LAKEWOOD AVE	7/29/2026	0.134	
28	LC170	2904 S 123rd East Ave	7/7/2026	0.148	
29	LC137	1515 E 19th ST	7/15/2026	0.152	
30	LC091	10603 E 100th ST	7/16/2026	0.160	
31	LC282	8929 S 77th East Ave	7/28/2026	0.160	
32	LC199	4029 S 118th East Ave	7/21/2026	0.167	
33	LC064	7529 S. Trenton	7/9/2026	0.168	
34	LC037	1928 W. 61st Pl.	7/14/2026	0.168	
35	LC129	1404 S 110th East Pl	7/7/2026	0.194	
36	LC094	10702 S TOLEDO AVE	7/8/2026	0.197	
37	LC103	12209 E 30th ST	7/14/2026	0.200	
38	LC201	4134 S NORFOLK AVE	7/21/2026	0.204	
39	LC101	12118 E 29th PL	7/9/2026	0.211	
40	LC212	4918 S COLUMBIA PL	7/21/2026	0.211	
41	LC166	2806 W 62nd ST	7/9/2026	0.228	
42	LC233	6406 E 75th ST	7/23/2026	0.234	
43	LC279	8828 S ERIE AVE	7/23/2026	0.240	
44	LC183	3125 S COLUMBIA CIR	7/7/2026	0.255	
45	LC092	10624 E 99th ST	7/9/2026	0.259	90th Percentile
46	LC039	6230 E. 49th St.	7/15/2026	0.289	
47	LC262	7742 S ERIE AVE	7/22/2026	0.296	
48	LC113	13003 E 45th ST	7/9/2026	0.313	
49	LC038	5510 E. 75th St.	7/7/2026	0.356	
50	LC088	10123 S GRANITE AVE	7/9/2026	0.360	